

CHAPTER 43

LIQUID CHILLING SYSTEMS

<i>GENERAL CHARACTERISTICS</i>	43.1	<i>CENTRIFUGAL LIQUID CHILLERS</i>	43.8
<i>Principles of Operation</i>	43.1	<i>Equipment Description</i>	43.8
<i>Common Liquid Chilling Systems</i>	43.1	<i>Performance and Operating Characteristics</i>	43.9
<i>Equipment Selection</i>	43.4	<i>Method of Selection</i>	43.10
<i>Control</i>	43.4	<i>Control Considerations</i>	43.11
<i>Standards</i>	43.5	<i>Auxiliaries and Special Applications</i>	43.11
<i>Methods of Testing</i>	43.5	<i>Operation and Maintenance</i>	43.12
<i>General Maintenance</i>	43.5	<i>SCREW LIQUID CHILLERS</i>	43.13
<i>RECIPROCATING LIQUID CHILLERS</i>	43.6	<i>Equipment Description</i>	43.13
<i>Equipment Description</i>	43.6	<i>Performance and Operating Characteristics</i>	43.14
<i>Performance Characteristics and Operating Problems</i>	43.6	<i>Method of Selection</i>	43.14
<i>Method of Selection</i>	43.7	<i>Control Considerations</i>	43.14
<i>Control Considerations</i>	43.7	<i>Auxiliaries and Special Applications</i>	43.15
<i>Special Applications</i>	43.8	<i>Maintenance</i>	43.15

A LIQUID chilling system cools water, brine, or other secondary coolant for air conditioning or refrigeration. The system may be either factory-assembled and wired or shipped in sections for erection in the field. The most frequent application is water chilling for air conditioning, although both brine cooling for low-temperature refrigeration and chilling of fluids in industrial processes are also common.

The basic components of a vapor-compression, liquid chilling system include a compressor, a liquid cooler (evaporator), a condenser, a compressor drive, a liquid refrigerant expansion or flow-control device, and a control center; the system may also include a receiver, an economizer, an expansion turbine, and/or a subcooler. In addition, certain auxiliary components may be used, such a lubricant cooler, lubricant separator, lubricant-return device, purge unit, lubricant pump, a refrigerant transfer unit, refrigerant vents, and/or additional control valves.

GENERAL CHARACTERISTICS

PRINCIPLES OF OPERATION

Liquid (usually water) enters the cooler, where it is chilled by liquid refrigerant evaporating at a lower temperature. The refrigerant vaporizes and is drawn into the compressor, which increases the pressure and temperature of the gas so that it may be condensed at the higher temperature in the condenser. The condenser cooling medium is warmed in the process. The condensed liquid refrigerant then flows back to the evaporator through an expansion device. A fraction of the liquid refrigerant changes to vapor (flashes) as the pressure drops between the condenser and the evaporator. Flashing cools the liquid to the saturated temperature at the evaporator pressure. It produces no refrigeration effect in the cooler. The following modifications (sometimes combined for maximum effect) reduce flash gas and increase the net refrigeration effect per unit of power consumption.

Subcooling. Condensed refrigerant may be subcooled to a temperature below its saturated condensing temperature in either the subcooler section of a water-cooled condenser or a separate heat exchanger. Subcooling reduces the amount of flashing and increases the refrigeration effect in the chiller.

The preparation of this chapter is assigned to TC 8.1, Positive Displacement Compressors, and TC 8.2, Centrifugal Machines.

Economizing. This process can occur either in a direct-expansion (DX), an expansion turbine, or a flash-type system. In a **DX system**, the main liquid refrigerant is usually cooled in the shell of a shell-and-tube heat exchanger, at condensing pressure, from the saturated condensing temperature to within several degrees of the intermediate saturated temperature. Before cooling, a small portion of the liquid flashes and evaporates in the tube side of the heat exchanger to cool the main liquid flow. Although subcooled, the liquid will still be at the condensing pressure.

An **expansion turbine** extracts rotating energy as a portion of the refrigerant vaporizes. As in the DX system, the remaining liquid is supplied to the cooler at the intermediate pressure.

In a **flash-type system**, the entire liquid flow is expanded to the intermediate pressure in a vessel that supplies liquid to the cooler at the saturated intermediate pressure; however, the liquid is at the intermediate pressure.

In any case, the flash gas enters the compressor at either an intermediate stage of a multistage centrifugal compressor, at the intermediate stage of an integral two-stage reciprocating compressor, at an intermediate pressure port of a screw compressor, or at the inlet of a high-pressure stage on a multistage reciprocating or screw compressor.

Liquid Injection. Condensed liquid is throttled to the intermediate pressure and injected into the second-stage suction of the compressor to prevent excessively high discharge temperatures and, in the case of centrifugal machines, to reduce noise. In the case of screw compressors, condensed liquid is injected into a port fixed at slightly below discharge pressure to provide lubricant cooling.

COMMON LIQUID CHILLING SYSTEMS

Basic System

The refrigeration cycle of a basic system is shown in [Figure 1](#). Chilled water enters the cooler at 12°C, for example, and leaves at 7°C. Condenser water leaves a cooling tower at 30°C, enters the condenser, and returns to the cooling tower near 35°C. Condensers may also be cooled by air or through evaporation of water. This system, with a single compressor and one refrigerant circuit with a water-cooled condenser, is used extensively to chill water for air conditioning because it is relatively simple and compact.

These liquid chillers are available with hermetic, semihermetic, and open compressors with various means of starting.




Fig. 1 Equipment Diagram for Basic Liquid Chiller

Multiple Chiller Systems

A multiple chiller system has two or more chillers connected by parallel or series piping to a common distribution system. Multiple chillers offer operational flexibility, standby capacity, and less disruptive maintenance. The chillers can be sized to handle a base load and increments of a variable load to allow each chiller to operate at its most efficient point.

Multiple chiller systems offer some standby capacity if repair work must be done on one chiller. Starting in-rush current is reduced, as well as power costs at partial-load conditions. Maintenance can be scheduled for one chilling machine during part-load times, and sufficient cooling can still be provided by the remaining unit(s). These advantages require an increase in installation cost and space, however.

Water should flow constantly through the chillers for stable control. Load variation is temperature-related and is easily detected by temperature controls. In contrast, when water flow varies the load becomes flow-related. Because a temperature control system cannot sense a variation in flow, it is unable to maintain stable control. However, some applications do have variable water flow through the cooling coils. In this case, a decoupled system is typically used to separate the distribution pumping from the production pumping. It allows variable flow through the cooling coils but maintains constant water flow through the chillers, allowing good control of the multiple chillers.

A typical decoupled system is shown in Figure 2. The multiple pumps are connected by a bypass pipe that connects the return and supply headers. Each chiller-pump combination operates independently from the remaining chillers. Capacity control is simplified and as if each chiller operated alone. Instead of using temperature as an indicator of demand, relative flow is the indicator. If greater flow is demanded than that supplied by the chiller-pumps, return water is forced through the bypass into the supply header. This flow indicates a need for additional chiller capacity and another chiller-pump starts. Bypass flow in the opposite direction indicates overcapacity and the chiller-pumps are turned off.

Two basic multiple chiller systems are used: parallel and series chilled water flow. In the **parallel arrangement**, liquid to be chilled is divided among the liquid chillers; the multiple chilled streams are combined again in a common line after chilling. As the cooling load decreases, one unit may be shut down. Unless water flow is stopped through the inoperative chiller, the remaining unit(s) provide colder-than-design chilled liquid. The combined streams (including one




Fig. 2 Decoupled System

from the idle chiller) then supply the chilled water at the design temperature in the common line.

When the design chilled water temperature is above about 7°C, all units should be controlled by the combined exit water temperature or by the return water temperature (RWT), since overchilling will not cause dangerously low water temperature in the operating machine(s). Chilled water temperature can be used to cycle one unit off when it drops below a capacity that can be matched by the remaining units.

When the design chilled water temperature is below about 7°C, each machine should be controlled by its own chilled water temperature, both to prevent dangerously low evaporator temperatures and to avoid frequent shutdowns by the low-temperature cutout. In this case, the temperature differential setting of the RWT must be adjusted carefully to prevent short cycling caused by the step increase in chilled water temperature when one chiller is cycled off. These control arrangements are shown in Figures 3 and 4.

In the **series arrangement**, the chilled liquid pressure drop may be higher if shells with fewer liquid-side passes or baffles are not available. No overchilling by either unit is required, and compressor power consumption is lower than it is for the parallel arrangement at partial loads. Because the evaporator temperature never drops below the design value (because no overchilling is necessary), the chances of evaporator freezeup are minimized. However, the chiller should still be protected by a low-temperature safety control.

Water-cooled condensers in series are best piped in a counterflow arrangement so that the lead machine is provided with warmer condenser and chilled water and the lag machine is provided with colder entering condenser and chilled water. Refrigerant compression for each unit is nearly the same. If about 55% of design cooling capacity is assigned to the lead machine and about 45% to the lag machine, identical units can be used. In this way, either machine can provide the same standby capacity if the other is down, and lead and lag




Fig. 3 Parallel Operation High Design Water Leaving Coolers (Approximately 7°C and Above)




Fig. 4 Parallel Operation Low Design Water Leaving Coolers (Below Approximately 7°C)

machines may be interchanged to equalize the number of operating hours on each.

A control system for two machines in series is shown in [Figure 5](#). (On reciprocating chillers, RWT sensing is usually used instead of leaving water sensing because it allows closer temperature control.) Both units are modulated to a certain capacity; then, one unit shuts down, leaving less than 100% load on the operating machine.

One machine should be shut down as soon as possible, with the remaining unit carrying the full load. This not only reduces the number of operating hours on a unit, but also leads to less total power consumption because the COP tends to decrease below the full load value when unit load drops much below 50%.

Heat-Recovery Systems

Any building or plant requiring the simultaneous operation of heat-producing and cooling equipment has the potential for a heat-recovery installation. Heat-recovery equipment should be considered for all new or retrofit installations. In some cases, the installed cost may be less because of the elimination or reduction of both heating equipment and the space required for it.

Heat-recovery systems extract heat from chilled liquid and reject some of that heat, plus the energy of compression, to a warm-water circuit for reheat or heating. Air-conditioned spaces thus furnish heating for other spaces in the same building. During the full-cooling season, all heat must be rejected outdoors, usually by a cooling




Fig. 5 Series Operation




Fig. 6 Heat-Recovery Control System

tower. During spring or fall, some heat is required inside, while a portion of the heat extracted from the air-conditioned spaces must be rejected outside simultaneously.

Heat recovery offers the user low heating costs and reduces space requirements for mechanical equipment. A control system must be designed carefully, however, to take the greatest advantage of the recovered heat and to maintain proper temperature and humidity in all parts of the building. [Chapter 8 of the ASHRAE Handbook—Systems and Equipment](#) covers balanced heat-recovery systems.

Since cooling tower water is not satisfactory for heating coils, a separate, closed warm-water circuit with another condenser bundle or auxiliary condenser, in addition to the main water chiller condenser, must be provided. In some cases, it is economically feasible to use a standard condenser and a closed-circuit water cooler.

A suggested control scheme is shown in [Figure 6](#). The heating water temperature is controlled by a cooling tower bypass valve, which modulates the flow of condenser cooling water to the tower. An outside air thermostat resets the hot water control point upward as the outdoor temperature drops and resets the chilled water temperature control point upward on colder days. In this

way, extra power is not consumed unnecessarily by the compressor in attempting to maintain summer design coil temperatures during dry, cold outdoor conditions.

EQUIPMENT SELECTION

The largest factor that determines total liquid chiller owning cost is the cooling load size; therefore, the total required chiller capacity should be calculated accurately. The practice of adding 10 to 20% to load estimates is unnecessary because of the availability of accurate load estimating methods, and it proportionately increases costs related to equipment purchase, installation, and the poor efficiency resulting from wasted power. Oversized equipment can also cause operational difficulties such as frequent on-off cycling or surging of centrifugal machines at low loads. The penalty for a small underestimation of cooling load, however, is not serious. On the few design load days of the year, an increase in chilled liquid temperature is often acceptable. However, for some industrial or commercial loads, a safety factor can be added to the load estimate.

The life-cycle cost as discussed in [Chapter 36 of the ASHRAE Handbook—Applications](#) should be used to minimize the overall purchase and operating costs. Total owning cost is composed of the following:

- **Equipment Price.** Each machine type and/or manufacturer's model should include all the necessary auxiliaries such as starters and vibration mounts. If these are not included, their price should be added to the base price. Associated equipment, such as condenser water pump, tower, and piping, should be included.
- **Installation Cost.** Factory-packaged machines are both less expensive to install and usually considerably more compact, resulting in space savings. The cost of field assembly of field-erected chillers must also be evaluated.
- **Energy Cost.** Using an estimated load schedule and part-load power consumption curves furnished by the manufacturer, a year's energy cost should be calculated.
- **Water Cost.** With water cooled towers, the cost of acquisition, water treatment, tower blowdown, and overflow water should be included.
- **Maintenance Cost.** Each bidder may be asked to quote on a maintenance contract on a competitive basis.
- **Insurance and Taxes.**

For package chillers that include heat recovery, system cost and performance should be compared in addition to equipment costs. For example, the heat-recovery chiller installed cost should be compared with the installed cost of a chiller plus a separate heating system. The following factors should also be considered: (1) energy costs, (2) maintenance requirements, (3) life expectancy of equipment, (4) standby arrangement, (5) relationship of heating to cooling loads, (6) effect of package selection on sizing, and (7) type of peripheral equipment.

Condensers and coolers are often available with either **liquid heads**, which require the water pipes to be disconnected for tube access and maintenance, or **marine-type water boxes**, which permit tube access with water piping intact. The liquid head is considerably lower in price. The cost of disconnecting piping must be greater than the additional cost of marine-type water boxes to justify the latter's use. Typically, an elbow and union or flange connection is installed only to facilitate the removal of heads.

These methods are helpful in choosing between equipment types and makes. [Chapter 36 of the ASHRAE Handbook—Applications](#) has further cost information.

The following types of liquid chillers are generally used for air conditioning:

Up to 90 kW — Reciprocating or scroll

90 to 280 kW — Screw, reciprocating, or scroll
 280 to 1600 kW — Screw, reciprocating, or centrifugal
 700 to 3500 kW — Screw or centrifugal
 3500 kW — Centrifugal

For air-cooled condenser duty, brine chilling, or other high pressure applications from 280 to about 700 kW, reciprocating and screw liquid chillers are more frequently installed than centrifugals. Centrifugal liquid chillers (particularly multistage machines), however, may be applied quite satisfactorily at high pressure conditions.

Factory packages are available to about 8400 kW and field-assembled machines to about 35 MW.

CONTROL

Liquid Chiller Controls

The **chilled liquid temperature sensor** sends an air pressure (pneumatic control) or electrical signal (electronic control) to the control circuit, which then modulates compressor capacity in response to leaving or return chilled liquid temperature change from its set point.

Compressor capacity adjustment is accomplished differently on the following liquid chillers:

Reciprocating chillers use combinations of cylinder unloading and on-off compressor cycling of single or multiple compressors.

Centrifugal liquid chillers, driven by electric motors, commonly use adjustable prerotation vanes, which are sometimes combined with movable diffuser walls. Turbine and engine drives and inverter-driven, variable-speed electric motors allow the use of speed control in addition to prerotation vane modulation, reducing power consumption at partial loads.

Screw compressor liquid chillers include a slide valve that adjusts the length of the compression path. Inverter-driven, variable-speed electric motors and turbine and engine drives can also modulate screw compressor speed to control capacity.

In air-conditioning applications, most centrifugal and screw compressor chillers modulate from 100% to approximately 10% load. Although relatively inefficient, hot-gas bypass can be used to reduce capacity to nearly 0% with the unit in operation.

Reciprocating chillers are available with simple on-off cycling control in small capacities and with multiple steps of unloading down to 12.5% in the largest multiple compressor units. Most intermediate sizes provide unloading to 50, 33, or 25% capacity. Hot-gas bypass can reduce capacity to nearly 0%.

The **water temperature controller** is a thermostatic device that unloads or cycles the compressor(s) when the cooling load drops below minimum unit capacity. An antirecycle timer is sometimes used to limit starting frequency.

On centrifugal or screw compressor chillers, a **current limiter** or **demand limiter** limits compressor capacity during periods of possible high power consumption (such as pulldown) to prevent current draw from exceeding the design value; such a limiter can be set to limit demand, as described in the section on Centrifugal Liquid Chillers.

Controls That Influence the Liquid Chiller

Condenser cooling water may need to be controlled to regulate condenser pressure. Normally, the temperature of the water leaving a cooling tower can be controlled by fans, dampers, or a water bypass around the tower. Bypass around the tower allows the water velocity through the condenser tubes to be maintained, which prevents low-velocity fouling.

A flow-regulating valve is another common means of control. The orifice of this valve modulates in response to condenser pressure. For example, a reduction in pressure decreases the water flow,

which, in turn, raises the condenser pressure to the desired minimum level.

For air-cooled or evaporative condensers, compressor discharge pressure can be controlled by cycling fans, shutting off circuits, or flooding coils with liquid refrigerant to reduce the heat transfer.

A reciprocating chiller usually has a thermal expansion valve, which requires a restricted range of pressure to avoid starving the evaporator (at low pressure).

An expansion valve(s) usually controls a screw compressor chiller. Cooling tower water temperature can be allowed to fall with decreasing load from the design condition to the chiller manufacturer's recommended minimum limit.

Screw compressor chillers above 500kW may use flooded-type evaporators and evaporator liquid refrigerant controls similar to those used on centrifugal chillers.

A thermal expansion valve may control a centrifugal chiller at low capacities, while higher capacity machines employ a high-pressure float, orifice(s), or even a low-side float valve to control refrigerant liquid flow to the cooler. These latter types of controls allow relatively low condenser pressures, particularly at partial loads. Also, a centrifugal machine may surge if pressure is not reduced when cooling load decreases. In addition, low pressure reduces compressor power consumption and operating noise. For these reasons, in a centrifugal installation, cooling tower water temperature should be allowed to fall naturally with decreasing load and wet-bulb temperature, except that the liquid chiller manufacturer's recommended minimum limit must be observed.

Safety Controls

Some or all of the cutouts listed below may be provided in a liquid chilling package to stop the compressor(s) automatically. Cutouts may be manual or automatic reset.

- **High Condenser Pressure.** This pressure switch opens if the compressor discharge pressure exceeds the value prescribed in ASHRAE *Standard* 15.
- **Low Refrigerant Pressure (or Temperature).** This device opens when evaporator pressure (or temperature) reaches a minimum safe limit.
- **High Lubricant Temperature.** This device protects the compressor if loss of lubricant cooling occurs or if a bearing failure causes excessive heat generation.
- **High Motor Temperature.** If loss of motor cooling or overloading because of a failure of a control occurs, this device shuts down the machine. It may consist of direct-operating bimetallic thermostats, thermistors, or other sensors embedded in the stator windings; it may be located in the discharge gas stream of the compressor.
- **Motor Overload.** Some small, reciprocating compressor hermetic motors may use a directly operated overload in the power wiring to the motor. Some larger motors use pilot-operated overloads. Centrifugal and screw compressor motors generally use starter overloads or current-limiting devices to protect against overcurrent.
- **Low Lubricant Sump Temperature.** This switch is used either to protect against a lubricant heater failure or to prevent starting after a prolonged shutdown before the lubricant heaters have had time to drive off refrigerant dissolved in the lubricant.
- **Low Lubricant Pressure.** To protect against clogged lubricant filters, blocked lubricant passageways, loss of lubricant, or a lubricant pump failure, a switch shuts down the compressor when lubricant pressure drops below a minimum safe value or if sufficient lubricant pressure is not developed shortly after the compressor starts.
- **Chilled Liquid Flow Interlock.** This device may not be furnished with the liquid chilling package, but it is needed in the

external piping to protect against a cooler freezeup in case the liquid stops flowing. An electrical interlock is typically installed.

- **Condenser Water Flow Interlock.** This device, which is similar to the chilled liquid flow interlock, is sometimes used in the external piping.
- **Low Chilled Liquid Temperature.** Sometimes called **freeze protection**, this cutout operates at a minimum safe value of leaving chilled liquid temperature to prevent cooler freezeup in the case of an operating control malfunction.
- **Relief Valves.** In accordance with ASHRAE *Standard* 15, relief valves, rupture disks, or both, set to relieve at the shell design working pressure, must be provided on most pressure vessels or on piping connected to the vessels. Fusible plugs may also be used in some locations. Pressure relief devices should be vented outdoors or to the low-pressure side, in accordance with regulations or the standard.

STANDARDS

ARI *Standards* 550, Centrifugal and Rotary Screw Water-Chilling Packages, and 590, Positive Displacement Compressor, provide guidelines for the rating of centrifugal and reciprocating liquid chilling machines, respectively.

The design and construction of refrigerant pressure vessels are governed by the ASME *Boiler and Pressure Vessel Code*, Section VIII, except when design working pressure is 103 kPa or less (as is usually the case for R-123 liquid chilling machines). The water-side design and construction of a condenser or cooler is not within the scope of the ASME code unless the design pressure is greater than 2.1 MPa or the design temperature is greater than 99°C.

ASHRAE *Standard* 15, Safety Code for Mechanical Refrigeration, applies to all liquid chillers and new refrigerants on the market. New standards for equipment rooms are included. Methods for the measurement of unit sound levels are described in ARI *Standard* 575, Method of Measuring Machinery Sound Within an Equipment Space.

METHODS OF TESTING

All tests of reciprocating liquid chillers for rating or verification of rating should be conducted in accordance with ASHRAE *Standard* 30, Methods of Testing Liquid Chilling Packages. Centrifugal or screw liquid chiller ratings should be derived and verified by test in accordance with ARI *Standard* 550.

GENERAL MAINTENANCE

The following general maintenance specifications apply to reciprocating, centrifugal, and screw chillers. The equipment should be neither overmaintained nor neglected. A preventive maintenance schedule should be established; the items covered can vary with the nature of the application. The list is intended as a guide; in all cases, the manufacturer's specific recommendation should be followed.

Continual Monitoring

- Condenser water treatment—treatment is determined specifically for the condenser water used.
- Operating conditions—daily log sheets should be kept to indicate trends and provide an advanced notice of deteriorating chillers.
- Brine quality for concentration and corrosion inhibitor levels.

Periodic Checks

- Leak check
- Purge operation
- System dryness
- Lubricant level
- Lubricant filter pressure drop
- Refrigerant quantity or level

- System pressures and temperatures
- Water flows
- Expansion valves operation

Regularly Scheduled Maintenance

- Condenser and lubricant cooler cleaning
- Evaporator cleaning on open systems
- Calibrating pressure, temperature, and flow controls
- Tightening wires and power connections
- Inspecting starter contacts and action
- Checking safety interlocks
- Dielectric checking of hermetic and open motors
- Tightness of hot gas valve
- Lubricant filter and drier change
- Analyzing lubricant and refrigerant
- Seal inspection
- Partial or complete valve or bearing inspection, as per manufacturer's recommendations
- Checking vibration levels

Extended Maintenance Checks

- Compressor guide vanes and linkage operation and wear
- Eddy current inspection of heat exchanger tubes
- Compressor teardown and inspection of rotating components
- Other components as recommended by manufacturer

RECIPROCATING LIQUID CHILLERS

EQUIPMENT DESCRIPTION

Components and Their Function

The reciprocating compressor described in [Chapter 34 of the ASHRAE Handbook—Systems and Equipment](#) is a positive-displacement machine that maintains fairly constant volume flow rate over a wide range of pressure ratios. The following types of compressors are commonly used in liquid chilling machines:

- Welded hermetic, to about 90 kW chiller capacity
- Semihermetic, to about 700 kW chiller capacity
- Direct-drive open, to about 1600 kW chiller capacity

Open motor-driven liquid chillers are usually more expensive than hermetically sealed units, but they can be more efficient. Hermetic motors are generally suction gas cooled; the rotor is mounted on the compressor crankshaft.

Condensers may be evaporative, air- or water-cooled. Water-cooled versions may be either tube-in-tube, shell-and-coil, shell-and-tube, or plate type heat exchangers. Most shell-and-tube condensers can be repaired, while others must be replaced if a refrigerant-side leak occurs.

Air-cooled condensers are much more common than evaporative condensers. Less maintenance is needed for air-cooled heat exchangers than for the evaporative type. Remote condensers can be applied with condenserless packages. (Information on condensers can be found in [Chapter 35 of the ASHRAE Handbook—Systems and Equipment](#).)

Coolers are usually direct-expansion, in which refrigerant evaporates while it is flowing inside tubes and chilled liquid is cooled as it is guided several times over the outside of the tubes by shell-side baffles. Flooded coolers are sometimes used on industrial chillers. Flooded coolers maintain a level of refrigerant liquid on the shell side of the cooler, while the liquid to be cooled flows through tubes inside the cooler. Tube-in-tube coolers are sometimes used with small machines; they offer low cost when repairability and installation space are not important criteria. (A detailed description of cool-

ers can be found in [Chapter 37 of the ASHRAE Handbook—Systems and Equipment](#).)

The **thermal expansion** valve, capillary, or other expansion device modulates refrigerant flow from the condenser to the cooler to maintain enough suction superheat to prevent any unevaporated refrigerant liquid from reaching the compressor. Excessively high values of superheat are avoided so that unit capacity is not reduced. (For additional information, see [Chapter 45](#).)

Lubricant cooling is not usually required for air conditioning. However, if lubricant cooling is necessary, a refrigerant-cooled coil in the crankcase or a water-cooled cooler may be used. Lubricant coolers are often used in conjunction with low suction temperatures or high-pressure ratio applications when extra lubricant cooling is needed.

Capacities and Types Available

Available capacities range from about 7 to 1600 kW. Multiple reciprocating compressor units have become popular for the following reasons:

- The number of capacity increments is greater, resulting in closer liquid temperature control, lower power consumption, less current inrush during starting, and extra standby capacity.
- Multiple refrigerant circuits are used, resulting in the potential for limited servicing or maintenance of some components while maintaining cooling.

Selection of Refrigerant

R-12 and R-22 have been the primary refrigerants used in chiller applications. CFC-12 has been replaced with HFC-134a, which has similar properties. However, R-134a requires synthetic lubricants because it is not miscible with mineral oils. R-134a is suitable for both open and hermetic compressors.

R-22 provides greater capacity than R-134a for a given compressor displacement. R-22 is used for most open and hermetic compressors, but as an HCFC, it is scheduled for phaseout in the future. R-717 (ammonia) has similar capacity characteristics to R-22, but, because of odor and toxicity, R-717 is subject to restrictions for use in public or populated areas. However, R-717 chillers are becoming more popular because of bans on CFC and HCFC refrigerants. R-717 units are open-drive compressors and are piped with steel because copper cannot be used in ammonia systems.

PERFORMANCE CHARACTERISTICS AND OPERATING PROBLEMS

A distinguishing characteristic of the reciprocating compressor is its pressure rise versus capacity. Pressure rise has only a slight influence on the volume flow rate of the compressor, and, therefore, a reciprocating liquid chiller retains nearly full cooling capacity, even on above design wet-bulb days. It is well suited for air-cooled condenser operation and low-temperature refrigeration. A typical performance characteristic is shown in [Figure 7](#) and compared with the centrifugal and screw compressors. Methods of capacity control include the following:

- Unloading of compressor cylinders (one at a time or in pairs)
- On-off cycling of compressors
- Hot-gas bypass
- Compressor speed control
- Combination of the previous methods

[Figure 8](#) illustrates the relationship between system demand and performance of a compressor with three steps of unloading. As cooling load drops to the left of the fully loaded compressor line (A), compressor capacity is reduced to that represented by line (B), which produces the required refrigerant flow. Because cooling load varies continuously but machine capacity is available in fixed incre-




Fig. 7 Comparison of Single-Stage Centrifugal, Reciprocating, and Screw Compressor Performance




Fig. 8 Reciprocating Liquid Chiller Performance with Three Equal Steps of Unloading

ments, some compressor on-off cycling or successive loading and unloading of cylinders is required to maintain fairly constant liquid temperature. In practice, a good control system minimizes the load-unload or on-off cycling frequency while maintaining satisfactory temperature control.

METHOD OF SELECTION

Ratings

Two types of ratings are published. The first, for a packaged liquid chiller, lists values of capacity and power consumption for many combinations of leaving condenser water and chilled water temperatures (ambient dry-bulb temperatures for air-cooled models). The second type of rating shows capacity and power consumption for different condensing temperatures and chilled water temperatures. This type of rating permits selection with a remote condenser that can be evaporative, water, or air cooled. Sometimes

the required rate of heat rejection is also listed to aid in selection of a separate condenser.

Power Consumption

With all liquid chilling systems, power consumption increases as condensing temperature rises. Therefore, the smallest package, with the lowest ratio of input to cooling capacity, can be used when condenser water temperature is low, the remote air-cooled condenser is relatively large, or when leaving chilled water temperature is high. The cost of the total system, however, may not be low when liquid chiller cost is minimized. Increases in cooling tower or fan coil cost will reduce or offset the benefits of reduced compression ratio. Life-cycle costs (initial cost plus operating expenses) should be evaluated.

Fouling

A fouling allowance of $0.044 \text{ m}^2 \cdot \text{K/kW}$ is included in manufacturers' ratings in accordance with ARI *Standard* 590. However, fouling factors greater than 0.044 should be considered in the selection if water conditions are other than ideal.

CONTROL CONSIDERATIONS

A reciprocating chiller is distinguished from centrifugal and screw compressor-operated chillers by its use of increments of capacity reduction rather than continuous modulation. Therefore, special arrangements must be used to establish precise chilled liquid temperature control while maintaining stable operation free from excessive on-off cycling of compressors or unnecessary loading and unloading of cylinders.

To help provide good temperature control, return chilled liquid temperature sensing is normally used by units with steps of capacity control. The resulting flywheel effect in the chilled liquid circuit damps out excessive cycling. Leaving chilled liquid temperature sensing has the advantage of preventing excessively low leaving chilled liquid temperatures if chilled liquid flow falls significantly below the design value. It may not provide stable operation, however, if rapid changes in load are encountered.

An example of a basic control circuit for a single compressor-packaged reciprocating chiller with three steps of unloading is shown in Figure 9. The unit is started by moving the on-off switch to the on position. The programmed timer will start operating. Assuming that the flow switch, field interlocks, and chiller safety devices are closed, pressing the momentarily closed reset button will energize control relay C1, locking in the safety circuit and the motor starting circuit. When the timer completes its program, timer switch 1 closes and timer switch 2 opens. Timer relay TR energizes, stopping the timer motor. When timer switch 1 closes, the motor starting circuit is completed and the motor contactor holding coil is energized, starting the compressor.

The four-stage thermostat controls the capacity of the compressor in response to the demand of the system. Cylinders are loaded and unloaded by de-energizing and energizing the unloader solenoids. If the load is reduced so that the return water temperature drops to a predetermined setting, the unit shuts down until the demand for cooling increases.

Opening a device in the safety circuit will de-energize control relay C1 and shut down the compressor. The liquid line solenoid is also de-energized. Manual reset is required to restart. The crankcase heater is energized whenever the compressor is shut down.

If the automatic reset, low-pressure cutout opens, the compressor shuts down, but the liquid line solenoid remains energized. The timer relay (TR) is de-energized, causing the timer to start and complete its program before the compressor can be restarted. This prevents rapid cycling of the compressor under low-pressure conditions. A time delay low-pressure switch can also be used for this purpose with the proper circuitry.




Fig. 9 Reciprocating Liquid Chiller Control System

SPECIAL APPLICATIONS

For multiple chiller applications and a 5 K chilled liquid temperature range, the use of a parallel chilled liquid arrangement is common because of the high cooler pressure drop resulting from the series arrangement. For a large (10 K) range, however, the series arrangement eliminates the need for overcooling during operation of one unit only. Special coolers with low water pressure drop may also be used to reduce total chilled water pressure drop in the series arrangement.

CENTRIFUGAL LIQUID CHILLERS

EQUIPMENT DESCRIPTION

Components and Their Function

The centrifugal compressor is described in [Chapter 34 of the ASHRAE Handbook—Systems and Equipment](#). Because it is not a constant displacement machine, it offers a wide range of capacities continuously modulated over a limited range of pressure ratios. By altering built-in design items (including number of stages, compressor speed, impeller diameters, and choice of refrigerant), it can be used in liquid chillers having a wide range of design chilled liquid temperatures and design cooling fluid temperatures. Its ability to vary capacity continuously to match a wide range of load conditions with nearly proportional changes in power consumption makes it

desirable for both close temperature control and energy conservation. Its ability to operate at greatly reduced capacity allows it to run most of the time with infrequent starting.

The hour of the day for starting an electric-drive centrifugal liquid chiller can often be chosen by the building manager to minimize peak power demands. It has a minimum of bearing and other contacting surfaces that can wear; this wear is minimized by providing forced lubrication to those surfaces prior to startup and during shutdown. Bearing wear usually depends more on the number of start-ups than the actual hours of operation. Thus, by reducing the number of startups, the life of the system is extended, and maintenance costs are reduced.

Both open and hermetic compressors are manufactured. Open compressors may be driven by steam turbines, gas turbines or engines, or electric motors, with or without speed-changing gears. (Engine and turbine drives are covered in detail in [Chapter 7](#) and electric motor drives in [Chapter 40 of the ASHRAE Handbook—Systems and Equipment](#).)

Packaged electric-drive chillers may be open or hermetic and use two-pole, 50 or 60 Hz polyphase electric motors, with or without speed-increasing gears. Hermetic units use only polyphase induction motors. Speed-increasing gears and their bearings, in most open and hermetic packaged chillers, operate in a refrigerant atmosphere, and the lubrication of their contacting surfaces is incorporated in the compressor lubrication system.

Magnetic and silicon controlled rectifier (SCR) motor controllers are used with packaged chillers. When purchased separately, the controller must meet the specifications of the chiller manufacturer to ensure adequate equipment safety. When timed step starting methods are used, the time between steps should be long enough for the motor to overcome the relatively high inertia of the compressor and attain sufficient speed to minimize the electric current drawn immediately after transition.

Flooded coolers are commonly used, although direct-expansion coolers are used by some manufacturers in the lower capacity ranges. The typical flooded cooler uses copper tubes or copper alloy that are mechanically expanded into the tube sheets, and, in some cases, into intermediate tube supports, as well.

Because liquid refrigerant that flows into the compressor increases power consumption and may cause internal damage, mist eliminators or baffles are often used in flooded coolers to minimize refrigerant liquid entrainment in the suction gas. (Additional information on coolers for liquid chillers can be found in [Chapter 37 of the ASHRAE Handbook—Systems and Equipment](#).)

The condenser is generally water-cooled, with refrigerant condensing on the outside of copper tubes. Large condensers may have refrigerant drain baffles, which direct the condensate from within the tube bundle directly to the liquid drains, reducing the thickness of the liquid film on the lower tubes.

Air-cooled condensers can be used with units that use higher-pressure refrigerants, but with considerable increase in unit energy consumption at design conditions. Operating costs should be compared with systems using cooling towers and condenser water circulating pumps.

System modifications, including subcooling and economizing (described under Principles of Operation) are often used to conserve energy. Some units combine the condenser, cooler, and refrigerant flow control in one vessel; a subcooler may also be incorporated. (Additional information concerning thermodynamic cycles can be found in [Chapter 1 of the ASHRAE Handbook—Fundamentals](#). For information on condensers and subcoolers, see [Chapter 35 of the ASHRAE Handbook—Systems and Equipment](#).)

Capacities and Types Available

Centrifugal packages are currently available from about 300 to 8500 kW at nominal conditions of 7°C leaving chilled water temperature and 35°C leaving condenser water temperature. This upper

limit is continually increasing. Field-assembled machines extend to about 35 MW. Single-stage and two-stage internally geared machines and two- and three-stage direct-drive machines are commonly used in packaged units. Electric motor-driven machines constitute the majority of units sold.

Units with hermetic motors, cooled by refrigerant gas or liquid, are offered from about 300 to 7000 kW. Open-drive units are not offered by all hermetic manufacturers in the same size increments but are generally available from 300 kW to 35 MW.

Selection of Refrigerant

In choosing refrigerant, the manufacturer considers coefficient of performance, operating pressures, heat-transfer properties, flow rate, stability, toxicity, flammability, cost, and availability for their machine designs. Halogenated hydrocarbons are normally used as refrigerants because they offer reasonable characteristics with respect to the application. ASHRAE *Standards* 15 and 34 cover the use, handling, and numbering of refrigerants.

The centrifugal compressor is particularly suitable for handling relatively large flows of suction vapor. As the volumetric flow of suction vapor increases with higher capacities and lower suction temperatures, the higher pressure refrigerants, for example, R-134a and R-22, are used. The physical size and weight of the refrigerant piping and, often, other components of the refrigeration system are reduced by the use of higher pressure refrigerants. In order of decreasing volumetric flow and increasing pressures are refrigerants R-113, R-123, R-11, R-114, R-134a, R-12 or R-500, and R-22. The CFC refrigerants R-11, R-12, R-113, R-114, and R-500 have been phased out.

Pressure vessels for use with R-123 usually have a design working pressure of 103 kPa on the refrigerant side. The vessel shells are usually stronger than necessary for this requirement to ensure sufficient rigidity and prevent collapse under vacuum.

The thermal stability of the refrigerant and its compatibility with materials it contacts are also important. Selection of elastomers and electrical insulating materials require special attention because many of these materials are affected by the refrigerants. (Additional information concerning refrigerants can be found in [Chapters 18 and 19 of the ASHRAE Handbook—Fundamentals](#).)

PERFORMANCE AND OPERATING CHARACTERISTICS

[Figure 10](#) illustrates a compressor's performance at constant speed with various inlet guide vane settings. [Figure 11](#) illustrates that compressor's performance at various speeds with open inlet guide vanes. Capacity is modulated at constant speed by automatic adjustment of prerotation vanes that whirl the refrigerant gas at the impeller eye. This effect matches system demand by shifting the compressor performance curve downward and to the left (as shown in [Figure 10](#)). Compressor efficiency, when unloaded in this manner, is superior to suction throttling. Some manufacturers also automatically reduce diffuser width or throttle the impeller outlet with decreasing load.

Speed control for a centrifugal compressor offers even lower power consumption. Down to about 50% capacity or at off design conditions, the speed may be reduced gradually without surging. Control is transferred to the prerotation vanes for operation at lower loads. While capacity is related directly to a change in speed, the pressure produced is proportional to the square of the change in speed. Therefore, the pressure produced by reducing the speed may be less than that required by the load. Combined use of gas bypass, prerotation vanes, etc., would then be necessary.

A **gas bypass** allows the compressor to operate down to zero load. This feature is a particular advantage for such intermittent industrial applications as the cooling of quenching tanks. Bypass vapor obtained by either method maintains the power consumption




Fig. 10 Typical Centrifugal Compressor and System at Constant Speed




Fig. 11 Typical Centrifugal Compressor Performance at Various Speeds

at the same level attained just prior to starting bypass, regardless of load reductions. At light loads, some bypass vapor, if introduced into the cooler below the tube bundle, may increase the evaporating temperature by agitating the liquid refrigerant and thereby more thoroughly wetting the tube surfaces.




Fig. 12 Temperature Relations in a Typical Centrifugal Liquid Chiller

Figure 12 shows how **temperature lift** varies with load. A typical reduction in entering condenser water temperature of 5 K helps to reduce temperature lift at low load. Other factors producing lower lift at reduced loads are

- Reduction in condenser cooling water range (the difference between entering and leaving temperatures, resulting from decreasing heat rejection)
- Decrease in temperature difference between condensing refrigerant and leaving condenser water
- Similar decrease between evaporating refrigerant and leaving chilled liquid temperature

In many cases, the actual reduction in temperature lift is even greater because the wet-bulb temperature usually drops with the cooling load, producing a greater decrease in entering condenser water temperature.

As stated earlier, speed control is usually used from 100% down to about 50% load or at off-design conditions; below 50%, inlet vane control is used. Power consumption is reduced when the coldest possible condenser water is used, consistent with the chiller manufacturer's recommended minimum condenser water temperature. In cooling tower applications, minimum water temperatures should be controlled by a cooling tower bypass and/or by cooling tower fan control, not by reducing the water flow through the condenser. Maintaining a high flow rate at lower temperatures minimizes fouling and power requirements.

Surging occurs when the system specific work becomes greater than the compressor developed specific work or above the surge line indicated in Figures 10 and 11. Excessively high temperature lift and corresponding specific work commonly originate from

- Excessive condenser or evaporator water-side fouling beyond the specified allowance
- Inadequate cooling tower performance and higher-than-design condenser water temperature
- Noncondensables in the condenser, which increase condenser pressure.

METHOD OF SELECTION

Ratings

A refrigeration machine with specified details is chosen from selection tables for given capacities and operating conditions, or through computer-generated selection or performance programs. Rating tables differ from selection tables in that they list the capacities and operating data for each refrigeration machine under various operating conditions, often with specific details for the listed conditions. The details specified for centrifugal systems include the number of passes and the water-side pressure drop in each of the heat exchangers, the required power input, electrical characteristics, and part-load performance.

The maximum number of condenser and cooler water passes should be used, without producing excessive water pressure drop. The greater the number of water-side passes, the less the power consumption. Sometimes a slight reduction in condenser water flow (and slightly higher leaving water temperature) allows a better selection (lower power consumption or smaller model) than will the choice of fewer water passes when a rigid pressure-drop limit exists.

Fouling

In accordance with ARI *Standard* 590, a fouling allowance of $0.044 \text{ m}^2 \cdot \text{K/kW}$ is included in manufacturers' ratings. ([Chapter 35 of the ASHRAE Handbook—Systems and Equipment](#) has further information about fouling factors.) To reduce fouling, a minimum water velocity of about 1 m/s is recommended in coolers or condensers. Maximum water velocities exceeding 3.3 m/s are not recommended because of potential erosion problems.

Proper water treatment and regular tube cleaning are recommended for all liquid chillers to reduce power consumption and operating problems. See [Chapter 48 of the ASHRAE Handbook—Applications](#) for water treatment information.

Continuous or daily monitoring of the quality of the condenser water is desirable. Checking the quality of the chilled liquid is also desirable. The intervals between checks become greater as the possibilities for fouling contamination become less—for example, an annual check should be sufficient for closed-loop water-circulating systems for air conditioning. Corrective treatment is required, and periodic, usually annual, cleaning of the condenser tubes usually keeps fouling within the specified allowance. In applications where more frequent cleaning is desirable, an on-line cleaning system may be economical.

Noise and Vibration

The chiller manufacturer's recommendations for mounting should be followed to prevent transmission or amplification of vibration to adjacent equipment or structures. Auxiliary pumps, if not connected with flexible fittings, can induce vibration of the centrifugal unit, especially if the rotational speed of the pump is nearly the same as either the compressor prime mover or the compressor. Flexible tubing becomes less flexible when it is filled with liquid under pressure and some vibration can still be transmitted. General information on noise, measurement, and control may be found in [Chapter 7 of the ASHRAE Handbook—Fundamentals](#), [Chapter 47 of the ASHRAE Handbook—Applications](#), and ARI *Standard* 575.

CONTROL CONSIDERATIONS

In centrifugal systems, the **chilled liquid temperature sensor** is usually placed in thermal contact with the leaving chilled water. In electrical control systems, the electrical signal is transmitted to an electronic control module, which controls the operation of an electric motor(s) positioning the capacity controlling inlet guide vanes. A current limiter is usually included on machines with electric motors. An electrical signal from a current transformer in the compressor motor controller is sent to the electronic control module. The module receives indications of both the leaving chilled water temperature and the compressor motor current. The portion of the electronic control module responsive to motor current is called the current limiter. It overrides the demands of the temperature sensor.

The **inlet guide vanes**, independent of the demands for cooling, do not open more than the position that results in the present setting of the current limiter. Pneumatic capacity controls operate in a similar manner. The chilled liquid temperature sensor provides a pneumatic signal. The controlling module receives both that signal and the motor current electrical signal and controls the operation of a pneumatic motor(s) positioning the inlet guide vanes. Both controlling systems have sensitivity adjustments.

The **current limiter** on most machines can limit current draw during periods of high electrical demand charges. This control can be set from about 40 to 100% of full load current. Whenever power consumption is limited, cooling capacity is correspondingly reduced. If cooling load is only 50% of the full value, the current (or demand) limiter can be set at 50% without loss of cooling. By setting the limiter at 50% of full current draw, any subsequent high demand charges are prevented during pulldown after startup. Even during periods of high cooling load, it may be desirable to limit electrical demand if a small increase in chiller liquid temperature is acceptable. If the temperature continues to decrease after the capacity control has reached its minimum position, a low-temperature control stops the compressor and restarts it when a rise in temperature indicates the need for cooling. Manual controls may also be provided to bypass the temperature control. Provision is included to ensure that the capacity control is at its minimum position when the compressor starts to provide an unloaded starting condition.

Additional operating controls are needed for appropriate operation of lubricant pumps, lubricant heaters, purge units, and refrigerant transfer units. An **antirecycle timer** should also be included to prevent frequent motor starts. Multiple unit applications require additional controls for capacity modulation and proper sequencing of units. (See the Multiple Chiller System section.)

Safety controls protect the unit under abnormal conditions. Safety cutouts that may be required are for high condenser pressure, low evaporator refrigerant temperature or pressure, low lubricant pressure, high lubricant temperature, high motor temperature, and high discharge temperature. Auxiliary safety circuits are usually provided on packaged chillers. At installation, the circuits are field wired to field-installed safety devices, including auxiliary contacts on the pump motor controllers and flow switches in the chilled water and condenser water circuits. Safety controls are usually provided in a lockout circuit, which will trip out the compressor motor controller and prevent automatic restart. The controls reset automatically, but the circuit cannot be completed until a manual reset switch is operated and the safety controls return to their safe positions.

AUXILIARIES AND SPECIAL APPLICATIONS

Auxiliaries

Purge units are required for centrifugal liquid chilling machines using R-123, R-11, R-113, or R-114 because evaporator pressure is below atmospheric pressure. If a purge unit were not used, air and moisture would accumulate in the refrigerant side. Noncondens-

ables collect in the condenser during operation, reducing the heat-transfer coefficient and increasing condenser pressure as a result of both their insulating effect and the partial pressure of the noncondensables. Compressor power consumption increases, capacity is reduced, and surging may occur.

Moisture may build up as free moisture once the refrigerant becomes saturated. Acids produced by a reaction between the free moisture and the refrigerant will then cause internal corrosion. A purge unit prevents the accumulation of noncondensables and ensures internal cleanliness of the chiller. However, a purge unit does not reduce the need to check for leaks and the need to repair them, which is required maintenance for any liquid chiller. Purge units may be manual or automatic, compressor-operated, or compressorless. To reduce the potential for air leaks when chillers are off, the chillers may be heated externally to pressurize them to atmospheric pressure.

ASHRAE *Standard* 15 requires purge units and rupture disks to be vented outdoors. Because of environmental concerns and the increasing cost of refrigerants, high efficiency (air to refrigerant) purges are available that reduce refrigerant losses during normal purging operations.

Lubricant coolers may be water cooled, using condenser water when the quality is satisfactory, or chilled water when a small loss in net cooling capacity is acceptable. These coolers may also be refrigerant or air cooled, eliminating the need for water piping to the cooler.

A **refrigerant transfer unit** may be provided for centrifugal liquid chillers. The unit consists of a small reciprocating compressor with electric motor drive, a condenser (air- or water-cooled), a lubricant reservoir and separator, valves, and interconnecting piping. Refrigerant transfers in three steps:

1. **Gravity Drain.** When the receiver is at the same level as or below the cooler, some liquid refrigerant may be transferred to the receiver by opening valves in the interconnecting piping.
2. **Pressure Transfer.** By resetting valves and operating the compressor, refrigerant gas is pulled from the receiver to pressurize the cooler, forcing refrigerant liquid from the cooler to the storage receiver. If the chilled liquid and condenser water pumps can be operated to establish a temperature difference, the migration of refrigerant from the warmer vessel to the colder vessel can also be used to assist in the transfer of refrigerant.
3. **Pump-Out.** After the liquid refrigerant has been transferred, valve positions are changed and the compressor is operated to pump refrigerant gas from the cooler to the transfer unit condenser, which sends condensed liquid to the storage receiver. If any chilled liquid (water, brine, etc.) remains in the cooler tubes, pump-out must be stopped before cooler pressure drops below the saturation condition corresponding to the freezing point of the chilled liquid.

If the saturation temperature corresponding to cooler pressure is below the chilled liquid freezing point when recharging, refrigerant gas from the storage receiver must be introduced until the cooler pressure is above this condition. The compressor can then be operated to pressurize the receiver and move refrigerant liquid into the cooler without danger of freezing.

Water-cooled transfer unit condensers provide fast refrigerant transfer. Air-cooled condensers eliminate the need for water, but they are slower and more expensive.

Special Applications

Heat Recovery. Instead of rejecting all heat extracted from the chilled liquid to a cooling tower, a separate, closed condenser cooling water circuit is heated by the condensing refrigerant for such purposes as comfort heating, preheating, or reheating. Some factory

packages include an extra condenser water circuit, either in the form of a double-bundle condenser or an auxiliary condenser.

A centrifugal heat-recovery package is controlled as follows:

- **Chilled liquid temperature** is controlled by a sensor in the leaving chilled liquid line signaling the capacity control device.
- **Hot water temperature** is controlled by a sensor in the hot water line that modulates a cooling tower bypass valve. As the heating requirement increases, hot water temperature drops, opening the tower bypass slightly. Less heat is rejected to the tower, condensing temperature increases, and hot water temperature is restored as more heat is rejected to the hot water circuit.

The hot water temperature selected has a bearing on the installed cost of the centrifugal package, as well as on the power consumption while heating. Lower hot water temperatures of 35 to 40°C result in a less expensive machine that uses less power. Higher temperatures require a greater compressor motor output, perhaps higher pressure condenser shells, sometimes extra compression stages, or a cascade arrangement. Installed cost of the centrifugal heat-recovery machine is increased as a result.

Another concern in the design of a central chilled water plant with heat-recovery centrifugal compressors is the relative size of the cooling and heating loads. The heating and cooling loads should be equalized on each machine so that the compressor may operate at optimum efficiency during both the full cooling and full heating seasons. When the heating requirement is considerably smaller than the cooling requirement, multiple packages will lower operating costs and allow standard air-conditioning centrifugal packages of lower cost to be used for the remainder of the cooling requirement. In multiple packages, only one unit is designed for heat recovery and carries the full heating load.

Free Cooling. Cooling without operating the compressor of a centrifugal liquid chiller is called free cooling. When a supply of condenser water is available at a temperature below the needed chilled water temperature, the chiller can operate as a thermal siphon. Low-temperature condenser water condenses refrigerant, which is either drained by gravity or pumped into the evaporator. Higher-temperature chilled water causes the refrigerant to evaporate, and vapor flows back to the condenser because of the pressure difference between the evaporator and the condenser. Free cooling is limited to about 10 to 30% of the chiller design capacity. Free cooling capacity depends on chiller design and the temperature difference between the desired chilled water temperature and the condenser water temperature. Free cooling is also available using either direct or indirect methods as described in [Chapter 36 of the ASHRAE Handbook—Systems and Equipment](#).

Air-Cooled System. Two types of air-cooled centrifugal systems are prevalent. One consists of a water-cooled centrifugal package with a closed-loop condenser water circuit. The condenser water is cooled in a water/air heat exchanger. This arrangement results in higher condensing temperature and increased power consumption. In addition, winter operation requires the use of glycol in the condenser water circuit, which reduces the heat-transfer coefficient of the unit.

The other type of unit is directly air-cooled, which eliminates the intermediate heat exchanger and condenser water pumps, resulting in lower power requirements. However, the condenser and refrigerant piping must be kept leak free.

Because a centrifugal machine will surge if it is subjected to a pressure appreciably higher than design, the air-cooled condenser must be designed to reject the required heat. In common practice, the selection of a reciprocating air-cooled machine is based on an outside dry-bulb temperature that will be exceeded 5% of the time. A centrifugal may be unable to operate during such times because of surging, unless the chilled water temperature is raised proportionately. Thus, the compressor impeller(s) and/or speed should be

selected for the maximum dry-bulb temperature to ensure that the desired chilled water temperature will be maintained at all times. In addition, the condenser coil must be kept clean.

An air-cooled centrifugal chiller should allow the condensing temperature to fall naturally to about 21°C during colder weather. The resulting decrease in compressor power consumption is greater than that for reciprocating systems controlled by thermal expansion valves.

During winter shutdown, precautions must be taken to prevent freezing of the cooler liquid caused by a free cooling effect from the air-cooled condenser. A thermostatically controlled heater in the cooler, in conjunction with a low refrigerant pressure switch to start the chilled liquid pumps, will protect the system.

Other Coolants. Centrifugal liquid chilling units are most frequently used for water chilling applications. But centrifugals are also used with such coolants as calcium chloride, methylene chloride, ethylene glycol, and propylene glycol. (For a complete description of secondary coolants, see [Chapter 20 of the ASHRAE Handbook—Fundamentals](#).) Coolant properties must be considered in calculating heat-transfer performance and pressure drop. Because of the greater temperature rise, higher compressor speeds and possibly more stages may be required for cooling these coolants. Compound and/or cascade systems are required for low-temperature applications.

Vapor Condensing. Many process applications condense vapors such as ammonia, chlorine, or hydrogen fluoride. Centrifugal liquid chilling units are used for these applications.

OPERATION AND MAINTENANCE

Proper operation and maintenance are essential for reliability, longevity, and safety. See [Chapter 38 of the ASHRAE Handbook—Applications](#) for general information on principles, procedures, and programs for effective maintenance. The manufacturer's operation and maintenance instructions should also be consulted for specific procedures. In the United States, Environmental Protection Agency regulations require (1) certification of service technicians, (2) a statement of minimum pressures necessary during evacuation of the system, and (3) definition of when a refrigerant charge must be removed prior to opening a system for service. All service technicians or operators maintaining systems must be familiar with these regulations.

Normal operation conditions should be established and recorded at initial startup. Changes from these conditions can be used to signal the need for maintenance. One of the most important items is to maintain a leak free unit.

Leaks on units operating at subatmospheric pressures allow air and moisture to enter the unit, which increases the condenser pressure. While the purge unit can remove noncondensables sufficiently to prevent an increase in condenser pressure, continuous entry of air and attendant moisture into the system promotes refrigerant and lubricant breakdown and corrosion. Leaks from units that operate above atmospheric pressure may release environmentally harmful refrigerants. Regulations require that annual leakage not exceed a percentage of the refrigerant charge. It is good practice, however, to find and repair all leaks.

Periodic analysis of the lubricant and refrigerant charge can also be used to identify system contamination problems. High condenser pressure or frequent purge unit operation indicate leaks that should be corrected as soon as possible. With positive operating pressures, leaks result in loss of refrigerant and such operating problems as low evaporator pressure. A leak check should also be included in preparation for a long-term shutdown. (See [Chapter 6](#) for a detailed discussion of the harmful effects of air and moisture.)

Normal maintenance should include periodic lubricant and refrigerant filter changes as recommended by the manufacturer. All

safety controls should be checked periodically to ensure that the unit is protected properly.

Cleaning of inside tube surfaces may be required at various intervals, depending on the water condition. Condenser tubes may only need annual cleaning if proper water treatment is maintained. Cooler tubes need less frequent cleaning if the chilled water circuit is a closed loop.

If the refrigerant charge must be removed and the unit opened for service, the unit should be leak-checked, dehydrated, and evacuated properly before recharging. [Chapter 46](#) has information on dehydrating, charging, and testing.

SCREW LIQUID CHILLERS

EQUIPMENT DESCRIPTION

Components and Their Function

Single-screw and twin-screw compressors are both positive-displacement machines with nearly constant flow performance. Compressors for liquid chillers can be both lubricant-injected and lubricant-injection-free. ([Chapter 34 of the *ASHRAE Handbook—Systems and Equipment*](#) describes screw compressors in greater detail.)

The cooler may be flooded or direct-expansion. No particular design has a cost advantage over the other. The flooded cooler is more sensitive to freezing, requires more refrigerant, and requires closer evaporator pressure control, but its performance is easier to predict and it can be cleaned. The direct-expansion cooler requires closer mass flow control, is less likely to freeze, and returns lubricant to the lubricant system rapidly. The decision to use one or the other is based on the relative importance of these factors on a given application.

Screw coolers have the following characteristics: (1) high maximum working pressure, (2) continuous lubricant scavenging, (3) no mist eliminators (flooded coolers), and (4) distributors designed for high turndown ratios (direct-expansion coolers). A suction gas, high-pressure liquid heat exchanger is sometimes incorporated into the system to provide subcooling for increased thermal expansion valve flow and reduced power consumption. (For further information on coolers, see [Chapter 37 of the *ASHRAE Handbook—Systems and Equipment*](#).)

Flooded coolers were once used in units with a capacity larger than about 1400 kW. Direct-expansion coolers are also used in larger units up to 2800 kW with a servo-operated expansion valve having an electronic controller that measures evaporating pressure, leaving secondary coolant temperature, and suction gas superheat.

The condenser may be included as part of the liquid chilling package when water-cooled, or it may be remote. Air-cooled liquid chilling packages are also available. When remote air-cooled or evaporative condensers are applied to liquid chilling packages, a liquid receiver generally replaces the water-cooled condenser on the package structure. Water-cooled condensers are the cleanable shell-and-tube type (see [Chapter 35 of the *ASHRAE Handbook—Systems and Equipment*](#)).

Lubricant cooler loads vary widely, depending on the refrigerant and application, but they are substantial because lubricant injected into the compressor absorbs a portion of the heat of compression. Lubricant is cooled by one of the following methods:

- Water-cooled using condenser water, evaporative condenser sump water, chilled water, or a separate water- or glycol-to-air cooling loop
- Air-cooled using a lubricant-to-air heat exchanger
- Refrigerant-cooled (where lubricant cooling load is low)
- Liquid injection into the compressor
- Condensed refrigerant liquid thermal recirculation (thermosyphon), where appropriate compressor head pressure is available.




Fig. 13 Refrigeration System Schematic

The latter two methods are the most economical both in first cost and overall operating cost because cooler maintenance and special water treatment are eliminated.

Efficient lubricant separators are required. The types and efficiencies of these separators vary according to refrigerant and application. Field built systems require better separation than complete factory-built systems. Ammonia applications are most stringent because no appreciable lubricant returns with the suction gas from the flooded coolers normally used in ammonia applications. However, separators are available for ammonia packages, which do not require the periodic addition of lubricant that is customary on other ammonia systems. The types of separators in use are centrifugal, demister, gravity, coalescer, and combinations of these.

Hermetic compressor units may use a centrifugal separator as an integral part of the hermetic motor while cooling the motor with discharge gas and lubricant simultaneously. A schematic of a typical refrigeration system is shown in [Figure 13](#).

Capacities and Types Available

Screw compressor liquid chillers are available as factory-packaged units from about 100 to 4400 kW. Both open and hermetic styles are manufactured. Packages without water-cooled condensers, with receivers, are made for use with air-cooled or evaporative condensers. Most factory-assembled liquid chilling packages use R-22, though some use R-134a.

Additionally, compressor units, comprised of a compressor, hermetic or open motor, and lubricant separator and system, are available from 70 to 7000 kW. These are used with remote evaporators and condensers for low-, medium-, and high-evaporating-temperature applications. Condensing units, similar to compressor units in range and capacity but with water-cooled condensers, are also built. Similar open motor-drive units are available for ammonia, as are booster units.

Selection of Refrigerant

The refrigerants most commonly used with screw compressors on liquid chiller applications are R-22, R-134a, and R-717. The active use of R-12 and R-500 has been discontinued for new equipment.

PERFORMANCE AND OPERATING CHARACTERISTICS

The screw compressor operating characteristic shown in Figure 7 is compared with reciprocating and centrifugal performance. Additionally, since the screw compressor is a positive-displacement compressor, it does not surge. Because it has no clearance volume in the compression chamber, it pumps high volumetric flows at high pressure. Because of this, screw compressor chillers suffer the least capacity reduction at high condensing temperatures.

The screw compressor provides stable operation over the whole working range because it is a positive-displacement machine. The working range is wide because the discharge temperature is kept low and is not a limiting factor because of lubricant injection into the compression chamber. Consequently, the compressor is able to operate single-stage at high pressure ratios.

An economizer can be installed to improve the capacity and lower the power consumption at full-load operation. An example of such an economizer arrangement is shown in Figure 13, where the main refrigerant liquid flow is subcooled in a heat exchanger connected to the intermediate pressure port in the compressor. The evaporating pressure in this heat exchanger is higher than the suction pressure of the compressor.

Lubricant separators must be sized for the size of compressor, type of system (factory-assembled or field-connected), refrigerant, and type of cooler. Direct-expansion coolers have less stringent separation requirements than do flooded coolers. In a direct-expansion system, the refrigerant evaporates in the tubes, which means that the velocity is kept so high that the lubricant rapidly returns to the compressor. In a flooded evaporator, the refrigerant is outside the tubes, and some type of external lubricant-return device must be used to minimize the concentration of lubricant in the cooler. Suction or discharge check valves are used to minimize backflow and lubricant loss during shutdown.

Because the lubricant system is on the high-pressure side of the unit, precautions must be taken to prevent lubricant dilution. Dilution can also be caused by excessive floodback through the suction or intermediate ports; unless properly monitored, it may go unnoticed until serious operating or mechanical problems occur.

METHOD OF SELECTION

Ratings

Screw liquid-chiller ratings are generally presented similarly to those for centrifugal-chiller ratings. Tabular values include capacity and power consumption at various chilled water and condenser water temperatures. In addition, ratings are given for packages without the condenser that list capacity and power versus chilled water temperature and condensing temperature. Ratings for compressors alone are also common, showing capacity and power consumption versus suction temperature and condensing temperature for a given refrigerant.

Power Consumption

Typical part-load power consumption is shown in Figure 14. Power consumption of screw chillers benefits from reduction of condensing water temperature as the load decreases, as well as operating at the lowest practical pressure at full load. However, because direct-expansion systems require a pressure differential, the power consumption saving is not as great at part load as shown.

Fouling

A fouling allowance of $0.044 \text{ m}^2 \cdot \text{K/kW}$ is incorporated in screw compressor chiller ratings. Excessive fouling (above the design




Fig. 14 Typical Screw Compressor Chiller Part-Load Power Consumption

value) increases power consumption and reduces capacity. Fouling of water-cooled lubricant coolers results in higher than desirable lubricant temperatures.

CONTROL CONSIDERATIONS

Screw chillers provide continuous capacity modulation, from 100% capacity down to 10% or less. The leaving chilled liquid temperature is sensed for capacity control. Safety controls commonly required are (1) lubricant failure switch, (2) high discharge pressure cutout, (3) low suction pressure switch, (4) cooler flow switch, (5) high lubricant and discharge temperature cutout, (6) hermetic motor inherent protection, (7) lubricant pump and compressor motor overloads, and (8) low lubricant temperature (flood back/dilution protection). The compressor is unloaded automatically (slide valve driven to minimum position) before starting. Once it starts operating, the slide valve is controlled hydraulically by a temperature-load controller that energizes the load and unload solenoid valves.

The current limit relay protects against motor overload from higher than normal condensing temperatures or low voltage and also allows a demand limit to be set, if desired. An antirecycle timer is used to prevent overly frequent recycling. Lubricant sump heaters are energized during the off cycle. A hot gas capacity control is optionally available and prevents automatic recycling at no-load conditions such as is often required in process liquid chilling. A suction to discharge starting bypass sometimes aids starting and allows the use of standard starting torque motors.

Some units are equipped with electronic regulators specially developed for the screw compressor characteristics. These regulators include PI control (Proportional-Integrating) of the leaving brine temperature and such functions as automatic/manual control, capacity indication, time circuits to prevent frequent recycling and to bypass the lubricant pressure cutout during startup, switch for unloaded starting, etc. (Typical external connections are shown in Figure 15.)




Fig. 15 Typical External Connections for Screw Compressor Chiller

AUXILIARIES AND SPECIAL APPLICATIONS

Auxiliaries

A **refrigerant transfer unit** is similar to the unit described in the section on Auxiliaries under Centrifugal Liquid Chillers. It is designed for R-22 operating pressure. Its flexibility is increased by including a reversible liquid pump on the unit. It is available as a portable unit or mounted on a storage receiver.

A **lubricant-charging pump** is useful for adding lubricant to the pressurized lubricant sump. Two types are used: a manual pump and an electric motor-driven positive-displacement pump.

Acoustical enclosures are available for installations that require low noise levels.

Special Applications

Because of the screw compressor's positive-displacement characteristic and lubricant-injected cooling, its use for high-differential applications is limited only by power considerations and maximum design working pressures. Therefore, it is being used for many special applications because of its reasonable compressor cost and no-surge characteristic. Some of the fastest growing areas are

- Heat-recovery installations
- Air-cooled
 - Split packages with field-installed interconnecting piping
 - Factory-built rooftop packages
- Low-temperature brine chillers for process cooling
- Ice rink chillers
- Power transmission line lubricant cooling

High-temperature compressor and condensing units are being used increasingly for air conditioning because of the higher efficiency of direct air-to-refrigerant heat exchange resulting in higher evaporating temperatures. Many of these installations have air-cooled condensers.

MAINTENANCE

Manufacturer's maintenance instructions should be followed, especially because some items differ substantially from reciprocating or centrifugal units. Water-cooled condensers must be cleaned of scale periodically (see the General Maintenance section). If condenser water is also used for the lubricant cooler, this should be considered in the treatment program. Lubricant coolers operate at higher temperatures and lower flows than condensers, so it is possible that the lubricant cooler may have to be serviced more often than the condenser.

Because large lubricant flows are a part of the screw compressor system, the lubricant filter pressure drop should be monitored carefully and the elements changed periodically. This is particularly important in the first month or so after startup of any factory-built package and is essential on field-erected systems. Since the lubricant and refrigeration systems merge at the compressor, much of the loose dirt and fine contaminants in the system eventually find their way to the lubricant sump, where they are removed by the lubricant filter. Similarly, the filter-drier cartridges should be monitored for pressure drop and moisture during initial start and regularly thereafter. Generally, if a system reaches an acceptable dryness level, it stays that way unless it is opened.

It is good practice to check the lubricant for acidity periodically, using commercially available acid test kits. The lubricant does not need to be changed unless it is contaminated by water, acid, or metallic particles. Also, a refrigerant sample should be analyzed yearly to determine its condition.

Certain procedures that should be followed on a yearly basis or during a regularly scheduled shutdown. These include checking and calibrating all operation and safety controls, tightening all electrical connections, inspecting power contacts in starters, dielectric checking of hermetic and open motors, and checking the alignment of open motors.

Leak testing of the unit should be performed regularly. A water-cooled package used for summer cooling should be leak tested annually. A flooded unit with proportionately more refrigerant in it, used for year-round cooling, should be tested every four to six months. A process air-cooled chiller designed for year-round operation 24 hours per day should be checked every one to three months.

Based on 6000 operating hours per year and depending on the above considerations, a typical inspection or changeout timetable is as follows:

Shaft seals	1.5 to 4 yr	Inspect
Hydraulic cylinder seals	1.5 to 4 yr	Replace
Thrust bearings	4 to 6 yr	Check preload via shaft end play every 6 months and replace as required
Shaft bearings	7 to 10 yr	Inspect

BIBLIOGRAPHY

- ASHRAE. 1996. Safety code for refrigeration systems. *ASHRAE Standard 15*. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Atlanta.
- ASHRAE. 1996. Methods of testing liquid chilling packages. *ASHRAE Standard 30*. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Atlanta.
- ASME. 2001. *Boiler and pressure vessel code*. American Society of Mechanical Engineers, New York.

ARI. 1998. Centrifugal and rotary screw water-chilling packages. ARI *Standard 550/590-98*. Air-Conditioning and Refrigerating Institute, Arlington, VA.

ARI. 1998. Methods of measuring machinery sound within an equipment space. ARI *Standard 575-94*. Air-Conditioning and Refrigerating Institute, Arlington, VA.