



Standard Specification for Thermoplastic Polyethylene Insulation for Electrical Wire and Cable¹

This standard is issued under the fixed designation D1351; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reappraisal. A superscript epsilon (ε) indicates an editorial change since the last revision or reappraisal.

1. Scope*

1.1 This specification covers a thermoplastic insulation which consists substantially of polyethylene.

1.2 This type of insulation is considered suitable for use on wire or cable that will be used for continuous operation at conductor temperatures up to 75 °C with a maximum conductor size of 1000 kcmil (507 mm²). The maximum voltage rating shall not exceed 35 000 V for power application or 9 000 V for series lighting.

1.3 In many instances the insulation material cannot be tested unless it has been formed around a conductor. Therefore, tests done on insulated wire or cable in this specification are solely to determine the relevant property of the insulation material and not to test the insulated conductor or completed cable.

1.4 Whenever two sets of values are presented, in different units, the values in the first set are the standard, while those in parentheses are for information only.

2. Referenced Documents

2.1 ASTM Standards:²

D1248 Specification for Polyethylene Plastics Extrusion Materials for Wire and Cable

D1711 Terminology Relating to Electrical Insulation

D2308 Specification for Thermoplastic Polyethylene Jacket for Electrical Wire and Cable

D2633 Test Methods for Thermoplastic Insulations and Jackets for Wire and Cable

D3349 Test Method for Absorption Coefficient of Ethylene Polymer Material Pigmented with Carbon Black

¹ This specification is under the jurisdiction of ASTM Committee D09 on Electrical and Electronic Insulating Materials and is the direct responsibility of Subcommittee D09.18 on Solid Insulations, Non-Metallic Shieldings and Coverings for Electrical and Telecommunication Wires and Cables.

Current edition approved March 1, 2014. Published April 2014. Originally approved in 1954. Last previous edition approved in 2008 as D1351-08. DOI: 10.1520/D1351-14.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

2.2 ICEA Standard:

T-24-380 Guide for Partial-Discharge Procedure³

3. Terminology

3.1 Definitions:

3.1.1 Refer to Terminology D1711 for definitions of terms used in this specification.

3.2 Definitions of Terms Specific to This Standard:

3.2.1 *aging (act of)*, *n*—exposure of materials to air at a temperature of 100 °C for 48 h.

4. Conductor Shields

4.1 Conductor shields shall be used on solid and stranded conductors of power cables having rated circuit voltages above 2000 V. This requirement does not apply to series lighting cables. Conductor shielding is conducting material at least 0.0025 in. (0.06 mm) thick applied over the surface of the conductor. The options include conducting nonmetallic tape, conducting compound, or conducting cement.

5. Physical Properties

5.1 The polyethylene, before application to the conductor, shall comply with the requirements of Specification D1248 for Type I; Class A, B or C; Category 4 or 5; Grade E4 or E5. The requirements of Specification D1248 do not apply to insulation removed from the conductor.

5.2 Insulation exposed to sunlight or weather requires Specification D1248, Class C compound or suitable protective coverings. Class C compound shall meet the minimum absorption coefficient requirement in Table 1.

5.3 Specimens removed from the wire or cable and tested at 20 to 30 °C (68 to 86 °F) shall conform to the requirements for physical properties specified in Table 1. Alternatively, the insulation shall be air-oven aged without removal from the conductor.

5.4 *Thickness of Insulation*—The minimum average insulation thickness shall be as specified in Table 2 or Table 3 of this

³ Available from The Insulated Cable Engineers Association, Inc. (ICEA), P.O. Box 1568, Carrollton, GA 30112, <http://www.icea.net>.

*A Summary of Changes section appears at the end of this standard

TABLE 1 Physical Properties of Compound

Unaged Requirements:	
Tensile strength, min, psi (MPa)	1500 (10.4)
Elongation at rupture, min, %	350
Aged Requirements:	
After air oven aging at 100 ± 1 °C for 48 h:	
Tensile strength, % retention, min	75
Elongation at rupture, % retention, min	75
Absorption Coefficient, min, absorbance/nm	320

specification. The minimum thickness shall be at least 90 % of the specified minimum average thickness.

5.5 Absorption Coefficient—Test according to Test Method **D3349**. Alternatively, a certification by the manufacturer of the polyethylene compound that the requirement has been complied with shall suffice.

6. Electrical Requirements

6.1 Order of Testing—Perform the partial discharge, ac voltage, insulation resistance, and dc voltage tests in that order when any of these tests are specified. The sequence of other testing is not specified.

6.2 Partial Discharge—When tested in accordance with ICEA T-24-380, as modified in Test Methods **D2633**, each length of completed shielded power cable rated for service at 2001 V and above shall comply with the minimum partial discharge extinction level. See Test Methods **D2633**.

6.3 AC Voltage Test—The insulated conductor shall withstand the ac voltage specified in **Table 2** or **Table 3** for 5 min. Unless otherwise specified, this test shall be omitted for nonshielded conductors rated up to 5000 V if the dc voltage test described in **6.6** is performed.

6.4 Insulation Resistance—The insulated conductor shall have an insulation-resistance value equal to or greater than that corresponding to a constant of 50 000 MΩ-1000 ft at 60 °F (15.6 °C). When the temperature of the water in which the insulation is tested differs from 60 °F, a correction factor must be applied. **Table 1** of Test Methods **D2633** contains the correction factors. Each insulation or cable manufacturer can furnish the 1 °F coefficient for their insulation material by using the procedure given in Test Methods **D2633**. Multiply the measured value by the correction factor to obtain the insulation resistance value corrected to 60 °F.

6.5 DC Voltage Test (Cables Rated at 5001 V and Above)—Upon completion of the insulation resistance test, each length of insulated power cable rated for service at 5001 V and over shall withstand for 15 min the dc test voltage given in **Table 2** or **Table 3**.

6.6 DC Voltage Test (Cables Rated at 5000 V or Less)—Upon completion of the insulation resistance test, each non-shielded conductor rated up to 5000 V shall withstand for 5 min the dc test voltage given in **Table 2** or **Table 3**. Unless otherwise specified, it is acceptable to omit this test for nonshielded conductors rated up to 5000 V if the ac voltage test described in **6.3** has been performed.

7. Keywords

7.1 cable; conductor; electrical; insulation; polyethylene; thermoplastic; wire

TABLE 2 Conductor Sizes, Insulation Thicknesses, and Test Voltages for Polyethylene-Insulated Power Cables^A

NOTE 1—Column A thicknesses (0 to 2000 V) are applicable to single-conductor power cables for general application when a black pigmented insulation is used without a further covering.

NOTE 2—Column B thicknesses (0 to 2000 V) are applicable to multiple-conductor cables with an outer covering and to single-conductor cables with an outer covering.

NOTE 3—To limit the maximum voltage stress on the insulation at the conductor to a safe value, the minimum size of the conductor shall be in accordance with **Table 2**.

For cables or conditions of service where mechanical stresses govern, such as in submarine cables or long vertical risers, it is possible that these minimum conductor sizes will not be strong enough.

NOTE 4—Polyethylene insulation used on nonshielded cable without an outer covering shall be black pigmented insulation meeting the requirements for both polyethylene insulation and polyethylene jacket.

NOTE 5—Polyethylene insulation used on nonshielded cable without an outer covering for rated circuit voltages of 2001 to 5000 V shall be ozone and discharge resistant when tested in accordance with Specification **D2308**.

NOTE 6—Carbon-black-pigmented polyethylene insulation shall not be used on power cable rated over 5000 V.

Rated Circuit Voltage, Phase to Phase, V ^B	Conductor Size, Awg or kcmil (mm ²)	Insulation Thickness for 100 and 133 Percent Insulation Levels, ^C Grounded and Ungrounded Neutral				a-c Test Voltage, kV, for 100 and 133 Percent Insulation Levels, ^C Grounded and Ungrounded Neutral		d-c Test Voltage, kV, for 100 and 133 Percent Insulation Levels, ^C Grounded and Ungrounded Neutral	
		Column A		Column B		A	B	A	B
		mils	mm	mils	mm				
0 to 600	14 to 9 (2.08 to 6.63)	45	1.14	30	0.76	4.0	3.5	12.0	10.5
	8 to 2 (8.37 to 33.62)	60	1.52	45	1.14	5.5	5.5	16.5	16.5
	1 to 4/0 (42.41 to 107.2)	80	2.03	55	1.40	7.0	7.0	21.0	21.0
	225 to 500 (114 to 253)	95	2.41	65	1.65	8.0	8.0	24.0	24.0
	525 to 1000 (266 to 507)	110	2.79	80	2.03	10.0	10.0	30.0	30.0
601 to 2000	14 to 9 (2.08 to 6.63)	60	1.52	45	1.14	5.5	5.5	16.5	16.5
	8 to 2 (8.37 to 33.62)	70	1.78	55	1.40	7.0	7.0	21.0	21.0
	1 to 4/0 (42.41 to 107.2)	90	2.29	65	1.65	8.0	8.0	24.0	24.0
	225 to 500 (140 to 253)	105	2.67	75	1.90	9.5	9.5	28.5	28.5
	525 to 1000 (266 to 507)	120	3.05	90	2.29	11.5	11.5	34.5	34.5
		100 Percent Insulation Level, ^D Grounded Neutral	133 Percent Insulation Level, Ungrounded Neutral	100 Percent Insulation Level, ^D Grounded Neutral	133 Percent Insulation Level, Ungrounded Neutral	100 Percent Insulation Level, Grounded Neutral	133 Percent Insulation Level, Ungrounded Neutral	100 Percent Insulation Level, Grounded Neutral	133 Percent Insulation Level, Ungrounded Neutral
NONSHIELDED ^E									
2001 to 5000	8 to 4/0 (8.37 to 107.2)	110	2.79	110	2.79	13	13	35	35
	225 to 500 (114 to 253)	120	3.05	120	3.05	13	13	35	35
	525 to 1000 (266 to 507)	130	3.30	130	3.30	13	13	35	35
Rated Circuit Voltage, Phase to Phase, V ^B	Conductor Size, Awg or kcmil (mm ²)	100 Percent Insulation Level, ^D Grounded Neutral	133 Percent Insulation Level, Ungrounded Neutral	100 Percent Insulation Level, ^D Grounded Neutral	133 Percent Insulation Level, Ungrounded Neutral	100 Percent Insulation Level, Grounded Neutral	133 Percent Insulation Level, Ungrounded Neutral	100 Percent Insulation Level, Grounded Neutral	133 Percent Insulation Level, Ungrounded Neutral
		SHIELDED							
2001 to 5000	8 to 1000 (8.37 to 507)	90	2.29	90	2.29	13	13	35	35
5001 to 8000	6 to 1000 (13.30 to 507)	115	2.92	140	3.56	18	22	45	45
8001 to 15000	2 to 1000 (33.62 to 507) ^F	175	4.45	215	5.46	27	33	70	80
15001 to 25000	1 to 1000 (42.41 to 507)	260	6.60	345	8.76	38	49	100	125
25001 to 28000	1 to 1000 (42.41 to 507)	280	7.11			42		105	
28001 to 35000	1/0 to 1000 (53.49 to 507)	345	8.76			49		125	

^A For series lighting cables, see **Table 3**.

^B The actual operating voltage shall not exceed the rated circuit voltage by more than (1) 5 percent during continuous operation or (2) 10 percent during emergencies lasting not more than 15 min.

^C The selection of the cable insulation level to be used in a particular installation shall be made on the basis of the applicable phase to phase voltage and the general system category as outlined below:

100 Percent Level—It is appropriate for cables in this category to be applied where the system is provided with relay protection such that ground faults will be cleared as rapidly as possible, but in any case within 1 min. While these cables are applicable to the great majority of cable installations which are on grounded systems, they are also potentially suitable on other systems for which the application of cables is acceptable provided the above clearing requirements are met in completely de-energizing the faulted section. In common with other electrical equipment, the use of cables is not recommended on systems where the ratio of the zero to positive phase reactance of the system at the point of cable application lies between – 1 and – 40 since excessively high voltages will be encountered in the case of ground faults.

133 Percent Level—This insulation level corresponds to that formerly designated for ungrounded systems. It is appropriate for cables in this category to be applied in situations where the clearing time requirements of the 100 percent level category cannot be met, and yet there is adequate assurance that the faulted section will be de-energized in a time not exceeding 1 h. They are also suitable for use when additional insulation strength over the 100 percent level category is desirable.

^D Where additional insulation thickness is desired, it shall be the same as for the 133 percent insulation level.

^E Where cable is provided with a protective covering, these insulation thicknesses shall be 90 mils (2.29 mm) for all conductor sizes listed.

^F For 133 percent insulation level (ungrounded neutral), the minimum conductor size is 1 Awg (42.41 mm²).

TABLE 3 Conductor Sizes, Insulation Thicknesses and Test Voltages for Polyethylene-Insulated Series Lighting Cables

Circuit Voltage, V ^{A,B}	Conductor Size, Awg (mm ²)	Insulation Thickness ^B		test Voltage, kV	
		mils	mm	ac	dc
0 to 1000	10 to 8 (5.26 to 8.37)	45	1.14	5.5	16.5
	6 to 4 (13.30 to 21.15)	55	1.40	7.0	21.0
1001 to 2000	10 to 8 (5.26 to 8.37)	55	1.40	7.0	21.0
	6 to 4 (13.30 to 21.15)	65	1.65	8.0	24.0
2001 to 3000	10 to 8 (5.26 to 8.37)	75	1.90	10	30
	6 to 4 (13.30 to 21.15)	90	2.29	10	30
3001 to 6000	8 to 4 (8.37 to 21.15)	110	2.79	13	35
	8 to 4 (8.37 to 21.15)	150	3.81	19	55

The following tabulation of series lighting transformer ratings is representative of those in common use:

Rating, kW	6,6-A Secondary		20-A Secondary	
	Full-load Voltage, V, with Protectors	Open-circuit Voltage, V, Without Protectors	Full-load Voltage, V, with Protectors	Open-circuit Voltage, V, Without Protectors
10	1515	2090	500	690
15	2272	3090	750	1020
20	3030	4115	1000	1360
25	3787	5110	1250	1685
30	4545	6130	1500	2020
40	6060	8180	2000	2700

^A A separate jacket is not required. If protectors are employed, the thickness shall be determined by the full-load voltage. If the circuit is to be operated without protectors, the thickness shall be determined by the open-circuit voltage.

^B The highest circuit voltage at each step represents the maximum operating voltage recommended for that thickness of insulation.

SUMMARY OF CHANGES

Committee D09 has identified the location of selected changes to this specification since the last issue, D1351 – 08, that may impact the use of this specification. (Approved March 1, 2014)

(1) Revised Table 1.

(2) Revised temperature in Section 5.3.

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the ASTM website (www.astm.org/COPYRIGHT/).