



Standard Specification for Gas Turbine Fuel Oils¹

This standard is issued under the fixed designation D2880; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the Department of Defense.

1. Scope*

1.1 This specification covers the selection of fuels for gas turbines, excepting gas turbines used in aircraft, for the guidance of interested parties such as turbine manufacturers and the suppliers and purchasers of fuel oils. The specification sets forth the properties of fuels at the time and place of custody transfer to the user.

1.2 Three appendixes are provided for informational purposes only and do not constitute a requirement of this specification unless mutually agreed upon between the interested parties.

1.2.1 **Appendix X1** describes the five grades of gas turbine fuels covered by this specification. Further, it states the significance of various test methods used in inspecting the fuels.

1.2.2 **Appendix X2** discusses the sources of fuel contaminants and notes the significance of such contaminants in the operation of gas turbines and gas turbine fuel systems. The particular significance of trace metals in gas turbine fuels is noted. Upper limits of trace metals are recommended for the various grades of gas turbine fuels, but these recommended limits do not constitute a requirement of the specification unless mutually agreed upon by the interested parties. Limitations due to the use of used or recycled oil are also noted.

NOTE 1—The gas turbine operator should consult Practice **D4418** for methods of ensuring fuels of adequate cleanliness and for guidance on long-term storage of distillate fuels and on liquids from non-petroleum sources as gas turbine.

NOTE 2—Nothing in this specification shall preclude observance of federal, state, or local regulations which may be more restrictive.

NOTE 3—The generation and dissipation of static electricity can create problems in the handling of distillate gas turbine fuel oils. For more information on the subject, see Guide **D4865**.

¹ This specification is under the jurisdiction of ASTM Committee **D02** on Petroleum Products, Liquid Fuels, and Lubricants and is the direct responsibility of Subcommittee **D02.E0** on Burner, Diesel, Non-Aviation Gas Turbine, and Marine Fuels.

Current edition approved Nov. 15, 2013. Published November 2013. Originally approved in 1970. Last previous edition approved in 2013 as D2880 – 13a. DOI: 10.1520/D2880-13B.

2. Referenced Documents

2.1 ASTM Standards:²

- D56** Test Method for Flash Point by Tag Closed Cup Tester
- D86** Test Method for Distillation of Petroleum Products at Atmospheric Pressure
- D93** Test Methods for Flash Point by Pensky-Martens Closed Cup Tester
- D97** Test Method for Pour Point of Petroleum Products
- D129** Test Method for Sulfur in Petroleum Products (General High Pressure Decomposition Device Method)
- D396** Specification for Fuel Oils
- D445** Test Method for Kinematic Viscosity of Transparent and Opaque Liquids (and Calculation of Dynamic Viscosity)
- D482** Test Method for Ash from Petroleum Products
- D524** Test Method for Ramsbottom Carbon Residue of Petroleum Products
- D975** Specification for Diesel Fuel Oils
- D1266** Test Method for Sulfur in Petroleum Products (Lamp Method)
- D1298** Test Method for Density, Relative Density, or API Gravity of Crude Petroleum and Liquid Petroleum Products by Hydrometer Method
- D1552** Test Method for Sulfur in Petroleum Products (High-Temperature Method)
- D1796** Test Method for Water and Sediment in Fuel Oils by the Centrifuge Method (Laboratory Procedure)
- D2622** Test Method for Sulfur in Petroleum Products by Wavelength Dispersive X-ray Fluorescence Spectrometry
- D2709** Test Method for Water and Sediment in Middle Distillate Fuels by Centrifuge
- D3605** Test Method for Trace Metals in Gas Turbine Fuels by Atomic Absorption and Flame Emission Spectroscopy
- D3828** Test Methods for Flash Point by Small Scale Closed Cup Tester
- D4052** Test Method for Density, Relative Density, and API Gravity of Liquids by Digital Density Meter

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

- D4294** Test Method for Sulfur in Petroleum and Petroleum Products by Energy Dispersive X-ray Fluorescence Spectrometry
- D4418** Practice for Receipt, Storage, and Handling of Fuels for Gas Turbines
- D4865** Guide for Generation and Dissipation of Static Electricity in Petroleum Fuel Systems
- D5453** Test Method for Determination of Total Sulfur in Light Hydrocarbons, Spark Ignition Engine Fuel, Diesel Engine Fuel, and Engine Oil by Ultraviolet Fluorescence
- D5949** Test Method for Pour Point of Petroleum Products (Automatic Pressure Pulsing Method)
- D5950** Test Method for Pour Point of Petroleum Products (Automatic Tilt Method)
- D5985** Test Method for Pour Point of Petroleum Products (Rotational Method)
- D6469** Guide for Microbial Contamination in Fuels and Fuel Systems
- D6728** Test Method for Determination of Contaminants in Gas Turbine and Diesel Engine Fuel by Rotating Disc Electrode Atomic Emission Spectrometry
- D7094** Test Method for Flash Point by Modified Continuously Closed Cup (MCCCFP) Tester
- D7220** Test Method for Sulfur in Automotive, Heating, and Jet Fuels by Monochromatic Energy Dispersive X-ray Fluorescence Spectrometry
- 2.2 *Other Documents:*³
- 26 CFR Part 48** Diesel Fuel Excise Tax; Dye Color and Concentration
- 40 CFR Part 80** Regulation of Fuels and Fuel Additives

3. Terminology

3.1 *Definitions of Terms Specific to This Standard:*

3.1.1 *fuel contaminants*—fuel components other than hydrocarbon oils. In the present context the contaminants are foreign materials that make the fuel less suitable or even unsuitable for the intended use.

3.1.1.1 *Discussion*—The contaminants of primary interest are foreign materials introduced subsequent to the manufacture of specification quality fuel. Hence they are materials introduced in the distribution system (that is, storage tanks, pipelines, tank trucks, barges, etc.) or in the user's storage and handling system, or generated within these systems (rust generated in steel pipes and tanks by moist fuel, and so forth). Contaminants may be soluble or insoluble in the fuel.

3.1.2 *fuel entering the combustor(s)*—the fuel that is actually burned in the gas turbine. Fuel may be sampled at a point upstream from the point of entry into the combustor(s), provided the sample is representative of the fuel actually entering the combustor(s).

3.1.3 *hydrocarbon oil, n*—a mixture with elemental composition primarily of carbon and hydrogen, also containing sulfur, oxygen or nitrogen from residual impurities and contaminants associated with the fuel's raw materials and manufacturing processes, and excluding added oxygenated materials.

3.1.3.1 *Discussion*—Examples of excluded oxygenated materials include but are not limited to alcohols, esters, ethers and triglycerides.

NOTE 4—Additives are generally included in finished gas turbine fuel oil to improve performance properties (corrosion and so forth).

4. General Requirements

4.1 The grades of gas turbine fuels herein specified shall be homogeneous mixtures of hydrocarbon oils with the use of additives to enhance performance properties, if required. The hydrocarbon oils shall be free of inorganic acid, and free of excessive amounts of solid or fibrous foreign matter likely to make frequent cleaning of suitable strainers necessary.

4.2 All grades containing residual components shall remain homogeneous in normal storage and not separated by gravity into light and heavy oil components outside the viscosity limits for the grade.

5. Detailed Requirements

5.1 The various grades of gas turbine fuel oil shall conform to the limiting requirements shown in **Table 1**. As noted in the supplementary footnotes to **Table 1**, the requirements for Grade Nos. 1-GT and 2-GT conform in most respects to corresponding Grade Nos. 1 and 2 fuels in Specification **D396**, and to Grade Nos. 1-D and 2-D in Specification **D975**. The viscosity range of Grade Nos. 3-GT and 4-GT fuel brackets the Grade Nos. 4, 5, and 6 of Specification **D396** and Grade No. 4-D of Specification **D975**. It is the intent that fuels meeting Specification **D396** and **D975** requirements may also be supplied under these specifications provided they meet the requirements listed in **Table 1**.

5.2 Modifications of limiting requirements and the inclusion of fuel additives to meet special operating conditions may be agreed upon between the interested parties.

5.3 The properties listed in this specification are those of greatest significance in obtaining acceptable performance of the turbine. However, trace metals, even in fractional parts per million, are detrimental to gas turbine service life. Information on the maximum concentration of critical metallic elements in the fuel as it enters the turbine combustor(s) is provided in **Appendix X2**. Distillate fuels are usually of satisfactory purity as refined, but suppliers rarely have control over possible contamination by trace metals in distribution and storage. The limits in **Appendix X2**, although required as the fuel enters the combustor(s), do not apply to the fuel as delivered unless mutually agreed upon by the interested parties. Fuels may, therefore, require on-site clean-up, quality control procedures, special handling, or other arrangements.

6. Test Methods

6.1 The requirements enumerated in this specification shall be determined in accordance with the following ASTM methods except as noted:

6.1.1 *Flash Point*—Test Methods **D93**, except where other methods are prescribed by law. For all grades, Test Method **D3828** and **D7094** may be used as an alternative with the same

³ Available from Superintendent of Documents, U. S. Government Printing Office, Washington, DC 20402.

TABLE 1 Detailed Requirements for Gas Turbine Fuel Oils at Time and Place of Custody Transfer to User^{A,B,C}

Property	ASTM Test Method ^D	Grade ^E				
		No. 0-GT	No. 1-GT ^F	No. 2-GT ^F	No. 3-GT	No. 4-GT
Flash point °C (°F) min	D93	^G	38 (100)	38 (100)	55 (130)	66 (150)
Water and sediment % vol max	D2709 D1796	0.05 ...	0.05 ...	0.05 ...	... 1.0	... 1.0
Distillation Temperature °C (°F)	D86					
90 % volume recovered min		...	...	282	...	...
max		...	288	338	...	...
Kinematic viscosity 2 mm ² /s ^H	D445					
AT 40°C (104°F) min		^G	1.3	1.9	5.5	5.5
max			2.4	4.1	...	...
AT 100°C (212°F) max			...	...	50.0	50.0
Ramsbottom Carbon residue on	D524	0.15	0.15	0.35	...	...
10 % distillation Residue % mass, max						
Ash % mass, max	D482 D1298	0.01	0.01	0.01	0.03	...
Density at 15°C kg/m ³ max		...	850	876	...	...
Pour point ^H °C (°F) max	D97	...	–18	–6	...	...

^A To meet special operating conditions, modifications of individual limiting requirements may be agreed upon between purchaser, seller, and manufacturer.

^B Gas turbines with waste heat recovery equipment may require fuel sulfur limits to prevent cold end corrosion. Environmental limits may also apply to fuel sulfur in selected areas in the United States and in other countries.

^C See Section 4 and 5 for further statements on gas turbine fuel oil requirements.

^D The test methods indicated are the approved referee methods. Other acceptable methods are indicated in 6.1.

^E No. 0-GT includes naphtha, Jet B fuel and other volatile hydrocarbon liquids. No. 1-GT corresponds in general to specification **D396** Grade No. 1 fuel and **D975** Grade 1-D diesel fuel in physical properties. No. 2-GT corresponds in general to Specification **D396** No. 2 fuel and **D975** Grade 2-D diesel fuel in physical properties. No. 3-GT and No. 4-GT viscosity range brackets specification **D396** Grades No. 4, No. 5 (light), No. 5 (heavy), and No. 6, and **D975** Grade No. 4-D diesel fuel in physical properties.

^F Under United States regulations, Grades No. 1-GT and No. 2-GT are required by 40 CFR Part 80 to contain a sufficient amount of dye Solvent Red 164 so its presence is visually apparent. At or beyond terminal storage tanks, they are required by 26 CFR Part 48 to contain the dye Solvent Red 164 at a concentration spectrally equivalent to 3.9 lb per thousand barrels of the solid dye standard Solvent Red 26.

^G When the flash point is below 38°C (100°F) or when kinematic viscosity is below 1.3 mm²/s at 40°C (104°F) or when both conditions exist, the turbine manufacturer should be consulted with respect to safe handling and fuel system design.

^H For cold weather operation, the pour point should be specified 6°C below the ambient temperature at which the turbine is to be operated except where fuel heating facilities are provided. When a pour point less than –18°C is specified for Grade No. 2-GT, the minimum viscosity shall be 1.7 mm²/s and the minimum 90 % recovered temperature shall be waived.

limits. For Grades No. 1-GT and No. 2-GT, Test Method **D56**⁴ may be used as an alternative with the same limits provided the flash point is below 93°C and the viscosity is below 5.5 mm²/s at 40°C. This test method will give slightly lower values. In case of dispute, Test Method **D93** shall be used as the referee method.

6.1.2 *Pour Point*—Test Method **D97**. For all grades, the automatic Test Methods **D5949**, **D5950**, or **D5985** can be used as alternates with the same limits. In case of dispute, Test Method **D97** shall be used as the referee method.

6.1.3 *Water and Sediment*—Test Method **D2709** is used for Grades 0-GT, 1-GT, and 2-GT. Test Method **D1796** is used for Grades 3-GT and 4-GT.

6.1.4 *Carbon Residue*—Test Method **D524**.

6.1.5 *Ash*—Test Method **D482**.

6.1.6 *Distillation*—Test Method **D86**.

6.1.7 *Viscosity*—Test Method **D445**.

6.1.8 *Density*—Test Method **D1298** or **D4052**.

6.1.9 *Sulfur*—Test Method **D129**, Test Methods **D1552**,⁵ **D2622**, and **D4294** can also be used for all grades. In addition, Test Method **D1266** can be used for Grades No. 0 and No. 1, but only with samples having sulfur contents of 0.4 mass percent and less (down to 0.01 %). Test Method **D5453** can be used for Grades 0, 1, and 2 GT oils, but only with samples having sulfur contents of 0.8 mass % and less (down to 0.001 %). Test Method **D7220** may be used for Grades 0, 1, and 2 GT oils, but only with samples having sulfur contents of 0.942 mass % and less (down to 0.0003 %). Test Method **D129** is the referee sulfur test method for Specification D2880.

7. Keywords

7.1 fuel oils; gas turbine; petroleum and petroleum products

⁵ For information on the precision of the ASTM methods of test for fuel oils refer to “An Evaluation of Methods for Determination of Sulfur in Fuel Oils” by A. R. Crawford and G. V. Dyroff (1969). This document is available from the Publications Section, American Petroleum Institute, 1220 L St., N.W., Washington, DC 20005.

⁴ Other mutually acceptable methods may be used.

APPENDIXES

(Nonmandatory Information)

X1. SIGNIFICANCE OF ASTM SPECIFICATIONS FOR GAS TURBINE FUEL OILS

X1.1 Scope

X1.1.1 This specification divides the fuel oils encompassed by Specifications **D396** and **D975** into four grades, based upon their applicability for use in gas turbines. Also there is a No. 0-GT grade to cover low-flash naphthas. The specification does not include fuels primarily intended for aircraft use. It places limiting values on a number of the properties of the fuels in each grade. The properties selected for limitation are those that are believed to be of the greatest significance in determining performance characteristics of the oils in the various gas turbine applications.

X1.1.2 The physical properties of commercial fuel oils that are important in gas turbine operation are generally the same as those specified by Specifications **D396** and **D975**. In addition, gas turbine operating experience has shown that certain chemical properties of the fuel oil ash must be controlled since slag-forming substances present in the oil ash can cause corrosion and deposits on those turbine parts that must operate at surface temperatures of 593°C and above. This specification includes the applicable physical properties from Specifications **D396** and **D975**. **Appendix X2** lists restrictions required to control high temperature corrosion and deposits.

X1.2 Grades

X1.2.1 Grade 0-GT includes naphtha, Jet B, and other light hydrocarbon liquids that characteristically have low flash point and low viscosity as compared with kerosine and fuel oils.

X1.2.2 Grade 1-GT is a light distillate fuel oil suitable for use in nearly all gas turbines.

X1.2.3 Grade 2-GT, which is a heavier distillate than Grade 1-GT, can be used by gas turbines not requiring the clean burning characteristics of Grade 1-GT. Fuel heating equipment may be required by the gas turbine depending on the fuel system design or ambient temperature conditions, or both.

X1.2.4 Grade 3-GT may be a heavier distillate than Grade 2-GT, a residual fuel oil that meets the low ash requirements, or a blend of distillate with a residual fuel oil. Fuel heating will be required by the gas turbine in almost every installation.

X1.2.5 Grade 4-GT includes most residuals and some topped crudes. Because of the wide variation and lack of control of properties, the gas turbine manufacturer should be consulted with regard to acceptable limits on properties.

NOTE X1.1—Fuels prepared to different specifications and sold under different names may meet the requirements of fuels specified under Specification D2880. However, specification tests would normally have to be run to ensure compliance with the requirements of Specification D2880 as other fuels are not necessarily interchangeable with D2880 fuels throughout the range permitted by the other specifications.

X1.3 Selection of Particular Grade

X1.3.1 The selection of a particular gas turbine fuel oil from one of these five ASTM grades for use in a given gas turbine requires consideration of the following factors:

X1.3.1.1 Availability of the fuel,

X1.3.1.2 Design of the gas turbine and fuel handling system,

X1.3.1.3 Maintenance of the gas turbine, and

X1.3.1.4 Operating requirements for the gas turbine.

X1.4 Significance of Test Methods

X1.4.1 The significance of the properties of fuel oil on which limitations are placed by the specifications is as follows:

X1.4.1.1 Flash point is an indication of the maximum temperature at which a fuel oil can be stored and handled without serious fire hazard. The minimum permissible flash point is usually regulated by federal, state, or municipal laws and is based on accepted practice in handling and use.

X1.4.1.2 Pour point is an indication of the lowest temperature at which a fuel oil can be stored and still be capable of flowing under gravitational forces. The pour point is prescribed in accordance with the conditions of storage and use. Fuels with higher pour point are permissible where heated storage and adequate piping facilities are provided.

X1.4.1.3 *Water and Sediments*—Appreciable amounts of water and sediment in a fuel oil tend to cause fouling of the fuel-handling facilities and to give trouble in the fuel system of the gas turbine. An accumulation of sediment in storage tanks and on filter screens may obstruct the flow of oil from the tank to the combustor of the gas turbine. Water in distillate fuels may cause corrosion of tanks and equipment, and water in residual fuel may cause emulsions.

X1.4.1.4 Carbon residue is a measure of the carbonaceous material left in a fuel after all the volatile components are vaporized in the absence of air. It is a rough approximation of the tendency of a fuel to form carbon deposits in the combustor of the gas turbine. Combustion systems designed for use on Grades 3-GT and 4-GT are insensitive to this property, but other gas turbines may require a limit on the carbon residue. To obtain measurable values of carbon residue in the lighter distillate fuel oils, it is necessary to remove 90 % of the oil by distillation in accordance with Test Method **D86**, and then determine the carbon residue concentrated in the remaining 10 % bottoms.

X1.4.1.5 Ash is the noncombustible material in an oil. Ash-forming materials may be present in fuel oil in two forms: (1) solid particles and (2) oil- or water-soluble metallic compounds. The solid particles are for the most part the same material that is designated as sediment in the water and sediment test. Depending on their size, these particles can contribute to wear in the fuel system and to plugging of the fuel

filter and the fuel nozzle. The soluble metallic compounds have little or no effect on wear or plugging, but they can contain elements that produce turbine corrosion and deposits as described subsequently.

X1.4.1.6 Distillation—The distillation test shows the volatility of a fuel and the ease with which it can be vaporized. Distillation temperature is not directly significant to operation of gas turbines designed for Grades 3-GT and 4-GT. In other gas turbines that are most susceptible to carbon deposition and smoke formation, the more volatile fuels may provide better performance.

X1.4.1.7 Viscosity of a fluid is a measure of its resistance to flow. In fuel oil it is highly significant since it indicates both the relative ease with which the oil will flow or may be pumped, and the ease of atomization by the fuel nozzles. Minimum viscosity is limited because some fuel pumps will not perform satisfactorily if the viscosity reaches too low a value. Maximum viscosity is limited since too high a viscosity can cause excessive pressure losses in the piping system, and poor fuel atomization.

X1.4.1.8 Density alone is of little significance as an indication of the burning characteristics of fuel oil. However, when used in conjunction with other properties, it is of value in weight-volume relationships and in calculating the specific energy heating value of an oil.

X1.4.1.9 Sulfur normally burning to sulfur dioxide, also can be oxidized partially to sulfur trioxide which then can combine with sodium and potassium compounds from the ash in the fuel to form sulfates, pyrosulfates, and such compounds as sodium or potassium iron trisulfate. The pyrosulfates, and the trisulfates have melting points in the operating range of the gas turbine. Hence, the compounds produce severe corrosion of the turbine blading. In general, it has been found impractical to prevent corrosion by limiting the sulfur content of the fuel, so corrosion of this type is controlled by limiting the sodium and potassium. Gas turbines with waste heat recovery equipment may require additional sulfur control to prevent cold-end corrosion.

X2. SIGNIFICANCE OF FUEL CONTAMINANTS AND TRACE METALS IN FUEL SYSTEMS AND IN FUEL ENTERING TURBINE COMBUSTOR(S)

X2.1 Scope

X2.1.1 This appendix discusses the sources of fuel contaminants and notes the significance of such contaminants in the operation of gas turbines and gas turbine fuel systems.

X2.1.2 The particular significance of trace metals in gas turbine fuels is noted and upper limits of trace metals are recommended for the various grades of gas turbine fuels.

X2.2 Sources of Contaminants

X2.2.1 Water may be present in the fuel as dissolved water or as free (undissolved) water, or both. The free water may be fresh or saline. Fresh water may enter the fuel from steam coils in storage tanks, from condensation out of moisture-laden air, or from leaking cooling coils. Saline water can enter the fuel during transportation in barges or tankers.

X2.2.2 Microbial slimes may result when conditions are conducive to the growth of microorganisms, which are always present. The presence of free water is essential to the growth of many of these microorganisms, which grow in tank water bottoms and feed on nutrients in the water or on the hydrocarbons.

X2.2.3 A significant source of particulate solids in gas turbine fuel systems can be the degradation of the fuel to form fuel insoluble compounds. The chemical reactions that cause this degradation vary with the chemical composition of the fuel but can include oxidation, polymerization, and acid-base reactions. The use of appropriate fuel additives can often provide some control of these reactions. Particulate solids can enter a fuel from the air (suspended dirt and aerosols) or from the distribution and storage systems (rust, corrosion products, gasket debris, and so forth).

X2.2.4 Metals may be present as metallic compounds in the fuel as a natural result of the composition of the crude oil and of the refining process. However, unless special precautions are taken, additional metallic compounds can be acquired during distribution and storage. A commercial product pipeline may contain residues of lead-containing gasoline which would then be dissolved by the gas turbine fuel. Tank trucks, railroad tankcars, barges, and tankers may be inadequately cleaned and contain residues of past cargos. Acidic components in saline water salts in the fuel may react with distribution and storage equipment.

X2.3 Significance of Contaminants

X2.3.1 Contamination levels in the fuel entering the combustor(s) must be low for improved turbine life. Low contamination levels in the fuel in the turbine's in-plant fuel system is required to minimize corrosion and operating problems. To provide fuel of adequate cleanliness to the gas turbine combustor(s) may require special actions by the user. These actions might include special transportation arrangements with the fuel supplier, particular care in on-site fuel storage and quality control procedures, and establishment of on-site clean-up procedures. Each of the four classes of contaminants defined in **X2.2.2** has its own significance to system operation.

X2.3.2 Water will cause corrosion of tanks, piping, flow dividers, and pumps. Corrosion or corrosion products in close tolerance devices such as flow dividers may cause plugging and may stop flow to the turbines. Free water is potentially corrosive; in sulfur-containing fuels, it may be particularly corrosive. Free water may contain dissolved salts that may be corrosive, and may encourage microbiological growth.

X2.3.3 Microbial slimes caused by microorganisms can plug filters and other close-tolerance openings. Some organisms can cause corrosion as well as produce slimes. Under anaerobic conditions, hydrogen sulfide, which may cause corrosion, can be generated by biological action. Biocides are available for controlling the growth of microorganisms, but their effect on trace metal levels and other fuel properties should be considered. Since water is required for the growth of the microorganisms, one way of controlling their growth is to eliminate the presence of water through tank-stripping operations or other separation techniques. Refer to Guide **D6469** for a more complete discussion.

X2.3.4 Particulate solids may shorten the life of fuel system components. Life of fuel pumps and of various close-tolerance devices is a function of particulate levels and size distributions in the fuel. High levels of particulates can lead to short cycle times in the operation of filters, filter/separators, centrifuges, and electrostatic purifiers. Since such separation devices do not remove all the particulates, certain quantities will be present in the down-stream fuel.

X2.3.5 Trace metals refer both to those metals present as metallic compounds in solution and to metals present in particulates like rust. They are dissolved or suspended either in the fuel hydrocarbons or in free water present in the fuel. The significance of several individual trace metals with respect to hot corrosion is discussed in **Appendix X1**. Although lower levels of trace metals in a fuel will promote longer turbine service from a corrosion standpoint, the specification of excessively low levels may limit the availability of the fuel or materially increase its cost. **Table X2.1** suggests levels of trace metals that would probably yield satisfactory service.

X2.3.6 Sodium and potassium can combine with vanadium to form eutectics which melt at temperatures as low as 566°C and can combine with sulfur in the fuel to yield sulfates with melting points in the operating range of the gas turbine. These compounds produce severe corrosion, and for turbines operating at gas inlet temperatures above 650°C additives are not yet in general use which control such corrosion. Accordingly, the sodium-plus-potassium level must be limited, but each element is measured separately. Some gas turbine installations incor-

porate systems for washing oil with water to reduce the sodium-plus-potassium level. In installations where the fuel is moved by sea transport, the sodium-plus-potassium level should be checked prior to use to ensure that the oil has not become contaminated with sea salt. For gas turbines operating at turbine inlet gas temperatures below 650°C (1200°F), the corrosion due to sodium compounds is of minor importance and can be further reduced by silicon-base additives. A high-sodium content is even beneficial in these turbines because it increases the water-solubility of the deposits and thereby increases the ease with which gas turbines can be water-washed to obtain recovery of the operating performance.

X2.3.7 Calcium is not harmful from a corrosion standpoint; in fact, it serves to inhibit the corrosive action of vanadium. However, calcium can lead to hardbonded deposits that are not self-spalling when the gas turbine is shut down, and that are not readily removed by water washing of the turbine. The fuel washing systems used at some gas turbine installations to reduce the sodium and potassium level will also significantly lower the calcium content of fuel oil.

X2.3.8 Vanadium can form low melting compounds such as vanadium pentoxide that melts at 691°C, and causes severe corrosive attack on all of the high temperature alloys used for gas turbine blades. If there is sufficient magnesium in the fuel, it will combine with the vanadium to form compounds with higher melting points and thus reduce the corrosion rate to an acceptable level. The resulting ash will form deposits in the turbine and will require appropriate cleaning procedures.

X2.3.8.1 When vanadium is present in more than trace amounts either in excess of 0.5 mg/kg or a level recommended by the turbine manufacturer, it is necessary to maintain a weight ratio of magnesium to vanadium in the fuel of not less than 3.0 in order to control corrosion.

X2.3.8.2 An upper limit of 3.5 is suggested since larger ratios will lead to unnecessarily high rates of ash deposition. In most cases, the required magnesium-to-vanadium ratio will be obtained by additions of magnesium-containing compounds to the fuel oil. The special requirements covering the addition of and type of magnesium-containing additive, or equivalent, shall be specified by mutual agreement between the various interested parties. The additive will vary depending on the application, but it is always essential that there is a fine and uniform dispersion of the additive in the fuel at the point of combustion.

X2.3.8.3 For gas turbines operating at turbine inlet gas temperatures below 650°C, the corrosion of the high-temperature alloys is of minor importance, and the use of a silicon-base additive will further reduce the corrosion rate by absorption and dilution of the vanadium compounds.

X2.3.9 Lead can cause corrosion and in addition it can spoil the beneficial inhibiting effect of magnesium additives on vanadium corrosion. Since lead is only rarely found in significant quantities in crude oils, its appearance in the fuel oil is primarily the result of contamination during processing or transportation.

TABLE X2.1 Trace Metal Limits of Fuel Entering Turbine Combustor(s)^{A,B}

Designation	Trace Metal Limits, mg/kg			
	Vanadium (V)	Sodium plus Potassium (Na + K)	Calcium (Ca)	Lead (Pb)
No. 0-GT	0.5	0.5	0.5	0.5
No. 1-GT	0.5	0.5	0.5	0.5
No. 2-GT	0.5	0.5	0.5	0.5
No. 3-GT	0.5	0.5	0.5	0.5
No. 4-GT	(Consult turbine manufacturers)			

^A Test Method **D3605** may be used for determination of vanadium, sodium, calcium, and lead.

^B Test Method **D6728** may be used for determination of vanadium, sodium, potassium, calcium, and lead.

SUMMARY OF CHANGES

Subcommittee D02.E0 has identified the location of selected changes to this standard since the last issue (D2880 – 13a) that may impact the use of this standard. (Approved Nov. 15, 2013.)

(1) An alternative test method (D7094) for the determination of flash point was added to Sections 2 and 6.1.1.

Subcommittee D02.E0 has identified the location of selected changes to this standard since the last issue (D2880 – 13) that may impact the use of this standard. (Approved Aug. 1, 2013.)

(1) Added definition of hydrocarbon oil in Terms Specific to This Standard section.	(2) Revised 4.1 on General Requirements for gas turbine fuel oils.
---	--

Subcommittee D02.E0 has identified the location of selected changes to this standard since the last issue (D2880 – 03 (2010)) that may impact the use of this standard. (Approved May 1, 2013.)

(1) An alternative test method (D7220) for the determination of sulfur was added to Sections 2 and 6.1.9.

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the ASTM website (www.astm.org/COPYRIGHT/).