



Standard Classification for Rating Outdoor-Indoor Sound Attenuation¹

This standard is issued under the fixed designation E1332; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

INTRODUCTION

This classification is part of a set of ratings for the sound isolating properties of materials, building elements, and structures. It is based on A-weighted reduction of a transportation noise source. Other ratings include Classification [E413](#) that rates the ability of a partition to reduce speech and other sounds within a limited frequency range, and Classification [E989](#) that provides a rating method for comparing the impact-insulation properties of floor-ceiling assemblies.

1. Scope

1.1 The purpose of this classification is to provide a method to calculate single-number ratings that can be used for assessing the isolation for the outdoor sound provided by a building or comparing building facade specimens including walls, doors, windows, and combinations thereof, including complete structures. These ratings are designed to correlate with subjective impressions of the ability of building elements to reduce the penetration of outdoor ground and air transportation noise.² These ratings provide an evaluation and rank ordering of the performance of test specimens based on their effectiveness at controlling the sound of a specific outdoor sound spectrum called the reference source spectrum.

1.2 In addition to the calculation method, this classification defines some ratings not defined in other standards. Other standards may define additional ratings based on the method of this classification.

1.3 The rating does not necessarily relate to the perceived aesthetic quality of the transmitted sound. Different facade elements with similar ratings may differ significantly in the proportion of low and high frequency sound that they transmit. It is best to use specific sound transmission loss values, in conjunction with actual spectra of outdoor and indoor sound levels, for making final selections of facade elements.

1.4 Excluded from the scope of this classification are applications involving noise spectra differing markedly from those described in [4.1](#). Thus excluded, for example, would be certain industrial noises with high levels at frequencies below

the 80 Hz one-third octave band, relative to levels at higher frequencies. However, for any source with a spectrum similar to those in [4.1](#), this classification provides a more reliable ranking of the performance of partitions and facade elements than do other classifications such as Classification [E413](#).

1.5 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.6 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 ASTM Standards:³

[C634](#) Terminology Relating to Building and Environmental Acoustics

[E90](#) Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements

[E413](#) Classification for Rating Sound Insulation

[E966](#) Guide for Field Measurements of Airborne Sound Insulation of Building Facades and Facade Elements

[E989](#) Classification for Determination of Impact Insulation Class (IIC)

2.2 ANSI Standard:

[S1.4](#) American National Standard Specification for Sound Level Meters⁴

2.3 ISO Standard:

¹ This classification is under the jurisdiction of ASTM Committee [E33](#) on Building and Environmental Acoustics and is the direct responsibility of Subcommittee [E33.03](#) on Sound Transmission.

Current edition approved May 1, 2010. Published June 2010. Originally approved in 1990. Last previous edition approved in 2010 as E1332–10. DOI: 10.1520/E1332-10A.

² This classification may be used in conjunction with Test Method [E90](#) or Guide [E966](#).

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

⁴ Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, <http://www.ansi.org>.

3. Terminology

3.1 The following terms used in this classification have specific meanings that are defined in Terminology **C634**: *airborne sound, decibel, impact insulation class, level reduction, octave band, outdoor-indoor transmission loss, sound insulation, sound isolation, sound level, sound transmission loss.*

3.2 Definitions of Terms Specific to This Standard:

3.2.1 *apparent outdoor-indoor transmission class, AO-ITC*(θ), n —of a building façade or façade element at a specified angle θ or range of angles - a single-number rating calculated in accordance with Classification E1332 using measured values of apparent outdoor-indoor transmission loss.

3.2.2 *apparent outdoor-indoor transmission loss, AOITL*(θ), n —of a building façade or façade element, in a specified frequency band at a specified angle θ or range of angles - the value of outdoor-indoor transmission loss obtained on a test façade element as installed, without flanking tests to identify or eliminate extraneous transmission paths; the AOITL is the lower limiting value of the outdoor-indoor transmission loss of the façade element.

3.2.3 *outdoor-indoor level reduction, OILR*(θ), n —of a building façade, façade element, or combination of façade surfaces enclosing a room, in a specified frequency band at a specified angle θ or range of angles—the difference between the time-averaged exterior sound pressure level which would be present at the façade of the room were the building and its façade not present due to a sound source at a specified angle of incidence θ or range of angles and the space-time average sound pressure level in a room of a building.

3.2.4 *outdoor-indoor noise isolation class, OINIC*(θ), n —of a building façade, façade element, or combination of façade surfaces enclosing a room, at a specified angle θ or range of angles—a single-number rating calculated in accordance with Classification E1332 using measured values of outdoor-indoor level reduction.

3.2.5 *outdoor-indoor transmission class, OITC, of a building façade or façade element, n*—a single-number rating calculated in accordance with Classification E1332 using measured values of sound transmission loss.

4. Significance and Use

4.1 This classification provides a single number rating for transmission loss or noise reduction data that have been measured or calculated. This rating is based on the difference between the overall A-weighted sound level of the sound spectrum given in **Table 1** and the overall A-weighted sound level of the spectrum that results from arithmetically subtracting the transmission loss or noise reduction data from this spectrum. The spectrum shape is an average of three typical spectra from transportation sources (aircraft takeoff, freeway, and railroad passby). A study showed that this classification correlated well with the A-weighted and loudness reductions (see **ISO 532**) calculated for each of the typical spectra for the one-third octave band range of 50 to 5000 Hz. The calculated numeric value of the rating is based on the sound transmission

TABLE 1 Reference Source Spectrum

One-third Octave Band Center Frequency, Hz	Sound Level, dB
80	103
100	102
125	101
160	98
200	97
250	95
315	94
400	93
500	93
630	91
800	90
1000	89
1250	89
1600	88
2000	88
2500	87
3150	85
4000	84

loss or noise reduction values for a particular specimen and depends only on that data and the shape of the reference source spectrum used in the calculation. The values shown in **Table 1** have an arbitrary reference level. Single-number ratings should always be used with caution. Specimens having the same rating can result in different indoor spectra depending on the variation of their transmission loss with frequency. Also, if the actual spectrum of the outdoor sound is different from that assumed in **Table 1**, the overall A-weighted outdoor-indoor noise reduction may be different from the OINIC.

4.2 This classification requires sound transmission loss (TL), apparent outdoor-indoor transmission loss (AOITL(θ)), or outdoor-indoor noise reduction measurements (OILR(θ)) in one-third octave bands from 80 to 4000 Hz. Due to accuracy limitations given in Test Method **E90** and Guide **E966**, measurements below the 100 Hz one-third octave band are not usually reported. Studies have shown that data in the 80 Hz one-third octave band are necessary to obtain acceptable correlations for transportation sound sources. For the purposes of this classification, measurements of sound transmission loss in the 80 Hz one-third octave band from qualified laboratories are deemed to be of acceptable accuracy.

4.3 Users of this classification should recognize that low frequency measurements of sound transmission loss may be affected by the test specimen size or the specimen edge restraints, or both, particularly for small modular specimens such as doors or windows. Consequently, the outdoor-indoor transmission class (OITC) may also be affected by these factors, resulting in some uncertainty of the field performance of assemblies bearing a rating number using this classification, but to what extent is unknown.

5. Basis of Classification

5.1 The rating of a test specimen is calculated using third-octave data such as transmission loss or outdoor-indoor noise reduction in the range 80 to 4000 Hz. This would usually be measured in accordance with Test Method **E90** or Guide **E966**, but might be estimated analytically. These data are then used to determine the A-weighted sound level reduction of the

TABLE 2 Worksheet for Calculating Outdoor-Indoor Ratings

Column 1	Column 2	Column 3	Column 4	Column 6
Band Center Frequency, Hz	Reference Sound Spectrum, dB (L_f)	A-weighting Correction, dB (A_f)	Column 2 + Column 3	Column 4 – Column 5
80	103	–22.5	80.5	
100	102	–19.1	82.9	
125	101	–16.1	84.9	
160	98	–13.4	84.6	
200	97	–10.9	86.1	
250	95	–8.6	86.4	
315	94	–6.6	87.4	
400	93	–4.8	88.2	
500	93	–3.2	89.8	
630	91	–1.9	89.1	
800	90	–0.8	89.2	
1000	89	0	89.0	
1250	89	0.6	89.6	
1600	88	1.0	89.0	
2000	88	1.2	89.2	
2500	87	1.3	88.3	
3150	85	1.2	86.2	
4000	84	1.0	85.0	

$$\text{Total Column 4 (dBA)} = 10 \log \sum_f 10^{(\text{Column 4}/10)}$$

$$= 100.13 \text{ dB}$$

$$\text{Total Column 6 (dBA)} = 10 \log \sum_f 10^{(\text{Column 6}/10)}$$

$$\text{Rating} = 100.13 - (\text{total Column 6})$$

where:

f = each one-third-octave frequency band.

TABLE 3 Example Worksheet Calculating OITC Specifically

Column 1	Column 2	Column 3	Column 4	Column 5	Column 6
Band Center Frequency, Hz	Reference Sound Spectrum, dB	A-weighting Correction, dB	Column 2 + Column 3	Specimen TL, dB	Column 4 – Column 5
80	103	–22.5	80.5	26	54.5
100	102	–19.1	82.9	26	56.9
125	101	–16.1	84.9	29	55.9
160	98	–13.4	84.6	29	55.6
200	97	–10.9	86.1	31	55.1
250	95	–8.6	86.4	32	54.4
315	94	–6.6	87.4	32	55.4
400	93	–4.8	88.2	30	58.2
500	93	–3.2	89.8	32	57.8
630	91	–1.9	89.1	36	53.1
800	90	–0.8	89.2	40	49.2
1000	89	0	89.0	44	45.0
1250	89	0.6	89.6	46	43.6
1600	88	1.0	89.0	48	41.0
2000	88	1.2	89.2	49	40.2
2500	87	1.3	88.3	47	41.3
3150	85	1.2	86.2	46	40.2
4000	84	1.0	85.0	50	35.0

$$\text{Total Column 4 (dBA)} = 10 \log \sum_f 10^{(\text{Column 4}/10)}$$

$$= 100.13 \text{ dB}$$

$$\text{Total Column 6 (dBA)} = 10 \log \sum_f 10^{(\text{Column 6}/10)}$$

$$\text{OITC} = 100.13 - (\text{total Column 6})$$

$$= 100.13 - 66.15$$

$$= 34$$

specimen for the reference source spectrum specified in [Table 1](#). The rating is then equal to the calculated A-weighted sound reduction, rounded to the nearest decibel.

5.2 The rating is calculated from the following and rounded to the an integer value:

$$\text{Rating} = 100.13 - 10 * \log \sum_f 10^{((L_f - D_f + A_f)/10)} \quad (1)$$

where:

L_f = reference source spectrum,

A_f = A-weighting adjustment, and

D_f = Data at each one-third-octave frequency band, such as sound transmission loss or outdoor-indoor noise reduction.

5.3 [Table 2](#) shows a general worksheet for use in calculating the rating, and [Table 3](#) shows an example worksheet for calculating OITC. The figures in Column 3 for the A-weighting adjustments are taken from [ANSI S1.4](#). Other ratings may be computed using the same worksheet substituting the appropriate data for the rating instead of the sound transmission loss.

6. Presentation of Results

6.1 It is recommended that ratings calculated in accordance with this classification always be presented together with a graph of the data used for the calculation.

7. Precision

7.1 A study⁵ of forty two sound attenuating gypsum board wall assemblies compared the calculated A-weighted sound reduction of each assembly, for three sound spectra representing railroad, freeway, and aircraft noise sources over the one-third-octave band center frequency range of 50 to 4000 Hz, to the calculated OITC. The study gave the following statistical data:

Source	Slope, dB	Intercept, dB	Correlation	Standard Deviation, dB
Railroad	0.977	–2.4	0.990	1.2
Freeway	1.088	–2.5	0.981	1.6
Aircraft	1.099	2.8	0.961	2.4

8. Keywords

8.1 A-weighting; aircraft; buildings; classification; facade; freeway; indoor; insulation; isolation; loudness; noise; outdoor-indoor noise isolation (OINIC(θ)); outdoor-indoor transmission class (OITC); outdoor; railroad; sound; traffic; transmission; transportation

⁵ Walker, K. W., “Single Number Ratings for Sound Transmission Loss,” *Sound and Vibration*, Vol. 22, July 1988.



E1332 – 10a

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the ASTM website (www.astm.org/COPYRIGHT/).