



Standard Guide for Testing Sheathed Thermocouples, Thermocouples Assemblies, and Connecting Wires Prior to, and After Installation or Service¹

This standard is issued under the fixed designation E1350; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

INTRODUCTION

Thermocouples are widely used in industry and provide reliable service when used within their specified temperature range. However, if thermocouples fail in service the consequences can range from insignificant to life-threatening. Often, a costly loss of equipment, product, or operating time will result. The user should weigh the potential consequences of thermocouple failure when considering which tests should be performed either prior to, during, or after installation.

This standard is a guide for the field testing of thermocouples, thermocouple assemblies, and their connecting wires to ensure that they were not damaged during storage, installation, or use rather than being a guide for acceptance testing of thermocouples as delivered from the vendor. The test methods range from basic tests to verify that the thermocouple was properly installed to tests necessary for failure analysis. Thermocouple tests such as homogeneity, capacitance, and loop-current step-response require elaborate equipment and sophisticated analysis and are not included in this guide.

Faulty installation practices and in-service operation beyond prescribed limits are frequently the cause of failure in properly made sheathed thermocouples. Many of the most common types of these application errors may be identified through use of the test methods described in this document. For further information, the reader is directed to MNL 12, Manual on the Use of Thermocouples in Temperature Measurement,² which is an excellent reference document on metal sheathed thermocouples.

1. Scope

1.1 This guide covers methods for users to test metal sheathed thermocouple assemblies, including the extension wires just prior to and after installation or some period of service.

1.2 The tests are intended to ensure that the thermocouple assemblies have not been damaged during storage or installation, to ensure that the extension wires have been attached to connectors and terminals with the correct polarity, and to provide benchmark data for later reference when testing to assess possible damage of the thermocouple assembly after operation. Some of these tests may not be appropriate for

thermocouples that have been exposed to temperatures higher than the recommended limits for the particular type.

1.3 The tests described herein include methods to measure the following characteristics of installed sheathed thermocouple assemblies and to provide benchmark data for determining if the thermocouple assembly has been subsequently damaged in operation:

1.3.1 *Loop Resistance:*

1.3.1.1 Thermoelements,

1.3.1.2 Combined extension wires and thermoelements.

1.3.2 *Insulation Resistance:*

1.3.2.1 Insulation, thermocouple assembly,

1.3.2.2 Insulation, thermocouple assembly and extension wires.

1.3.3 *Seebeck Voltage:*

1.3.3.1 Thermoelements,

1.3.3.2 Combined extension wires and thermocouple assembly.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the*

¹ This guide is under the jurisdiction of ASTM Committee E20 on Temperature Measurement and is the direct responsibility of Subcommittee E20.04 on Thermocouples.

Current edition approved June 1, 2013. Published July 2013. Originally approved in 1991. Last previous edition approved in 2007 as E1350 – 07. DOI: 10.1520/E1350-13.

² *Manual on the Use of Thermocouples in Temperature Measurement*, MNL 12, ASTM. Available from ASTM International, www.astm.org.

responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.

2. Referenced Documents

2.1 ASTM Standards:³

E230 Specification and Temperature-Electromotive Force (EMF) Tables for Standardized Thermocouples

E344 Terminology Relating to Thermometry and Hydrometry

E608/E608M Specification for Mineral-Insulated, Metal-Sheathed Base Metal Thermocouples

E780 Test Method for Measuring the Insulation Resistance of Mineral-Insulated, Metal-Sheathed Thermocouples and Thermocouple Cable at Room Temperature

E839 Test Methods for Sheathed Thermocouples and Sheathed Thermocouple Cable

E1129/E1129M Specification for Thermocouple Connectors

E1684 Specification for Miniature Thermocouple Connectors

E2181/E2181M Specification for Compacted Mineral-Insulated, Metal-Sheathed, Noble Metal Thermocouples and Thermocouple Cable

MNL 12 Manual on the Use of Thermocouples in Temperature Measurement

3. Terminology

3.1 Definitions—The definitions given in Terminology **E344** shall apply to this guide.

3.2 Definitions of Terms Specific to This Standard:

3.2.1 extension wires, *n*—pair of wires having temperature-emf characteristics that match the thermocouple temperature-emf characteristics over a specified temperature range.

3.2.2 junction class, *n*—Style U junctions are electrically isolated from conductive sheaths and from reference ground and Style G junctions are electrically connected to conductive sheaths.⁴

3.2.3 sensing circuit, *n*—the combination of the thermoelements and extension wires, but excluding active signal conditioning components such as reference junction compensators, amplifiers, and transmitters.

3.2.4 sheathed-thermocouple assembly, *n*—an assembly consisting of two thermoelements within ceramic insulation contained within a metal protective sheath, electrically joined at a junction to form a thermocouple, with its associated parts.

3.2.4.1 Discussion—An assembly may include associated parts such as a terminal block and a connection head. The metal protecting tube, or sheath, has a moisture seal at the reference junction end. Usually the metal sheath is welded closed at the measuring end. However, if the thermocouple has an exposed junction, it must have an effective moisture seal at the measuring end as well as at the reference junction end.

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

⁴ Historically referred to as class 1 and class 2 junctions.

3.2.5 terminal block, *n*—a terminal device for mechanical connection of thermoelements and extension wires or for the connection of extension wires to each other or to instruments.

3.2.6 thermocouple connector, *n*—a quick-connect plug and jack in which the electrically connecting components have temperature-emf characteristics matching the extension wires or thermoelements they are intended to connect.

3.2.6.1 Discussion—The temperature-emf characteristics of the connector parts will match the extension wires or the thermoelements only over a specified temperature range. Thermocouple connectors are described in Specifications **E1129/E1129M** and **E1684**.

4. Summary of Tests

4.1 Loop Resistance Measurements:

4.1.1 Thermocouple—The electrical loop resistance is compared to the resistance measured before installation to ensure that the thermoelements have not been broken or been short circuited (for example, at the thermocouple connector) during the installation process.

4.1.2 Sensing Circuit—The measurements may be used to establish the loop resistance of the combined thermocouple assembly and extension wires and to ensure that the extension wires are not shorted and that all connections are secure. The resistance of the extension wires should be measured separately before they are connected to the thermocouple assembly.

4.2 Insulation Resistance Measurements:

4.2.1 Thermocouple Assembly—The room temperature insulation resistance of the installed Style U thermocouple assembly is compared to the resistance measured before installation to ensure that the sheath and moisture seal have not been damaged and that the thermoelements were not shorted to the sheath during installation.

NOTE 1—This test applies only to thermocouple assemblies with Style U thermocouple junctions. Thermocouples having Style G junctions cannot be tested in this manner.

4.2.2 Sensing Circuit—The measurement is to establish that the electrical isolation of the Style U thermocouples has not been degraded by the extension circuit.

4.2.3 Extension Wires—The measurement is to establish that the extension wires are continuous and not shorted to each other, or to any other component, including earth ground. This is a necessary measurement when Style G thermocouples are tested.

4.3 Seebeck Voltage Measurements:

4.3.1 Thermocouple Assembly—The measurement, dependent on a temperature difference between the measuring junction and the terminal block, is to verify that the thermocouple connector is mated to the thermocouple with proper polarity.

4.3.2 Sensing Circuit—The measurement, dependent on a temperature difference between the measuring junction and the terminating hardware, is to verify that correct polarity has been maintained in connecting the extension wires to the thermocouple.

5. Significance and Use

5.1 These test procedures confirm and document that the thermocouple assembly was not damaged prior to or during the installation process and that the extension wires are properly connected.

5.2 The test procedures should be used when thermocouple assemblies are first installed in their working environment.

5.3 In the event of subsequent thermocouple failure, these procedures will provide benchmark data to verify failure and may help to identify the cause of failure.

5.4 The usefulness and purpose of the applicable tests will be found within each category.

5.5 These tests are not meant to ensure that the thermocouple assembly will measure temperatures accurately. Such assurance is derived from proper thermocouple and instrumentation selection and proper placement in the location at which the temperature is to be measured. For further information, the reader is directed to MNL 12, Manual on the Use of the Thermocouples in Temperature Measurement² which is an excellent reference document on metal sheathed thermocouple uses.

6. Apparatus

6.1 *Digital Ohm-meter or Multi-meter*, a direct current resistance measurement instrument having a measuring range from zero ohms to at least 1 megohm with a resolution less than 1kiloohm.

6.2 *Megohmmeter or Megohm Bridge*, with ranges from 5×10^4 ohm to 10^{12} ohm with an accuracy of better than $\pm 10.0\%$ of the measured resistance and a test voltage selectable between 50 and 500 dc volts (VDC).

6.3 *Heat Source*, for example, a small propane type torch or an electric heat gun.

7. General Requirements

7.1 The following test procedures assume that the loop resistance and room temperature insulation resistance of the delivered thermocouple were already found to be acceptable by Test Method E839 prior to installation.

7.2 All thermocouple assemblies to be tested should be identified by a serial number or by some other type of unique identifier traceable to pre-installation tests and to a manufacturer's production run.

7.3 These procedures require that all circuits have electrical continuity.

7.4 For all connections the color codes and material composition of the extension wires should be appropriate for the particular thermocouple type being tested. See Specification E230 for standard thermocouple type color codes.

8. Procedure: Loop Resistance Measurements

8.1 *Thermocouple Loop Resistance*—With the thermocouple disconnected from its extension wires and temperature measuring instrument, measure the loop resistance at the plug connector pins or at the terminal block. The basic measurement

is simply to establish circuit continuity. For accurate loop resistance measurements to establish benchmark data and to ensure that the thermoelements are not shorted to each other (for example, at the thermocouple connector) use a digital ohmmeter able to measure resistance with a resolution smaller than 0.1 ohm. Because any Seebeck voltage generated by the thermocouple will affect the resistance value measured, two resistance measurements shall be made, with the second measurement taken with reversed polarity from the first. The average of the two measurements is the thermocouple's true loop resistance. **Warning**—Ohm-meters function by measuring the voltage produced by passing a small DC current through the unknown resistance. If the thermocouple is in a temperature gradient zone such that the measuring and reference junctions are at different temperatures, the thermocouple's Seebeck voltage will add to or subtract from the voltage measured by the ohm-meter. The objective of averaging the loop resistance measurements in forward and reverse polarities is to eliminate the effect of the thermocouple's Seebeck voltage. However, if a thermocouple with low loop resistance is tested while it is installed in a high temperature zone, the Seebeck voltage may be greater than the voltage produced by the ohm-meter, resulting in a negative voltage at the ohm-meter's terminals (see 8.1.3). Some digital multimeters may not indicate negative resistance and thus averaging the forward and reverse polarity measurements will result in an erroneous loop resistance measurement.

8.1.1 If very accurate resistance measurements are required, measure the ohm-meter's test lead resistance. If the ohm-meter's lead resistance is significant ($>0.1\%$ of the thermocouple's loop resistance), subtract the ohm-meter's test lead resistance from all subsequent measurements of the thermocouple's loop resistance.

NOTE 2—An installed thermocouple will often be at a different temperature than when it was tested before installation. The different temperature will result in a different loop resistance that should not be interpreted as a thermocouple defect.

8.1.2 If several thermocouples of the same type are installed near the same location and in the same thermal environment, compare the resistance per unit length, for all thermocouples in the group before and after installation. Damage may be suspected in a given thermocouple if its resistance per unit length is significantly ($>10\%$) different from the before and after installation readings of resistance per unit length of its companion thermocouples in the group.

NOTE 3—A loop resistance measurement, taken after the thermocouple assembly has been installed, which differs significantly from the initial loop resistance measurement will require replacement or repair of the thermocouple. If, for example, the thermocouple connector was rotated in relation to the sheath during installation, the thermoelements might have been broken or shorted at the connector and may be repairable.

8.1.3 An alternative method which may be used to determine the loop resistance of a thermocouple at which is in service is to shunt the thermocouple at its connector pins with a variable resistor. Measure the thermocouple's open circuit Seebeck voltage between the connector pins with a high impedance voltmeter capable of measuring accurately in the microvolt range (see Fig. 1). The temperature of the thermocouple's measuring junction and the connector's pins must




FIG. 1 An Alternative Method to Measure Loop Resistance

remain stable during the test. Close the switch and adjust the resistance of the variable resistor until the closed circuit voltage is $\frac{1}{2}$ that of the open circuit Seebeck voltage (this will occur when the variable resistor has the same resistance as the thermocouple's loop). The variable resistor is then disconnected from the circuit and its resistance measured directly with an ohmmeter. This method avoids the problem of the Seebeck voltage that is described in 8.1.

NOTE 4—At elevated ($>800^{\circ}\text{C}$) temperatures the insulation resistance of a thermocouple with a Style U junction may become so low that significant electrical shunting may occur either between the thermoelements or between the thermoelements and the sheath. In that case neither the loop resistance measurements nor the temperature measured by the thermocouple will be accurate. The insulation resistance of a thermocouple with a Style U junction at elevated temperature should be measured (see 9.3) before other test measurements are taken.

8.2 *Sensing Circuit Loop Resistance*—With the extension wires disconnected from the temperature measuring instrument but still connected to the thermocouple assembly, measure the total loop resistance of the combined thermocouple assembly and the extension wires in accordance with 8.1 to at least establish if electrical continuity of the extension wires and thermocouple assembly exists. If an accurate measurement of the extension wires' loop resistance is required, subtract the thermocouple assembly's loop resistance, measured in 8.1.2 or 8.1.3, from the total resistance measured to determine the loop resistance of the extension wires alone. Record the loop resistance of the extension wires for benchmark data. If the resistance per unit length of a given extension wire differs by more than $>5\%$ from other extension wires of the same type, then the extension wires or circuit connections are suspect and should be carefully examined for damage. For example, terminal blocks having loose or corroded connections can increase circuit resistance, or cause open or short circuits; any of which will result in incorrect temperature measurements.

8.2.1 If during normal operation a temperature reading becomes erratic or shows an abrupt shift, a defect may be found either in the thermocouple-extension wire circuit or in the instrumentation itself. If the instrumentation is not at fault, either or both of the thermocouple and extension wire can be replaced. For failure analysis, re-measure the total loop resistance of the extension wire and the thermocouple assembly and compare the measurement with the circuit's benchmark data. If there has been a significant change in the total resistance then the thermocouple's and the extension wires' loop resistances can be measured separately to establish where the change has occurred. Note that a stray, superimposed dc voltage will also affect a thermocouple's temperature reading and loop resistance measurements.

9. Procedure: Insulation Resistance Measurements

9.1 The insulation resistance test can only be performed on Style U thermocouples.

9.2 *Thermocouple Assembly Prior to Installation*—This test's objective is to verify that the moisture seal has neither been damaged nor deteriorated during storage. Measure the room temperature insulation resistance between the connector pins, terminal block, or leads and the metal sheath in accordance with Test Method E780. Compare the insulation resistance value with that measured earlier during acceptance testing, when the thermocouples were delivered. A decrease of insulation resistance by two orders of magnitude ($100\times$) or more from the acceptance test measurement value indicates damage to either the sheath or moisture seal during storage. If the result is acceptable, record the insulation resistance value obtained as a benchmark for the future.

9.3 *Thermocouple Assembly After Installation*—Measure the room temperature insulation resistance in accordance with Test Method E780 immediately after the thermocouple has been installed in order to compare the before and after installation values. The measurement shall be taken before connection of the extension wires between the connector pins, terminal block, or leads and the metal sheath. A decrease of insulation resistance by two orders of magnitude ($100\times$) or more from the "prior to" installation measurement value indicates damage to either the sheath or moisture seal during installation. If the result is acceptable, record the insulation resistance value obtained as a benchmark for the future.

9.3.1 If the thermocouple assembly is subject to its service temperature (or an ambient temperature appreciably higher than room temperature) immediately after installation, a lower insulation resistance may be expected as a consequence of the higher temperature's known effect on insulation resistance values (see Note 5). In this event, the prior to and after insulation resistance values of similar and nearby thermocouple assemblies can be compared in order to estimate the decrease in insulation resistance that may be expected for the particular temperature distribution to which the thermocouple assembly is exposed.

NOTE 5—If the thermocouple is at an elevated ($>800^{\circ}\text{C}$) temperature, insulation resistance should be measured using the procedures given in Test Methods E839, but it is recommended that not more than 10 V DC be applied for the insulation resistance test.

9.4 *Sensing Circuit*—With the extension wires connected to the thermocouple assembly but disconnected from the temperature measuring instrument, measure the insulation resistance in accordance with Test Method E839 between a common reference ground and the combined extension wire and thermocouple assembly. Do not use a test voltage that exceeds the extension wires' insulation rating. For a Style G thermocouple assembly, the insulation resistance of the extension wires should be measured and recorded while disconnected from both prior to connection to the thermocouple assembly and temperature measuring instrument.

9.4.1 Lower insulation resistance values may be expected due to the inclusion of the extension wires in the test. However, a decrease of insulation resistance by two orders of magnitude

(100×) or more compared against the value recorded in 9.3 may indicate deterioration of the extension wires (often due to dirty or moist terminal connections). Deterioration is likely to occur should the extension wires have been exposed to a temperature higher than the rated temperature of the extension wires' insulation. As good practice, users should take care that no portion of the extension wire circuit passes through an area in which the temperature approaches the rated limits of the wire's insulation.

9.4.2 If during normal operation a temperature reading becomes erratic or shows an unexplained, abrupt shift, repeat the test described in 9.4. A decrease of insulation resistance by more than two orders of magnitude (100×) or more compared against the value initially recorded in 9.4 indicates the temperature reading is no longer reliable, either because of a sheath defect, moisture seal leak, or terminal connections that are loose, dirty, or moist.

10. Procedure: Seebeck Voltage Measurement Tests

10.1 *Thermocouple Assembly Polarity and Integrity Tests*—Perform these tests before the thermocouple assembly is installed. The purpose of the tests is to ensure that the thermocouple plug and any intermediate connections have been connected with correct polarities and that significant inhomogeneities, due to manufacturing defects or field assembly errors, are not present in the sheathed assembly. Use a portable heat source which provides an air temperature lower than that which could damage any component of the system to be tested. The test methods may require two operators in communication.

10.1.1 Attach the positive lead of a digital voltmeter to the positive pin of the thermocouple connector and the negative lead to the negative pin of the connector. Monitor the emf reading while using the heat source to warm the measuring junction of the thermocouple assembly, but do not warm the thermocouple connector itself. The emf should increase as the measuring junction temperature increases. A decreasing emf when the measuring junction is heated indicates the thermoelements are incorrectly connected to the thermocouple connector. If the emf does not change while warming the thermocouple's measuring junction's expected location, the thermoelements are likely short circuited between the measuring junction and the thermocouple connector, inadvertently creating a second but unwanted measuring junction in the thermocouple circuit.

10.1.2 Shield and heat sink the measuring junction of the thermocouple such that its temperature does not vary by more than 1°C/min.

10.1.3 Monitor the emf reading while using the heat source to progressively warm the thermocouple sheath between the thermocouple connector and the shielded and thermally stabilized measuring junction. Do not warm either the connector or the measuring junction. This test's objective is to detect a gross thermoelement inhomogeneity between the measuring junction and the connector of the sheathed thermocouple assembly. An observed emf change corresponding to more than 2°C temperature change for the type thermocouple being tested may

indicate a serious defect in the thermoelements (such as a splice of different materials or short circuit within the sheathed thermocouple).

NOTE 6—An inhomogeneity of significant magnitude which is spatially small may not be detected by this test and the user is cautioned against comparing these test results against in situ measurement errors. This test does not indicate the spatial non-uniformity of the Seebeck coefficient and serves only to identify thermoelement fracture, wiring flaws or other types of circuit error.

10.2 *Installed Thermocouple Polarity Tests*—Two alternative tests are described below. Both are intended to be performed immediately after the thermocouple assembly has been installed but prior to connection of the extension wires. The objective of either test is to verify that the thermocouple assembly has not been damaged during installation and, if terminal blocks are used, that the correct polarities have been maintained. The first test method is less complex and may be used if the thermocouple assembly has been installed in a location where the temperature of the measuring junction is known to be significantly different from the connector pins or terminals so as to produce a stable and measurable emf. The second test method, which involves applying heat to the thermocouple assembly, can be used only if the thermocouple under test is accessible.

10.2.1 Alternative Test A, in which a measurable emf is present after installation: measure the emf of the thermocouple at the connector plug pins or terminal block by attaching the positive lead of a digital voltmeter to the positive pin of the thermocouple connector and the negative lead of the voltmeter to the negative pin. The thermoelements are connected to the connector plug with correct polarity if: (1) a negative emf is found when the measuring junction is known to be at a *lower temperature* than the connector pins or terminals; or (2) a positive emf is found when the measuring junction is known to be at a *higher temperature* than the connector pins or terminals. Record the emf magnitude and polarity for each thermocouple assembly before connecting the extension wires.

10.2.2 Alternative Test B, in which a measurable emf is not present after installation, may require two operators able to communicate: no emf will be present when the measuring junction and reference junction of the thermocouple are at the same temperature. Attach the positive lead of a digital voltmeter to the positive pin of the thermocouple connector and the negative lead to the negative pin of the connector. Monitor the emf reading while using the heat source to warm the measuring junction of the thermocouple assembly but do not warm the thermocouple connector itself. The emf should increase as the measuring junction temperature increases. A decreasing emf when the measuring junction is heated indicates the thermoelements are incorrectly connected to the thermocouple connector. If the emf does not change while warming the measuring junction, the connector plug may have been rotated during installation such that the thermoelements have been short circuited.

10.3 *Sensing Circuit Polarity Tests*—Two alternative tests follow. Both are intended to be performed immediately after the thermocouple extension wires have been installed. The objective of either test is to verify that the thermocouple

extension wires have been connected with proper polarity. These tests are useful in discovering multiple polarity reversals in the measuring circuit that cannot be detected simply by observing the polarity of emf change in response to heating or cooling of the measuring junction alone. If the extension wires are color-coded, all wire connections should be inspected first to confirm that correct color coding was maintained throughout the entire circuit (refer to Specification **E230** for color codes in current use).

10.3.1 With the extension wires connected to the thermocouple assembly but not to the temperature measuring instrument, use a digital voltmeter to measure and record the magnitude and polarity of the emf at the point in the circuit at which the extension wires will be connected to the temperature measuring instrument.

10.3.1.1 Alternative Test A, in which a measurable emf is present after installation is identical to the test described in **10.2.1** except that the extension wires are connected to the thermocouple assembly. Compare the measured emf's polarity with that measured in **10.2.1**. A change of emf polarity at the point where the extension wires will be connected to the temperature measuring instrument indicates that the extension wires are connected incorrectly at one terminal located between the thermocouple assembly and the temperature measuring instrument. Note that this test will not indicate a change in emf or polarity if the extension wires have been incorrectly connected at both ends of the circuit.

10.3.1.2 Alternative Test B, in which a measurable emf is not present after installation, may require two operators able to communicate. No emf will be present when the measuring junction and reference junction of the thermocouple circuit are at the same temperature. Attach the positive lead of a digital voltmeter to the positive extension wire and the negative lead to the negative extension wire at the instrument connection end of the extension wires. Monitor the emf reading (which will be negligible) while using the heat source to warm all the connections, one at a time, between the thermocouple assembly

and the instrument connection end of the extension wires. A change of emf indicates the extension wires are either improperly matched to the thermocouple type or have been connected with incorrect polarity at the connection point being warmed.

10.3.2 As a general rule, the heat source should be passed along the entire accessible length of the thermocouple assembly and extension wires adjacent to and including any connections. Verify the polarity at the points where a connection is made from the original thermoelement to the extension wires and where the extension wires are interrupted or spliced.

10.3.3 If the thermocouple or extension wires are found to be connected with reversed polarity, it is critical to accurate temperature measurement that they be connected correctly at the point of error rather than making a second change of polarity at the temperature measuring instrument's terminals. While the introduction of a second polarity error would indicate correct polarity on the temperature measuring instrument, a significant error in the temperature reading would result.

11. Report

11.1 The final results of each test performed after installation is complete should be recorded for comparison against results of the tests performed on the thermocouple assembly prior to installation.

11.2 Test data measured periodically during the service life of the thermocouple assembly may be reported into the same test record to provide chronological documentation of the thermocouple assembly's condition.

12. Precision and Bias

12.1 As the validation tests of this guide are qualitative, precision and bias statements are not appropriate.

13. Keywords

13.1 sheathed thermocouples; thermocouple installations; thermocouple testings; thermocouples

APPENDIX

(Nonmandatory Information)

X1. Additional Information

X1.1 Users should be aware that an emf, not a temperature, is measured whenever a thermocouple is used to determine a temperature. Any extraneous voltages that are introduced into the thermocouple circuit will be interpreted as a temperature change, resulting in an error in the indicated temperature. Although extension wires are not usually a part of a sheathed thermocouple assembly, they can be a key part of the measuring system and if improperly installed with incorrectly matched

materials or polarity, the extension wires will produce voltages that will introduce substantial errors into the temperature measurement. When high accuracy measurements are made with calibrated thermocouples, it is especially important that the extension wires exhibit thermoelectric properties which closely match those of the accompanying thermocouple materials over the temperature range to which the extension wires are exposed.

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the ASTM website (www.astm.org/COPYRIGHT/).