



Standard Test Method for Oxyacetylene Ablation Testing of Thermal Insulation Materials¹

This standard is issued under the fixed designation E 285; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This test method covers the screening of ablative materials to determine the relative thermal insulation effectiveness when tested as a flat panel in an environment of a steady flow of hot gas provided by an oxyacetylene burner.

1.2 This test method should be used to measure and describe the properties of materials, products, or assemblies in response to heat and flame under controlled laboratory conditions and should not be used to describe or appraise the fire hazard of materials, products, or assemblies under actual fire conditions. However, results of this test method may be used as elements of a fire risk assessment which takes into account all of the factors which are pertinent to an assessment of the fire hazard of a particular end use.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

1.4 The values stated in SI units are to be regarded as the standard.

2. Referenced Documents

2.1 ASTM Standards:²

D 792 Test Methods for Density and Specific Gravity (Relative Density) of Plastics by Displacement

2.2 Federal Standards:³

BB-A-106C Acetylene, Technical, Dissolved

BB-O-925A Oxygen, Technical, Gas and Liquid

¹ This test method is under the jurisdiction of ASTM Committee E21 on Space Simulation and Applications of Space Technology and is the direct responsibility of Subcommittee E21.08 on Thermal Protection.

Current edition approved Nov. 1, 2008. Published December 2008. Originally approved in 1965 as E 285 – 65T. Last previous edition approved in 2002 as E 285 – 80(2002).

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from Standardization Documents Order Desk, Bldg. 4 Section D, 700 Robbins Ave., Philadelphia, PA 19111-5098, Attn: NPODS.

3. Summary of Test Method

3.1 Hot combustion gases are directed along the normal to the specimen until burn-through is achieved. The erosion rate of the material is determined by dividing the original thickness by the time to burn-through. The insulating effectiveness is determined from back-face temperature measurements. Insulation index numbers are computed by dividing the times for temperature changes of 80, 180, and 380°C, from the initial ambient temperature, by the original thickness. The insulation-to-density performance is computed by dividing the insulation index by the density of the panel.

3.2 The general characteristics of the oxyacetylene heat source are:

3.2.1 *Heat Flux*—835 W/cm² (cold-wall calorimeter).

3.2.2 *Velocity*—210 m/s (cold, unreacted gases).

3.2.3 Neutral flame conditions.

4. Significance and Use

4.1 This test method is intended to screen the most obvious poor materials from further consideration. Since the combustion gases more closely resemble the environment generated in rocket motors, this test method is more applicable to screening materials for nozzles and motor liners than for aerodynamic heating.

4.2 The environment for any specific high-temperature thermal protection problem is peculiar to that particular application. The conditions generated by the oxyacetylene heat source in this test method represent only one set of conditions; they do not simulate any specific application. Thus, the test results cannot be used to predict directly the behavior of materials for specific environments, nor can they be used for design purposes. However, over a number of years, the test has been useful in determining the relative merit of materials, particularly in weeding out obviously poor materials from more advanced data-generation programs. It has also been considered for use as a production quality-control test for rocket insulation materials.

4.3 The tester is cautioned to use prudence in extending the usefulness of the test method beyond its original intent, namely, screening. For situations having environments widely different from those of the test, the user is urged to modify the

oxyacetylene burner conditions to suit his requirements or perhaps change to a different heat-generating device that provides better simulation.

5. Apparatus

5.1 General—The apparatus shall consist of an oxyacetylene burner, a specimen holder, and means for measuring the time to burn-through and for recording the back-face temperature history of the specimen. Auxiliary apparatus all consist of a calorimetric device to measure heat-transfer rate as specified in 5.5.

5.2 Heat Source—The hot-gas source shall consist of a welding torch with suitable storage for acetylene and oxygen, together with suitable manifolds, flow regulators, and flow and pressure indicators, as shown schematically in Fig. 1.




FIG. 1 Schematic Diagram of Gas System

5.2.1 Torch—The torch shall be a Victor Model 315⁴ and shall be mounted so that the flame can be made to contact the specimen in less than 1/2 s from the time of actuation.

NOTE 1—Both a solenoid-powered mechanism and a hand-operated system of levers and push rods have been found to be adequate for this purpose.

5.2.2 Torch Tip—The tip shall be a Victor welding nozzle, Type 4, No. 7, equipped with a water jacket to minimize damage to the tip (Note 2).⁴ Details of the water jacket are shown in Figs. 2 and 3 and the torch tip is shown in Fig. 4.

NOTE 2—Proprietary designation cannot be avoided because of the broad spectrum of heat flux and flame patterns produced by competitive

torch tips of similar size. The Victor torch tip was selected on the basis of popularity, reproducibility of test results, and the relatively high heat flux it produces.

5.2.3 Fuel Storage and Manifold—A minimum of three acetylene cylinders shall be tapped simultaneously through a manifold and suitable pressure regulators. Cylinders shall be stored in an upright position and held at room temperature for at least 1 h, or until at equilibrium with room temperature, before using. The complete bank of cylinders shall be changed when the gage reads 0.7 MPa (100 psi). Acetylene storage tanks shall be protected by a check valve against accidental backflow from the torch. The acetylene shall be maintained at 294.2 K (70°F) when possible (Note 3). The purity of acetylene gas shall conform with Federal Specification BB-A-106C. The minimum acetylene content shall be 98 %.

NOTE 3—If this is not possible, the flow rate shall be corrected to 294.2 K in accordance with the flow rate specified in 5.2.7. The gas temperature shall not be allowed to exceed 299 K (79°F) or go below 289 K (61°F). Flow rates are corrected to 294.2 K because most manufacturers use this temperature as standard for calibration charts.

5.2.4 Oxygen Storage—A minimum of one oxygen tank shall be tapped through suitable pressure regulators. The oxygen shall be maintained at 294.2 K when possible (Note 4). The purity of oxygen gas shall conform with Federal Specification BB-O-925A. The minimum oxygen content shall be 99.5 %.

5.2.5 Safety Wall—The acetylene and oxygen storage area shall be isolated from the torch and the operating area by a suitable safety wall. For convenience, a two-stage regulator shall be located in the storage space and a single-stage pressure regulator located in the operating area.

5.2.6 Pressure Regulators—The regulators for the oxygen and the acetylene shall be capable of supplying the flow of gases specified in 5.2.7.

5.2.7 Flowmeters—The flowmeters for the acetylene and the oxygen shall be capable of supplying an accurate flow of gases.⁵ A variation of ± 5 % in gas flow rate due to instrumentation inaccuracies shall be permissible. The total flow rate of unreacted gases shall be 6.37 standard m³/h (294.2 K, 0.1 MPa) (225 standard ft³/h (70.0°F, 14.7 psia)), and the volume ratio of oxygen to acetylene shall be 1.20, which corresponds to essentially a neutral (oxygen-free) atmosphere.

NOTE 4—Flowmeter and pressure-gage settings are not specified because they will vary with the size and brand of flowmeter used. Consult manufacturers' instructions and calibration charts that are furnished with the flowmeters.

5.2.8 Flow-Pressure Gages—Suitable pressure gages shall be located at the exit (downstream) side of the flowmeters to monitor metered gas pressure. These gages shall be capable of supplying pressure measurements to maintain an accurate flow of gases in accordance with the specifications stated in 5.2.7.

NOTE 5—Pressure gages graduated 0 to 50 psig for oxygen and 0 to 30 psig for acetylene, both in 1-psig increments, have been found to be suitable.

⁴ Victor Equipment Co., 2800 Airport Rd., Denton, TX 76207.

⁵ Fischer-Porter Meter size 4, Fig. 1735, float shape BSVT, equivalent capacity 3.35 standard ft³/min air, has been found satisfactory for this purpose.




FIG. 2 Details of Water Jacket for Oxyacetylene Torch




FIG. 3 Assembly of Water Jacket for Oxyacetylene Torch

5.2.9 Temperature-Measuring Devices—Gas temperatures shall be measured with thermocouples, thermistors, or other suitable devices located at the exit (downstream) side of the flowmeters. Accuracy shall be within ± 1.0 K (± 1.8 F).

5.2.10 Piping, Hoses, and Needle Valves—Any combination of piping, tubing, hoses, and needle valves may be employed that have sufficient flow capacity to allow the fuel and oxidant to flow and be controlled at the specified flow rates.

5.3 Specimen Holder—The specimen and the calorimeter shall be supported in a suitable fixture arranged in such a fashion that it can be moved to align and set the distance and angle (see 8.4 for specifications) between the specimen, or calorimeter, and the torch tip (Note 6). The back surface of the

specimen shall be unobstructed by the holder for a distance of 25.4 mm (1.00 in.) out from the center of the specimen. Only materials with a thermal conductivity of 0.2 W/m·K (1.4 Btu·in./h·ft²·°F) or less shall contact the back of the specimen. The front surface of the specimen shall be unobstructed for a distance of 48.0 mm (1.89 in.) out from the center of the specimen. The total area of contact with front and back surfaces shall not exceed 52.0 cm² (8.06 in.²).

NOTE 6—A lathe bed with the specimen holder mounted on the tool carriage has been found to be adequate for the purpose. Water cooling of the holder is recommended to prolong service life.

5.4 Back-Face Temperature Measurement—The back-face temperature history shall be measured with a No. 28 AWG gage Chromel-Alumel thermocouple.

NOTE 7—For soft specimens, it shall be permissible to attach a thin copper disk, no larger than 10 mm (0.39 in.) in diameter, to the thermocouple junction.

5.4.1 Thermocouple Mounting—A spring-loaded, two-hole ceramic support rod no larger than 3.2 mm (1/8 in.) in diameter shall be used to maintain good contact between the thermocouple and the back surface of the specimen.

5.4.2 Temperature Data Recording—The thermocouple emf shall be recorded as back-face temperature, in degrees Celsius, as a function of time during the test. The data acquisition system (DAS) shall have a sampling rate of 1 s or less. Provision shall also be provided to record the starting time of the test.




FIG. 4 Victor Type 4, No. 7 Torch Tip

5.4.3 *Starting Switch*—An electric switch shall be installed on the torch mechanism to provide a “test start” event signal for the DAS for the erosion rate measurement.

5.5 *Calorimeter*—The cold wall heat flux of the hot-gas source shall be measured by using a calorimetric device.

5.6 *Burn-Through Detector*—A device such as a mirror, photocell, or direct visual means shall be used to detect burn-through of the specimen for termination of the test. If possible, this should also be included as an event record on the DAS.

5.6.1 *Timer*—The DAS shall provide timing increments of 0.1-s, or less, to measure the time to burn-through of the specimen.

6. Test Specimen

6.1 The test specimen shall be a square, flat panel 6.35 ± 0.41 mm (0.250 ± 0.016 in.) thick.

6.2 The dimensions of length and width shall both be $101.6^\circ + 0.0^\circ$, -0.71 mm ($4.000 + 0.000$, -0.028 in.).

6.3 Five replicates of each type of specimen shall be tested.

6.4 The thickness and density of the specimen shall be measured before the test.

6.4.1 The density shall be measured in accordance with Test Methods **D 792**. If the immersing fluid is known to have adverse effects on the specimen, the density shall be determined by a simple weight-to-volume calculation wherein the volume is determined by scaling the specimen.

6.4.2 The thickness at the point of flame impingement shall be determined with suitable micrometer calipers or equivalent. Reasonable care shall be taken to avoid depressing soft specimens.

7. Calibration

7.1 The DAS should be calibrated at frequent intervals using known reference voltages. The frequency of calibration

and exact procedure are not given here because of the large variety of data systems and standard voltage devices on the market.

7.2 The heat flux should be measured at the start of each testing day and at any time during testing when there is a suspicion of faulty torch operation, such as an irregularly shaped flame or an unusual color or noise in the flame. The torch tip should be replaced if the heat flux is outside the specifications listed below.

7.2.1 Mount the calorimeter in the specimen holder and connect to the DAS. Align the center of the calorimeter with the center line of the torch (**Note 8**) and set the correct distance between the calorimeter face and the end of the torch tip. Make heat-flux measurements at on-axis positions of 19.00 and 25.40 ± 0.30 mm (0.748 and 1.000 ± 0.012 in.).

NOTE 8—A metal rod, thin enough to slide into the torch port has been found to be suitable for aligning the central axes of the copper cylinder (of the calorimeter) and the torch tip. Absolute alignment is difficult because of the uncertainty of the exact location of the axis of the hot gas with respect to the axis of the torch tip. Moreover, since the torch port has a variable inside diameter, the aligning tool cannot be rigidly held in place to locate the axis. Best results have been obtained by inserting the tool into the torch port and slowly rotating the tool so that its free end describes a circle. Alignment adjustments are then made until the circle described is concentric with the copper cylinder of the calorimeter. Special care should be taken to avoid damaging the internal contour of the torch tip with the aligning tool.

7.2.2 Ignite the torch and adjust the gas flow rates to the conditions set forth in **5.2.7**. After flow conditions are stabilized, record data according to applicable calorimeter standard.

7.2.3 Make three trials at each position. The average heat flux at the two distances of 19.0 and 25.4 mm should be 835 ± 40 and 520 ± 60 W/cm², respectively. Replace the torch tip if the heat flux is outside these specifications.

8. Procedure

8.1 Check the alignment of the thermocouple with the center of the torch tip and adjust if needed.

8.2 Place the specimen in the holder and secure it firmly.

8.3 Mount the thermocouple against the backside of the specimen and connect the leads to the DAS.

8.4 Set the distance between the specimen face and torch tip to 19.0 ± 0.30 mm (0.748 ± 0.012 in.) and the angle between torch and specimen to $90 \pm 3^\circ$.

8.5 Ignite the torch and adjust the gas flow rates to the conditions set forth in 5.2.7. After flow conditions are stabilized, begin data recording and allow the torch flame to contact the specimen. Terminate the test at the instance that burn-through is detected.

8.6 Using the events recorded on the DAS, determine the burn-through time in seconds. Record the time for back-face temperature changes of 80, 180, and 380°C from ambient temperature.

8.7 Test five replicates of each type of specimen.

9. Calculation

9.1 *Insulation Index*—Calculate the insulation indexes for each replicate by dividing the time for back-face temperature changes of 80, 180, and 380°C (from ambient) by the original thickness of the specimen, as follows:

$$I_T = t_T/d \quad (1)$$

where:

I_T = insulation index at temperature T , s/m,

t_T = time for back-face temperature changes of 80, 180, and 380°C , s, and

d = thickness of specimen, m.

9.1.1 *Average Insulation Index*—Calculate the average insulation index as follows:

$$(I_T)_{\text{avg}} = \Sigma I_T/N \quad (2)$$

where:

$(I_T)_{\text{avg}}$ = average insulation index at temperature T , s/m,

ΣI_T = sum of individual values of insulation indexes at temperature T , and

N = number of replicates.

9.1.2 *Standard Deviation*—Calculate the standard deviation as follows:

$$S_T = \sqrt{\Sigma [I_T - (I_T)_{\text{avg}}]^2 / (N - 1)} \quad (3)$$

where:

S_T = standard deviation at temperature T ,

$(I_T)_{\text{avg}}$ = average index at temperature T ,

I_T = individual values of indexes at temperature T , and

N = number of replicates.

9.1.3 *Insulation-to-Density Performance*—Divide the average insulation index at each temperature by the average density of the replicates as follows:

$$(P_{\text{avg}})_T = (I_T)_{\text{avg}}/D_{\text{avg}} \quad (4)$$

where:

$(P_{\text{avg}})_T$ = average insulation-to-density ratio at temperature T , $\text{s}\cdot\text{m}^2/\text{kg}$, and

D_{avg} = average density of the replicates, kg/m^3 .

9.2 *Erosion Rate*—Calculate the erosion rate for each replicate by dividing the original thickness of the specimen by the time to burn-through as follows:

$$E = d/b \quad (5)$$

where:

E = erosion rate, m/s,

d = thickness of panel, m, and

b = burn-through time, s.

9.2.1 *Average Erosion Rate*—Calculate the average erosion rate as follows:

$$E_{\text{avg}} = \Sigma E/N \quad (6)$$

where:

E_{avg} = average erosion rate, m/s,

ΣE = sum of individual values or erosion rates, and

N = number of replicates.

9.2.2 *Standard Deviation*—Calculate the standard deviation as follows:

$$S_E = \sqrt{[\Sigma (E - E_{\text{avg}})^2] / (N - 1)} \quad (7)$$

where:

S_E = standard deviation of erosion rates,

E_{avg} = average erosion rate,

E = individual values of erosion rates, and

N = number of replicates.

9.3 *Average Heat Flux*—Calculate the average heat flux as follows:

$$F_{\text{avg}} = \Sigma F/N \quad (8)$$

where:

F_{avg} = average heat flux, W/m^2 ,

ΣF = sum of individual values of heat flux at each test position, and

N = number of trials at each test position.

10. Report

10.1 Report the following information:

10.1.1 Identity or composition of the sample. Whenever possible, identify components by their chemical names; state the amount of each component present; and, in the case of fibrous reinforcements, give the direction and orientation of the fibers,

10.1.2 Thickness of the specimen, m,

10.1.3 Density of the specimen, kg/m^3 ,

10.1.4 Average insulation indexes at the specified temperature rises, s/m,

10.1.5 Standard deviations of insulation indexes at the specified temperature rises,

10.1.6 Average insulation-to-density ratios at the specified temperature rises, $\text{s}\cdot\text{m}^2/\text{kg}$,

10.1.7 Average erosion rate, m/s,

10.1.8 Standard deviation of the erosion rate, and

10.1.9 Average heat flux at the test conditions, W/m^2 .

11. Precision

11.1 When the test method is used by a single operator in repetitive tests on a homogeneous material, the mean deviation from the arithmetic average is approximately $\pm 5\%$.

11.2 When the test method is used by competent operators in different laboratories, the mean deviation from the average is approximately $\pm 5\%$.

12. Keywords

12.1 ablation; convection; oxyacetylene; thermal insulation

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org).