



Standard Guide for In-Service Annealing of Light-Water Moderated Nuclear Reactor Vessels¹

This standard is issued under the fixed designation E509/E509M; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This guide covers the general procedures for conducting an in-service thermal anneal of a light-water moderated nuclear reactor vessel and demonstrating the effectiveness of the procedure. The purpose of this in-service annealing (heat treatment) is to improve the mechanical properties, especially fracture toughness, of the reactor vessel materials previously degraded by neutron embrittlement. The improvement in mechanical properties generally is assessed using Charpy V-notch impact test results, or alternatively, fracture toughness test results or inferred toughness property changes from tensile, hardness, indentation, or other miniature specimen testing (1).²

1.2 This guide is designed to accommodate the variable response of reactor-vessel materials in post-irradiation annealing at various temperatures and different time periods. Certain inherent limiting factors must be considered in developing an annealing procedure. These factors include system-design limitations; physical constraints resulting from attached piping, support structures, and the primary system shielding; the mechanical and thermal stresses in the components and the system as a whole; and, material condition changes that may limit the annealing temperature.

1.3 This guide provides direction for development of the vessel annealing procedure and a post-annealing vessel radiation surveillance program. The development of a surveillance program to monitor the effects of subsequent irradiation of the annealed-vessel beltline materials should be based on the requirements and guidance described in Practices E185 and E2215. The primary factors to be considered in developing an effective annealing program include the determination of the feasibility of annealing the specific reactor vessel; the availability of the required information on vessel mechanical and fracture properties prior to annealing; evaluation of the particular vessel materials, design, and operation to determine the

annealing time and temperature; and, the procedure to be used for verification of the degree of recovery and the trend for reembrittlement. Guidelines are provided to determine the post-anneal reference nil-ductility transition temperature (RT_{NDT}), the Charpy V-notch upper shelf energy level, fracture toughness properties, and the predicted reembrittlement trend for these properties for reactor vessel beltline materials. This guide emphasizes the need to plan well ahead in anticipation of annealing if an optimum amount of post-anneal reembrittlement data is to be available for use in assessing the ability of a nuclear reactor vessel to operate for the duration of its present license, or qualify for a license extension, or both.

1.4 The values stated in either SI units or inch-pound units are to be regarded separately as standard. The values stated in each system may not be exact equivalents; therefore, each system shall be used independently of the other. Combining values from the two systems may result in non-conformance with the standard.

1.5 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 ASTM Standards:³

- E185 Practice for Design of Surveillance Programs for Light-Water Moderated Nuclear Power Reactor Vessels
- E636 Guide for Conducting Supplemental Surveillance Tests for Nuclear Power Reactor Vessels, E 706 (IH)
- E900 Guide for Predicting Radiation-Induced Transition Temperature Shift in Reactor Vessel Materials, E706 (IIF)
- E1253 Guide for Reconstitution of Irradiated Charpy-Sized Specimens
- E2215 Practice for Evaluation of Surveillance Capsules from Light-Water Moderated Nuclear Power Reactor Vessels

¹ This guide is under the jurisdiction of ASTM Committee E10 on Nuclear Technology and Applications and is the direct responsibility of Subcommittee E10.02 on Behavior and Use of Nuclear Structural Materials.

Current edition approved Jan. 1, 2014. Published February 2014. Originally approved in 1997. Last previous edition approved in 2008 as E509–03 (2008). DOI: 10.1520/E0509_E0509M-14.

² The boldface numbers in parentheses refer to the list of references at the end of this standard.

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.



2.2 ASME Standards:

Boiler and Pressure Vessel Code, Section III, Rules for Construction of Nuclear Power Plant Components⁴
Code Case N-557, In-Place Dry Annealing of a PWR Nuclear Reactor Vessel (Section XI, Division 1)⁴

2.3 Nuclear Regulatory Commission Documents:

NRC Regulatory Guide 1.99, Revision 2, Effects of Residual Elements on Predicted Radiation Damage on Reactor Vessel Materials⁵

NRC Regulatory Guide 1.162, Format and Content of Report for Thermal Annealing of Reactor Pressure Vessels⁵

3. Significance and Use

3.1 Reactor vessels made of ferritic steels are designed with the expectation of progressive changes in material properties resulting from in-service neutron exposure. In the operation of light-water-cooled nuclear power reactors, changes in pressure-temperature ($P - T$) limits are made periodically during service life to account for the effects of neutron radiation on the ductile-to-brittle transition temperature material properties. If the degree of neutron embrittlement becomes large, the restrictions on operation during normal heat-up and cool down may become severe. Additional consideration should be given to postulated events, such as pressurized thermal shock (PTS). A reduction in the upper shelf toughness also occurs from neutron exposure, and this decrease may reduce the margin of safety against ductile fracture. When it appears that these situations could develop, certain alternatives are available that reduce the problem or postpone the time at which plant restrictions must be considered. One of these alternatives is to thermally anneal the reactor vessel beltline region, that is, to heat the beltline region to a temperature sufficiently above the normal operating temperature to recover a significant portion of the original fracture toughness and other material properties that were degraded as a result of neutron embrittlement.

3.2 Preparation and planning for an in-service anneal should begin early so that pertinent information can be obtained to guide the annealing operation. Sufficient time should be allocated to evaluate the expected benefits in operating life to be gained by annealing; to evaluate the annealing method to be employed; to perform the necessary system studies and stress evaluations; to evaluate the expected annealing recovery and reembrittlement behavior; to develop and functionally test such equipment as may be required to do the in-service annealing; and, to train personnel to perform the anneal.

3.3 Selection of the annealing temperature requires a balance of opposing conditions. Higher annealing temperatures, and longer annealing times, can produce greater recovery of fracture toughness and other material properties and thereby increase the post-anneal lifetime. The annealing temperature also can have an impact on the reembrittlement trend after the anneal. On the other hand, higher temperatures can create other

undesirable property effects such as permanent creep deformation or temper embrittlement. These higher temperatures also can cause engineering difficulties, that is, core and coolant removal and storage, localized heating effects, etc., in preventing the annealing operation from distorting the vessel or damaging vessel supports, primary coolant piping, adjacent concrete, insulation, etc. See ASME Code Case N-557 for further guidance on annealing conditions and thermal-stress evaluations (2).

3.3.1 When a reactor vessel approaches a state of embrittlement such that annealing is considered, the major criterion is the number of years of additional service life that annealing of the vessel will provide. Two pieces of information are needed to answer the question: the post-anneal adjusted RT_{NDT} and upper shelf energy level, and their subsequent changes during future irradiation. Furthermore, if a vessel is annealed, the same information is needed as the basis for establishing pressure-temperature limits for the period immediately following the anneal and demonstrating compliance with other design requirements and the PTS screening criteria. The effects on upper shelf toughness similarly must be addressed. This guide primarily addresses RT_{NDT} changes. Handling of the upper shelf is possible using a similar approach as indicated in NRC Regulatory Guide 1.162. Appendix X1 provides a bibliography of existing literature for estimating annealing recovery and reembrittlement trends for these quantities as related to U.S. and other country pressure-vessel steels, with primary emphasis on U.S. steels.

3.3.2 A key source of test material for determining the post-anneal RT_{NDT} , upper shelf energy level, and the reembrittlement trend is the original surveillance program, provided it represents the critical materials in the reactor vessel.⁶ Appendix X2 describes an approach to estimate changes in RT_{NDT} both due to the anneal and reirradiation. The first purpose of Appendix X2 is to suggest ways to use available materials most efficiently to determine the post-anneal RT_{NDT} and to predict the reembrittlement trend, yet leave sufficient material for surveillance of the actual reembrittlement for the remaining service life. The second purpose is to describe alternative analysis approaches to be used to assess test results of archive (or representative) materials to obtain the essential post-anneal and reirradiation RT_{NDT} , upper shelf energy level, or fracture toughness, or a combination thereof.

3.3.3 An evaluation must be conducted of the engineering problems posed by annealing at the highest practical temperature. Factors required to be investigated to reduce the risk of distortion and damage caused by mechanical and thermal stresses at elevated temperatures to relevant system components, structures, and control instrumentation are described in 5.1.3 and 5.1.4.

3.4 Throughout the annealing operation, accurate measurement of the annealing temperature at key defined locations must be made and recorded for later engineering evaluation.

⁴ Available from the American Society of Mechanical Engineers, 345 E. 47th Street, New York, NY 10017.

⁵ Available from Superintendent of Documents, U.S. Government Printing Office, Washington, DC 20402.

⁶ Consideration can be given to the reevaluation of broken Charpy specimens from capsules withdrawn earlier which can be reconstituted using Guide E1253 or from material obtained (sampled) from the actual pressure-vessel wall.



3.5 After the annealing operation has been carried out, several steps should be taken. The predicted improvement in fracture toughness properties must be verified, and it must be demonstrated that there is no damage to key components and structures.

3.6 Further action may be required to demonstrate that reactor vessel integrity is maintained within ASME Code requirements such as indicated in the referenced ASME Code Case N-557 (2). Such action is beyond the scope of this guide.

4. General Considerations

4.1 Successful use of in-service annealing requires a thorough knowledge of the irradiation behavior of the specific reactor-vessel materials, their annealing response and reirradiation embrittlement trend, the vessel design, fabrication history, and operating history. Some of these items may not be available for specific older vessels, and documented engineering judgment may be required to conservatively estimate the missing information.

4.1.1 To ascertain the design operating life, knowledge of the following items is needed: reactor vessel material composition, mechanical properties, fabrication techniques, nondestructive test results, anticipated stress levels in the vessel, neutron fluence, neutron energy spectrum, operating temperature, and power history.

4.1.1.1 The initial RT_{NDT} as specified in subarticle NB-2300 of the ASME Boiler and Pressure Vessel Code, Section III, should be determined or estimated for those materials of concern in the high fluence regions of the reactor pressure vessel. Alternative methods for the determination of RT_{NDT} also may be used. Consideration should be given to the technical justification for alternate methodologies and the data, which form the basis for the RT_{NDT} determination. Initial RT_{NDT} values should be available or estimated for all materials located in these areas.

4.1.1.2 The initial Charpy upper shelf energy as defined by Practices E185 and E2215 should be determined for materials of concern in the beltline region of the reactor pressure vessel. Initial upper shelf energy levels should be available or estimated for all materials located in this area.

4.1.1.3 Unirradiated archive heats of reactor vessel beltline materials⁷ should be maintained for preparation of additional surveillance samples as required by Practices E185 and E2215. Previously tested specimens should be retained as an additional source of material.

4.1.1.4 A record of the actual fabrication history, including heat treatment and welding procedure, of the materials in the beltline region of the vessel should be maintained.

4.1.1.5 The chemical composition should be determined for base metal(s) and deposited weld metal(s) and should include all elements potentially relevant to irradiation, annealing, and reirradiation behavior, for example, copper, nickel, phosphorus, manganese and sulfur. The variability in chemical composition should be determined when possible.

4.1.2 The anticipated remaining operating lifetime of the reactor vessel without annealing should be established using neutron embrittlement projections for the reactor vessel materials.

4.1.2.1 A surveillance program conducted in accordance with the requirements of Practices E185 and E2215 will provide information from which to evaluate vessel condition. Attention should be given to assuring that variations in the fluence-rate, neutron energy spectrum, and irradiation temperature for all different reactor neutron environments utilized are taken into account.

4.1.2.2 Transition temperature and upper-shelf Charpy energy data have been compiled and used to develop correlations of ΔRT_{NDT} and upper shelf drop versus fluence, for example, Guide E900 or NRC Regulatory Guide 1.99, Revision 2. These approaches, or other class-specific correlations, should be used to estimate ΔRT_{NDT} and upper shelf energy drop for the specific heats of materials in the vessel beltline.

4.1.2.3 The results of surveillance specimen tests required by Practice E2215 should be compared to the data developed in 4.1.2.2 to ascertain whether the materials are performing as expected. If not, an evaluation should be made to establish the extent of the remaining service life before restoration of properties is necessary.

4.1.3 Available data should be compiled for the annealing and post-anneal reirradiation responses of each class of material, and if available, for the specific heats of materials in the vessel. The bibliography (3-78) in Appendix X1 provides references for data compilation. Data collected should include transition temperature shifts and upper shelf Charpy energy changes. Actual fracture toughness data also should be compiled, as well as other supplemental information or data such as instrumented Charpy, indentation/hardness, tensile, and other miniature specimen test results (see Practice E636 for additional testing that can be utilized in assessing annealing behavior). The extent of the increased service life after annealing should be estimated using the guidance provided in Appendix X2.

4.1.4 Irradiated material from the vessel surveillance program should be retained as a source of material for future vessel condition assessments.

5. Annealing Method

5.1 The annealing method selected should consider the magnitude of the recovery needed to extend the lifetime, the predicted annealing response, the reirradiation response, the accessibility of the reactor vessel to allow inspection and temperature monitoring, the constraints resulting from the design of the reactor, and the structural relationship of the reactor vessel to the primary system and supports. A detailed annealing procedure should be prepared, for example, see ASME Code Case N-577(2) and NRC Regulatory Guide 1.162. This written procedure should include all quality assurance measures and training to be conducted to assure an effective annealing operation.

5.1.1 The annealing method employed must not degrade the original design of the system. The parameters for a dry anneal may exceed the original design limits of the reactor vessel. In

⁷ Consideration should be given to the possibility of thermal embrittlement of beltline materials, including heat-affected-zones, as a result of the annealing heat-treatment.



this case, the primary coolant water has been removed and a heating device is employed to raise the vessel temperature locally in the affected beltline region above the original design temperature. ASME Code Case N-557 (2) provides a framework for assuring design conformance for an in-service thermal anneal in air. A lower temperature wet anneal, in which the heating medium is the primary coolant water, should not exceed the original design pressure and temperature for the reactor vessel.

5.1.2 A review of all reactor components likely to be impacted by the anneal should be completed prior to the initiation of the anneal.

5.1.3 Consideration should be given to the effects of mechanical and thermal stresses and temperature on all system components, structures, and control instrumentation. Specific material properties should be justified by the analyst evaluating these effects. Examples of such effects are as follows:

5.1.3.1 Changes in the properties of friction reducing materials in sliding or articulating connections.

5.1.3.2 Reduction in neutron and gamma absorption capacity of supplementary shielding materials.

5.1.3.3 Effect of thermal growth on closely machined articulated or sliding interfaces.

5.1.3.4 Changes in mechanical and thermal properties of the reactor vessel insulation.

5.1.3.5 Effect of elevated temperatures on low melting point alloys, if applicable.

5.1.4 A detailed thermal and stress evaluation should be performed to demonstrate that localized temperatures, thermal stresses, and subsequent residual stresses are acceptable. This evaluation will help to establish the heating system design and heat-up/cool-down rates for the anneal procedure.

5.1.4.1 Vessel distortion should be considered both analytically and physically. Measurement of dimensions prior to and after annealing should be considered to assess dimensional stability.

5.1.4.2 Adequate analytical estimation and actual measurement of concrete temperatures in the region near the reactor vessel are needed to avoid concrete degradation. The properties of the concrete should be known or estimated⁸ in order to demonstrate that no damage will occur during the annealing.

5.1.5 The annealing method selected must assure adequate recovery of the reactor vessel materials. An experimental program may be undertaken prior to the in-service anneal to establish the degree of material properties recovery for the specific materials in the beltline of the vessel (see [Appendix X2](#)). This program shall use materials that are representative of reactor vessel materials in accordance with the criteria set forth in Practice [E185](#) for material selection and irradiation conditions. For example, the program may use existing broken irradiated Charpy halves from the current surveillance program that have been reconstituted following Guide [E1253](#), or samples taken from the actual pressure vessel. Other miniature or small specimen testing techniques also can be considered if properly validated. The program also may assess the adequacy

of selected heat treatment conditions for achieving the minimum required recovery. The results from the experimental program should be compared with the data compiled for [4.1.3](#). Data generated relative to the actual vessel neutron exposure should be reviewed in relation to temperature, fluence and fluence-rate effects.

5.1.6 The annealing procedure employed should provide for adequate instrumentation to control and monitor the temperature of the vessel such that a complete temperature record is available throughout all phases of the annealing operation.⁹ Special consideration should be given to axial, azimuthal, and through-wall thermal gradients in the beltline region and any regions anticipated to experience high stresses during the anneal, such as the nozzles.

5.1.7 The annealing procedure should include a description of the annealing equipment, an outline of the operational requirements, and integration of pre-annealing test of the heating equipment. Consideration should be given to storage of the core, internals, and coolant.

5.1.8 Special precautions to assure the protection of plant personnel and the general public from any release of radioactive materials should be provided. The annealing operation also should give adequate consideration to the radiation exposure of personnel, as well as any radioactive waste processing, radioactive-material decontamination, and radioactive-waste shipment.

5.2 The annealing process must be carefully monitored to assure that the conditions outlined in the annealing procedure described in [5.1](#) are maintained. The temperature of the reactor vessel must be monitored to assure that the annealing operating conditions are maintained and to demonstrate that temperature gradients are consistent with the thermal and stress analyses.

6. Annealing Surveillance and Verification

6.1 The effectiveness of the anneal depends upon the degree of property recovery and the reembrittlement trend. The surveillance specimens, as described in Practice [E185](#), provide a means of assessing the degree of properties recovered from an anneal.

6.1.1 Guidelines for assessing annealing recovery from available materials are given in [Appendix X2](#). A surveillance program must be established after the anneal to monitor reirradiation embrittlement. [Appendix X2](#) also contains guidelines for such a surveillance program.

6.1.2 If sufficient materials are not available or if conditions dictate that the approach in [6.1.1](#) is inapplicable, an alternative program for demonstrating the effectiveness of the in-service anneal and for monitoring the reirradiation response of the vessel materials should be established. [Appendix X2](#) again contains guidelines that can be followed. The bibliography ([3-78](#)) given in [Appendix X1](#) also will be valuable in establishing an alternative program.

7. Documentation

7.1 A description and analysis of the annealing procedures, results, and supporting data should be prepared, for example,

⁸ Follow American Concrete Institute guidelines as appropriate. Additional guidance may be available from U.S. annealing demonstration programs.

⁹ U.S. annealing demonstrations provide further insight into the degree of instrumentation needed to adequately monitor and control the annealing operation.



see ASME Code Case N-557 (2) and NRC Regulatory Guide 1.162. This documentation should include, but not be limited to, the following information and data:

7.1.1 A description should be provided of all data and analyses used to support the justification for performing the anneal. This should include all irradiation analyses or test program results, as well as all special calculations, related stress analyses, and heating evaluations.

7.1.2 A description of all materials used in the establishment of the annealing process and the monitoring of the actual annealing operation should be included. This section should include the reporting requirements of Practices E185 and E2215.

7.1.3 A detailed description of the proposed annealing procedure and a chronology of the proposed versus actual procedure for the annealing operation should be documented. Special emphasis is to be given to the location of temperature monitors and their records.

7.1.4 A detailed evaluation of the results of the annealing operation with appropriate technical justification should be reported. Any limitations regarding material property recovery or future plant operation should be described and documented.

7.1.5 Applicable ASME codes, ASTM standards and guides, NRC regulations and guides, and other technical references should be provided. All appropriate regulations and standards should be addressed as to the extent to which they were met.

7.1.6 Specific details of the planned new surveillance program for monitoring the reembrittlement trend for the beltline materials should be described.

8. Keywords

8.1 fracture toughness; irradiation; nuclear reactor vessels (light-water moderated); radiation exposure; surveillance (of nuclear reactor vessels)

APPENDIXES

(Nonmandatory Information)

X1. BIBLIOGRAPHY OF MATERIAL PROPERTIES FOR PRESSURE VESSEL STEELS

X1.1 References containing existing material property information for pressure vessel materials are listed to cover annealing response, changes in RT_{NDT} and upper shelf recovery, and reirradiation embrittlement. Limited fracture toughness data also are available. These data are to be used in assessing the anticipated annealing recovery and reembrittlement for similar pressure vessel steels. These same data may be used to determine a generic response when relevant materials are not available for actual recovery demonstration and surveillance.

X1.2 The reference bibliography (3-78) of annealing information is not intended to be totally inclusive. Major emphasis is given to U.S. commercial pressure vessel steels and welds, particularly those with high copper concentrations that may be

critical in older operating plants. Studies before 1974 (see Refs (3-12)) involved steels that only are typical of a few commercial vessels in operation today.

X1.3 The work performed on annealing in the 1970s at the Naval Research Laboratory is summarized in Ref (13). For other sources of information during the 1970s, see Refs (14-18).

X1.4 Data and evaluations reported in the 1980s can be found starting with Ref (19). This compilation includes data for European and Russian steels, for example, see Refs (20-47).

X1.5 More recent studies for pressure vessel steels, primarily focused on the WWER-440 steels, are contained in Refs (68-78).

X2. GUIDANCE FOR VERIFYING RECOVERY AND RE-IRRADIATION EMBRITTLEMENT

X2.1 The key elements with respect to continued operation of a reactor vessel after annealing are the degree of recovery and the reembrittlement trend. Ideally, both of these elements should be measured using existing surveillance capsules containing the limiting reactor beltline materials. Older vessels, however, which may be the first candidates for annealing, may not have enough surveillance capsules, or the limiting material may not have been included in the surveillance program. Even if there are capsules that can be used to assess annealing and the subsequent reembrittlement, different lead factors may make future assessments difficult to directly quantify unless a reembrittlement trend curve can be estimated. The purpose of this appendix is to provide guidance for defining the post-

anneal reference temperature (RT_{NDT}) and to estimate and measure the reembrittlement trends for reactor beltline materials. This guide is general since it is impractical to give specific quantitative directions due to the variety of materials, irradiation conditions, and other considerations such as future operating plans.

X2.2 Quantification of annealing recovery has been studied in detail, primarily in test reactor environments, while subsequent reembrittlement trends have less supporting data, and therefore, less definition. Upper shelf Charpy energy changes can be addressed in a similar manner as the RT_{NDT} approach presented in this appendix.

X2.3 The approach presented here is to provide guidance in developing an approximate annealing/reembrittlement trend curve from the existing surveillance irradiation data and several correlations that can be checked with other available capsule results, post-anneal, and used to project future trends. Test reactor irradiations with archive, or representative, materials may be used in special cases to check the trend curve methodology, but uncertainties due to temperature and fluence-rate effects should be considered.

X2.4 Since the data base of annealing recovery and reembrittlement trend does not cover all materials and annealing conditions, several assumptions have been made in developing a trend curve approach, and these assumptions should be kept in mind using the methodology. Mechanistic modeling of the irradiation, annealing, and reirradiation processes for plant specific materials may provide useful guidance and help reduce uncertainties in using this methodology.

X2.5 A conservative methodology of post-anneal reirradiation trend curve development is schematically shown in Fig. X2.1. This methodology is termed “lateral shift” since the initial irradiation trend curve merely is translated laterally to project reirradiation behavior.

X2.5.1 The initial irradiation correlation must be established for the critical material(s). Suggested methods include using Guide E900 or NRC Regulatory Guide 1.99, Revision 2. From these guides, a mean prediction curve for initial irradiation (I) damage is used with an approximate variance (σ_I^2). Existing surveillance data, or other appropriately justified data, can be used to adjust the mean curve, similar to the process allowed in NRC Regulatory Guide 1.99, Revision 2.

X2.5.2 The next step is the estimation of the annealing recovery for the irradiated-annealed (IA) condition. An approach, such as suggested in NRC Regulatory Guide 1.162 and documented in Ref (49), may be used. This approach has been statistically analyzed, and the corresponding overall variance (σ_{IA}^2) is no greater than that from the original irradiation. The variance associated with the anneal, therefore, is encompassed in the irradiation variance: $\sigma_{IA}^2 = \sigma_I^2$. Certain

limitations of this approach are acknowledged in Ref (49) relative to the range of applicable data and caution should be exercised when approaching these limiting conditions. The limited extent of data used to develop the predictive equations also should be considered.

X2.5.3 Next is a lateral shift of the initial irradiation embrittlement path to become the post-anneal reirradiation trend curve for the irradiated-annealed-reirradiated (IAR) condition. This step has some technical uncertainty, but appears to be a logical first approximation. A variance σ_{IAR}^2 (assumed equivalent to σ_I^2) for reembrittlement may be used to project a reirradiation trend curve and approximate statistical bound.

X2.5.4 The predicted trend curve should be checked by experimental results. This verification should be planned well before the actual annealing takes place. The suggested procedures that may be followed in evaluating the estimated trend curve are described in X2.7.

X2.6 The “vertical shift” trend curve approach is similar to that of the “lateral shift,” except the portion of the initial irradiation trend, projected as reirradiation behavior, is translated down vertically as shown in Fig. X2.2. The use of this estimated trend curve should be justified with actual post-anneal reirradiation data since the vertical shift method predicts significantly lower changes in RT_{NDT} after thermal annealing. Limited data show that reembrittlement trends for anneals near 850°F (454°C) for one week lie between the lateral and vertical shift approaches.

X2.7 The following procedures provide guidance for assessing recovery and reembrittlement prior to making the decision to anneal, as well as developing the post-vessel anneal surveillance program once the decision to anneal has been made. The new surveillance program will provide a check on the recovery and reembrittlement estimation methodology just described and provide actual data for making adjustments when appropriate.




FIG. X2.1 Lateral Shift Method for Estimating Reirradiation Embrittlement




FIG. X2.2 Vertical Shift Method for Estimating Reirradiation Embrittlement



X2.7.1 First, withdraw all, or nearly all, capsules from the reactor and follow the diagram in Fig. X2.3.¹⁰ The entry point into the flow diagram is to answer the question in the top diamond-shaped box as to whether or not there is adequate material available to perform testing on the vessel materials or

¹⁰ One capsule may be kept in place in case the decision to anneal is later reversed, or for contingency purposes.




FIG. X2.3 Procedure for Evaluating Annealing Feasibility and Reembrittlement Trend



other representative materials.¹¹ If the answer is yes, then the following sequence of steps beginning in X2.7.2 should be followed. If the answer is no, the steps beginning in X2.7.3 should be followed. Note that the boxes in Fig. X2.3 are identified with the appropriate paragraph number as used throughout X2.7.

X2.7.2 For Use When Adequate Vessel or Representative Material Exists—The material can come from the existing surveillance program (tested or untested specimens,) samples taken from the vessel wall, archived material from the original vessel construction or the surveillance program, which can be irradiated, or from materials available from other sources that can be justified as representative.

X2.7.2.1 An evaluation of how much material is available should be made to determine the extent of testing that can be performed for *IA* and *IAR* condition assessment. If sufficient material is available to perform both pre-vessel and post-vessel annealing evaluations, proceed to X2.7.2.2. If there is very limited material available, then emphasis should be placed upon the post-vessel anneal evaluations in the new surveillance program, and the user should proceed to X2.7.2.3.

X2.7.2.2 Pre-vessel annealing testing of irradiated materials for evaluating the *IA* response, using the projected annealing time and temperature, should be performed and compared to the existing *IA* correlation for the same time-temperature and material condition. If additional material is available, as well as time to perform further irradiations prior to vessel annealing, *IAR* experiments, again using the projected annealing time and temperature, can be performed to test the lateral shift model and provide further insight prior to making the final decision to anneal. Test reactor irradiations can be considered for *IA* and *IAR* conditioning. Proceed to X2.7.2.4.

NOTE X2.1—Actual testing is indicated in Fig. X2.3 by use of a parallelogram-shaped box.

X2.7.2.3 Since there is not adequate material to develop *IA* data prior to vessel annealing, the *IA* correlation approach should be used to assess the degree of anticipated recovery for the vessel materials. The rectangular-shaped box indicates an evaluation or analytical step. Proceed to the next step.

X2.7.2.4 The lateral shift model for *IAR* behavior should be used to assess the benefits to be realized once the vessel is placed back in service and operated to some future point in time.

X2.7.2.5 Utilizing the recovery *IA* measured data, if available, and the *IA* correlations for the vessel materials, coupled with the lateral shift *IAR* model, the actual decision to anneal the vessel can be made. If inadequate recovery, or reembrittlement trends, or both, suggest poor performance

from annealing, move to X2.7.4. If the decision to anneal is affirmative, then proceed as follows for the post-vessel anneal surveillance program.

X2.7.2.6 The new post-vessel anneal surveillance program should be planned to utilize the best combination of available vessel and representative materials for *IA* and *IAR* assessment.

X2.7.2.7 Perform post-vessel annealing on material irradiated to approximately the same fluence as the vessel, preferably in the reactor which is to be annealed, to determine the vessel *IA* condition. The lower bound time and temperature from the actual vessel anneal should be used for the test material annealing conditions. Another consideration would be the upper bound temperature and time if temper-type embrittlement is expected to be relevant.

X2.7.2.8 The *IA* data generated from the new surveillance program should be compared with projections from existing correlation(s). If the results are within appropriate statistical limits, there are advantages in being able to directly use the *IA* correlation(s) for complete vessel calculations, so proceed to the next step. If the results are different statistically, proceed to X2.7.2.10 to make appropriate adjustments.

X2.7.2.9 Since the test results closely match and validate the correlation, continue to use existing *IA* correlation(s) for the vessel materials. Proceed to X2.7.2.11.

X2.7.2.10 When the tested material results from the new surveillance program do not match statistically the predictions from *IA* correlation, the differences between measured and predicted should be used to adjust the predicted response for the vessel materials using a simple proportionality approach, for example, see NRC Regulatory Guide 1.162. Proceed to the next step.

X2.7.2.11 The lateral shift method provides a prediction approach for reembrittlement trend and should be used initially unless there are data available to support a different trend methodology, that is, results from the optional *IAR* testing in X2.7.2.2.

X2.7.2.12 Post-vessel annealing reembrittlement data should be generated for the new surveillance program. At least one *IAR* measurement should be made to correspond to the targeted end-of-license (EOL) fluence for the vessel after annealing. Additional *IAR* measurements are encouraged since additional data can better define the reembrittlement trend. If only one additional *IAR* measurement can be made, it should be conducted at an intermediate fluence between the time of annealing and the targeted EOL.

X2.7.2.13 Once two *IAR* measurements are made, a new trend curve can be developed by calculating a “new” chemistry factor for reembrittlement, similar to the preanneal embrittlement approach in NRC Regulatory Guide 1.99, Revision 2 or using Guide E900 and continuing to use the lateral shift method. Another approach would be to fit the data to a model falling between the lateral shift and the vertical shift methods or using other predictive methods that can be justified technically. Once the data have been used to the maximum degree possible, accurate assessment for *P – T* limits and compliance with Regulatory PTS screening criteria can be made. Proceed to X2.7.5.

¹¹ “Representative” materials should match the critical base and weld materials in the vessel with regard to ASTM specification, material heat, vintage, and chemistry (copper and nickel content) in that order for base materials and weld wire specification, material heat, weld flux, vintage, and chemistry (copper, phosphorus, sulfur, and nickel content) in that order for weld metals, to the extent practical. In some cases, representative materials also can be equated to bounding materials when shown that the expected embrittlement trends should be greater than the actual critical materials. Practices E185 and E2215 provide details on original surveillance program design which can yield guidance in developing a post-anneal surveillance program.



X2.7.3 For Use When Adequate Vessel or Representative Material Does Not Exist—When there is not adequate or representative material available for developing a program to measure recovery and reembrittlement trends, more emphasis must be placed on the correlation processes.

X2.7.3.1 The *IA* recovery correlations and the lateral shift model for *IAR* trending must be used to assess the benefits to be realized from thermal annealing. This provides the key information for deciding upon the actual annealing of the embrittled vessel.

X2.7.3.2 This question is the same as in **X2.7.2.4**. If inadequate recovery or reembrittlement, or both, suggest poor performance from annealing, move to **X2.7.4**. If the decision to anneal is affirmative, then proceed as follows for a post-vessel anneal surveillance program.

X2.7.3.3 A new surveillance program will be needed to monitor the effects of continued embrittlement on vessel steels. Since there are no materials that can be judged as representative, material(s) from the class of steels in the vessel

should be selected in a conservative manner to develop a new surveillance program. Proceed to **X2.7.2.7**.

X2.7.4 This step represents the outcome if annealing is judged to be inadequate as a mitigative measure for radiation embrittlement for the projected EOL fluence of the vessel. Other options for embrittlement management should be pursued, some of which already may be part of the overall embrittlement management program.

X2.7.5 This is the completion step for all of paths in **Fig. X2.3**. Sufficient time must be planned to develop an acceptable surveillance program for assuring verification and monitoring of the annealing recovery and reembrittlement. The exact degree of timing depends upon many factors, including capsule lead factors and the condition of available materials. Test reactor experiments can be a viable option in circumstances in which immediate answers are needed, although it is preferable to utilize the actual operating vessel environment for irradiations.

REFERENCES

- (1) Schmitt, Winfried and Blauel, Johann G., "Application of Micromechanical Material Models for the Evaluation of the Fracture Toughness of Primary Circuit Steel Components," *Small Specimen Test Techniques Applied to Nuclear Reactor Vessel Thermal Annealing and Plant Life Extension*, ASTM STP 1204, pp. 106–117, 1993.
- (2) *White Paper: Technical Basis for ASME Code Case N-557, In-Place Dry Annealing of a PWR Nuclear Reactor Vessel*, TR-106967, Electric Power Research Institute, December 1996.
- (3) Carpenter, G. F., Knopf, N. R., and Byron, E. S., "Anomalous Embrittling Effects Observed During Irradiation Studies on Pressure Vessel Steels," *Nuclear Science and Engineering*, Vol 19, pp. 18–38, 1964.
- (4) Steele, L. E. and Serpan, Jr., C. Z., "New Information on Neutron Embrittlement and Embrittlement Relief of Reactor Pressure Vessel Steels," *Flow and Fracture of Metals and Alloys in Nuclear Environments*, ASTM STP 380, pp. 283–310, 1965.
- (5) Seman, D. J. and Pasierb, E. J., "Consideration on the Annealing of Irradiated Pressure Vessel Steel," *Transactions of the American Nuclear Society*, Vol 8, pp. 416–417, 1965.
- (6) Seman, D. J. and Pasierb, E. J., "Annealing of Irradiated Pressure Vessel Steel," *Transactions of the American Society*, Vol 9, pp. 389–390, 1966.
- (7) Serpan, Jr., C. Z., Steele, L. E., and Hawthorne, J. R., "Radiation Damage Surveillance of Power Reactor Pressure Vessels," *Journal of Basic Engineering*, Vol 89, pp. 221–232, 1967.
- (8) Serpan, Jr., C. Z. and Hawthorne, J. R., "Yankee Reactor Pressure Vessel Surveillance: Notch Ductility Performance of Vessel Steel and Maximum Service Fluence from Exposure During Cores II, III, and IV," *Journal of Basic Engineering*, Vol 89, pp. 877–910, 1967.
- (9) Steele, L. E., Hawthorne, J. R., and Gray, Jr., R. A., "Neutron Irradiation Embrittlement of Several Higher Strength Steels," *Effects of Radiation on Structural Materials*, ASTM STP 426, pp. 346–370, 1967.
- (10) Serpan, Jr., C. Z., *Notch Ductility and Tensile Property Evaluation of the PM-2A Reactor Pressure Vessel*, NRL Report 6739, Naval Research Laboratory, 1968.
- (11) Potapovs, U., Hawthorne, J. R., and Serpan, Jr., C. Z., "Notch Ductility Properties of SM-1A Reactor Pressure Vessel Following the In-Place Annealing Operation," *Nuclear Applications*, Vol 5, pp. 389–409, 1968.
- (12) Steele, I. E. and Serpan, Jr., C. Z., *Analysis of Reactor Vessel Radiation Effects Surveillance Programs*, ASTM STP 481, 1970.
- (13) Hawthorne, J. R., *Survey of Post-Irradiation Heat Treatment as a Means to Mitigate Radiation Embrittlement of Reactor Vessel Steels*, NUREG/CR-0486, NRL Report 8287, 1979.
- (14) Hall, J. F. and Seman D. J., *The Effect of Post-Irradiation Annealing and Reirradiation on the Fracture Properties of A302B Pressure Vessel Steel*, WAPD-TM-1095, Bettis Atomic Power Laboratory, 1973.
- (15) Hawthorne, J. R., Koziol, J. J., and Groeschel, R. C., "Evaluation of Commercial Production A533-B Plates and Weld Deposits Tailored for Improved Radiation Embrittlement Resistance," *Properties of Reactor Structural Alloys After Neutron or Particle Irradiation*, ASTM STP 570, pp. 83–102, 1975.
- (16) Spitznagel, J. A., Shogan, R. P., and Phillips, J. H., "Annealing of Irradiation Damage in High Copper-Ferritic Steels," *Irradiation Effects on the Microstructure and Properties of Metals*, ASTM STP 611, pp. 434–448, 1976.
- (17) Steele, L. E., *Neutron Irradiation Embrittlement of Reactor Pressure Vessel Steels*, Technical Report Series No. 163, International Atomic Energy Agency, Vienna, 1975.
- (18) Klausnitzer, E. N., Gersha, A., and Leitz, C., "Irradiation Behavior of Nickel-Chromium-Molybdenum Type Weld Metal," *Effects of Radiation on Structural Materials*, ASTM STP 683, pp. 267–277, 1979.
- (19) Hawthorne, J. R., *Notch Ductility Degradation of Low-Alloy Steels with Low-to-Intermediate Neutron Fluence Exposures*, NUREG/CR-1053, NRL Report 8357, 1980.
- (20) Mancuso, J. F., Spitznagel, J. A., Shogan, R. P., and Holland, J. R., "Correlation Between Microhardness, Tensile Properties, and Notch Ductility of Irradiated Ferritic Steels," *Effects of Radiation on Materials: Tenth Conference*, ASTM STP 775, pp. 38–48, 1981.
- (21) Hawthorne, J. R., Watson, H. E., and Loss, F. J., "Experimental Investigation of Multicycle Irradiation and Annealing Effects on Notch Ductility of A533-B Weld Deposits," *Effects of Radiation on Materials: Tenth Conference*, ASTM STP 725, pp. 63–75, 1981.
- (22) Loss, F. J., Menke, B. H., Gray, R. A., Hawthorne, J. R., and Watson, H. E., "J-R Curve Characterization of A533-B Weld Metal with Irradiation and Post-irradiation Annealing," *Effects of Radiation on Materials: Tenth Conference*, ASTM STP 725, pp. 76–91, 1981.



- (23) Hawthorne, J. R., "Appendix F-Reactor Pressure Vessel Annealing," *Resolution of the Reactor Vessel Materials Toughness Safety Issue*, NUREG-0744, Vol 2, 1981.
- (24) Hawthorne, J. R., "Significance of Nickel and Copper Content to Radiation Sensitivity and Post-irradiation Heat Treatment Recovery of Reactor Vessel Steels," *Effects of Radiation on Materials: Eleventh Conference, ASTM STP 782*, pp. 375–391, 1982.
- (25) Harvey, D. J., and Wechsler, M. S., "Kinetics of Annealing of Irradiated Surveillance Pressure Vessel Steel," *Effects of Radiation on Materials: Eleventh Conference, ASTM STP 788*, pp. 505–519, 1982.
- (26) Hawthorne, J. R., *Status of Knowledge of Radiation Embrittlement in USA Reactor Pressure Vessel Steels*, NUREG/CR-2511, NRL Memo Report 4737, 1982.
- (27) Mager, T. R., *Feasibility of and Methodology for Thermal Annealing an Embrittled Reactor Vessel*, EPRI NP-2712, Electric Power Research Institute, Vols 1 and 2, 1982.
- (28) Pachur, D., "Radiation Annealing Mechanisms of Low-Alloy Pressure Vessel Steels Dependent on Irradiation Temperature and Neutron Fluence," *Nuclear Technology*, Vol 59, pp. 463–475, 1982.
- (29) Hawthorne, J. R., *Significance of Nickel and Copper Content to Radiation Sensitivity and Postirradiation Heat Treatment Recovery of Reactor Vessel Steels*, NUREG/CR-2948, MEA-2006, 1982.
- (30) Hawthorne, J. R., *Exploratory Assessment of Post-Irradiation Heat Treatment Variables in Notch Ductility Recovery of A533-B Steel*, NUREG/CR-3229, MEA-2011, 1983.
- (31) Server, W. L., *Post-Irradiation Annealing Recovery of High Copper Reactor Pressure Vessel Weld Metal Toughness Properties*, NUREG/CR-3582, EGG-MS-6388, 1983.
- (32) Macdonald, B. P., "Post-Irradiation Annealing Recovery of Commercial Pressure Vessel Steels," *Effects of Radiation on Materials: Twelfth International Symposium*, Williamsburg, VA, ASTM STP 870, pp. 972–978, 1984.
- (33) Server, W. L., "Review of In-Service Thermal Annealing of Nuclear Reactor Pressure Vessels," *Effects of Radiation on Materials: Twelfth International Symposium, ASTM STP 870*, pp. 979–1008, 1984.
- (34) Lott, R. G., Mager, T. R., Shogan, R. P., and Yanichko, S. E., "Annealing and Reirradiation Response of Irradiated Pressure Vessel Steels," *Radiation Embrittlement of Nuclear Reactor Pressure Vessel Steels: An International Review (Second Volume)*, ASTM STP 909, pp. 242–259, 1986.
- (35) Pavinich, W. A. and Lowe, A. L., "The Effect of Thermal Annealing on the Fracture Toughness of Submerged-Arc Weld Metal," *Effects of Radiation on Materials: Thirteenth International Symposium, ASTM STP 956*, pp. 448–460, 1987.
- (36) Tipping, P., Waeber, W., and Mercier, O., "A Study of the Mechanical Property Changes of Embrittled Pressure Vessel Steels and Their Response to Annealing Treatments," *Transactions of the Ninth International Conference on Structural Mechanics in Reactor Technology (SMIRT)*, Vol G, pp. 115–127, 1987.
- (37) Hawthorne, J. R., and Hiser, A. L., *Experimental Assessments of Gundremmingen RPV Archive Material for Fluence Rate Effects Studies*, NUREG/CR-5201, MEA-2286, 1988.
- (38) Tipping, P., Waeber, W. and Mercier, O., "Study of a Possible Plant Life Extension by Intermediate Annealing of the Reactor Pressure Vessel, II, Confirmation by Further Annealing Studies," *NEA/CSNI-UNIPED Specialist Meeting on Regulatory and Life Limiting Aspects of Core Internals and Pressure Vessels*, CSNI Report No. 146, Vol 2, pp. 473–488, 1988.
- (39) Hawthorne, J. R. and Hiser, A. L., *Irradiation and Irradiation-Anneal-Reirradiation Studies of RPV Steels and Welds in Support of the BR3 Reactor*, MEA-2218, 1988.
- (40) Hawthorne, J. R., *Steel Impurity Element Effects on Postirradiation Properties Recovery by Annealing*, NUREG/CR-5388, MEA-2354, 1989.
- (41) Hawthorne, J. R., *Irradiation-Anneal-Reirradiation (IAR) Studies of Prototypic Reactor Vessel Weldments*, NUREG/CR-5469, MEA-2364, 1989.
- (42) Waeber, W. B. and Njo, D.-H., "The Swiss Research Program on Irradiation Embrittlement and Annealing of Reactor Pressure Vessel Steels," *Radiation Embrittlement of Nuclear Reactor Pressure Vessel Steels: An International Review (Third Vol)*, ASTM STP 1011, pp. 48–69, 1989.
- (43) Popp, K., et al., "Evaluation of Thermal Annealing Behavior of Neutron-Irradiated Reactor Pressure Vessel Steels Using Nondestructive Test Methods," *Radiation Embrittlement of Nuclear Reactor Pressure Vessel Steels: An International Review (Third Volume)*, ASTM STP 1011, pp. 188–205, 1989.
- (44) Mager, T. R. and Lott, R. G., "Semiempirical Model for Annealing and Reirradiation Embrittlement in Pressure Vessel Steels," *Radiation Embrittlement of Nuclear Reactor Pressure Vessel Steels: An International Review (Third Volume)*, ASTM STP 1011, pp. 206–216, 1989.
- (45) Mader, E., Lucas, G. E., and Odette, G. R., "The Effects of Metallurgical and Irradiation Variables on the Postirradiation Annealing Kinetics of Pressure Vessel Steels," *Effects of Radiation on Materials: Fifteenth International Symposium, ASTM STP 1125*, pp. 151–171, 1992.
- (46) Valo, M., et al., "Irradiation Response and Annealing Behavior of Pressure Vessel Model Steels and Iron Ternary Alloys Measured with Positron Techniques," *Effects of Radiation on Materials: Fifteenth International Symposium, ASTM STP 1125*, pp. 172–185, 1992.
- (47) Ahlstrand, R., et al., "Evaluation of the Recovery Annealing of the Reactor Pressure Vessel of NPP Nord (Griefswald) Units 1 and 2 by Means of Subsize Impact Specimens," *Radiation Embrittlement of Nuclear Reactor Pressure Vessel Steels: An International Review (Fourth Volume)*, ASTM STP 1170, pp. 321–343, 1993.
- (48) Popp, K., et al., "Irradiation and Annealing Behavior of 15Kh2MFA Reactor Pressure Vessel Steel," *Radiation Embrittlement of Nuclear Reactor Pressure Vessel Steels: An International Review (Fourth Volume)*, ASTM STP 1170, pp. 344–368, 1993.
- (49) Amayev, A. D., Kryukov, A. M., and Sokolov, M. A., "Recovery of the Transition Temperature or Irradiated WVER-440 Vessel Metal by Annealing," *Radiation Embrittlement of Nuclear Reactor Pressure Vessel Steels: An International Review (Fourth Volume)*, ASTM STP 1170, pp. 369–379, 1993.
- (50) Kupca, L. and Cepcek, S., "Thermal Annealing of the Reactor Pressure Vessel NPP Unit 2 in Jaslovské Bohunice for Its Radiation Embrittlement Regeneration," *Radiation Embrittlement of Nuclear Reactor Pressure Vessel Steels: An International Review (Fourth Volume)*, ASTM STP 1170, pp. 380–388, 1993.
- (51) Leitz, C., Klausnitzer, E. N., and Hofman, G., "Annealing Experiments on Irradiated NiCrMo Weld Metal," *Small Specimen Test Techniques Applied to Nuclear Reactor Vessel Thermal Annealing and Plant Life Extension, ASTM STP 1204*, pp. 417–423, 1993.
- (52) Kussmaul, K. and Fohl, J., "Review of the State of the Art in the Assessment for Material Degradation with Time," *International Journal of Pressure Vessels and Piping*, Vol 54, pp. 137–156, 1993.
- (53) Kryukov, A. M. and Sokolov, M. A., "Investigation of Material Behavior After Annealing Using Subsize Specimens," *Small Specimen Test Techniques Applied to Nuclear Reactor Vessel Thermal Annealing and Plant Life Extension, ASTM STP 1204*, pp. 417–423, 1993.
- (54) Amayev, A. D., et al., "Use of Subsize Specimens for Determination of Radiation Embrittlement of Operating Reactor Pressure Vessels," *Small Specimen Test Techniques Applied to Nuclear Reactor Vessel Thermal Annealing and Plant Life Extension, ASTM STP 1204*, pp. 424–439, 1993.
- (55) Valo, M. and Ahlstrand, R., "Application of Reconstitution Welding Technique for Studying Base Metal of a Novovonesh Unit-1 Trepan Sample," *Small Specimen Test Techniques Applied to Nuclear*



Reactor Vessel Thermal Annealing and Plant Life Extension, ASTM STP 1204, pp. 440–456, 1993.

- (56) Server, W. L., and Biemiller, E. C., “Recent Evaluation of ‘Wet’ Thermal Annealing to Resolve Reactor Pressure Vessel Embrittlement,” *Transactions of the 12th International Conference on Structural Mechanics in Reactor Technology (SMiRT)*, Vol F, 1993.
- (57) Ahlstrand, R., Valo, M., and Kohopaa, J., “Evaluation of Material Properties of the Reactor Vessel in NPP Greiswald Unit 2 Before and After Annealing,” *International Workshop on WVER-440 Reactor Pressure Vessel Embrittlement and Annealing*, IWG-LMNPP-94/3, 1994.
- (58) Rosinski, S. T. and Carter, R. G., eds., “Proceedings of the DOE/SNL/EPRI Sponsored Reactor Pressure Vessel Thermal Annealing Workshop,” SAND94-1515, Albuquerque, NM, 1994.
- (59) Iskander, S. K., Sokolov, M. A., and Nanstad, R. K., “Some Aspects of the Role of Annealing in Plant Life Extension,” *Transactions of the American Nuclear Society, 1994 Winter Meeting, Washington, DC, November 13–17, 1994*, Vol 71, American Nuclear Society, pp. 191–192, 1994.
- (60) Sokolov, M. A., McCabe, D. E., Iskander, S. K., and Nanstad, R. K., “Comparison of Fracture Toughness and Charpy Impact Properties Recovery by Thermal Annealing of Irradiated Reactor Pressure Vessel Steels,” *Seventh International Symposium on Environmental Degradation of Materials in Nuclear Power Systems—Water Reactors*, Vol 2, NACE International, pp. 771–782, 1995.
- (61) *Irradiation Embrittlement and Mitigation*, Proceedings of a Specialists Meeting Organized by IAEA, Espoo, Finland, October 1995.
- (62) Fabry, A., et al., “Research to Understand the Embrittlement Behavior of the Yankee Surveillance Plate and Other Outlier Steels,” *Effects of Radiation on Materials: Seventeenth International Symposium*, ASTM STP 1270, 1995.
- (63) Fabry, A., et al., “Enhanced Surveillance of Nuclear Reactor Pressure Vessels,” *Materials Aging and Component Life Extension*, Vol I, pp. 577–588, 1995.
- (64) Biemiller, E. C., *Results and Analyses of Irradiation/Annealing Experiments Conducted on a Reactor Pressure Vessel Weld and Plate Materials—Yankee Atomic Electric Company Test Reactor Irradiation Program*, EPRI TR-106001, 1995.
- (65) Hawthorne, J. R., *Experimental Tests of Irradiation-Anneal-Reirradiation Effects on Mechanical Properties of RPV Plate and Weld Materials*, SAND96-0119, 1996.
- (66) Iskander, S. K., Sokolov, M. A., and Nanstad, R. K., “A Perspective on Thermal Annealing of Reactor Pressure Vessel Materials from the Viewpoint of Experimental Results,” *ICONE-4, Proceedings of the ASME-JSME 4th International Conference on Nuclear Engineering, New Orleans, March 10–14, 1996*, Volume 1, Part A, ASME International, New York, pp. 479–491, 1996.
- (67) Eason, E. D., Wright, J. E., Odette, G. R., and Mader, E. V., *Models for Embrittlement Recovery Due to Annealing of Reactor Pressure Vessel Steels*, NUREG/CR-6327, 1995.
- (68) Kohopaa, J., “Effects of Post-Irradiation Thermal Annealing on Radiation Embrittlement Behaviour of Cr-Mo-V Weld Metals,” *Acta polytechnica Scandinavica*, Mechanical Engineering Series 132, Espoo, Finland, 1998.
- (69) Nanstad, R.K., Tipping, Ph., Waeber, W., and Kalkof, R.D., “Effects of Irradiation and Post-Annealing Reirradiation on Reactor Pressure Vessel Steel Heat JRQ,” *Proceedings of the IAEA Specialists Meeting on Irradiation Embrittlement and Mitigation*, Gloucester, England, May 2001.
- (70) Viehrig, H.W., Boehmert, J., and Ulbricht, A., “Comparison of the Irradiation Effects on Microstructure and Mechanical Properties of VVER-Type RPV Steels,” *Proceedings of the IAEA Specialists Meeting on Irradiation Embrittlement and Mitigation*, Gloucester, England, May 2001.
- (71) Platanov, P.A., Nikolaev, Yu. A., “Radiation Embrittlement Kinetics of the First Generation of VVER-440 RPVs After Post-Irradiation Annealing,” *Proceedings of the IAEA Specialists Meeting on Irradiation Embrittlement and Mitigation*, Gloucester, England, May 2001.
- (72) Kryukov, A., et al., “Advanced Model for the VVER RPV Material Re-Embrittlement Assessment,” *Proceedings of the IAEA Specialists Meeting on Irradiation Embrittlement and Mitigation*, Gloucester, England, May 2001.
- (73) Valo, M., et al., “Tentative Re-Irradiation Behaviour of WVER-440 Welds After Annealing,” *Proceedings of the IAEA Specialists Meeting on Irradiation Embrittlement and Mitigation*, Gloucester, England, May 2001.
- (74) Lucon, E., et al., “SCK-CEN Contribution to the IAEA Round Robin Exercise on WVER-440 RPV Weld Material: Irradiation, Annealing, and Re-Embrittlement,” *Proceedings of the IAEA Specialists Meeting on Irradiation Embrittlement and Mitigation*, Gloucester, England, May 2001.
- (75) Onizawa, K. and Suzuki, M., “Comparison of Transition Temperature Shifts Between Static Fracture Toughness and Charpy-v Impact Properties Due to Irradiation and Post Irradiation Annealing for Japanese A533B-1 Steels,” *Effects of Radiation on Materials: 20th International Symposium*, ASTM STP 1405, ASTM International, West Conshohocken, PA, 2002, pp. 109–124.
- (76) Viehrig, H.W., Boehmert, J., Dzugan, J., and Richter, H., “Master Curve Evaluation of Irradiated Russian VVER Type Reactor Pressure Vessel Steels,” *Effects of Radiation on Materials: 20th International Symposium*, ASTM STP 1405, ASTM International, West Conshohocken, PA, 2002, pp. 109–124.
- (77) Iskander, S.K., et al., “Reirradiation Response Rate of a High-Copper Reactor Pressure Vessel Weld,” *Effects of Radiation on Materials: 20th International Symposium*, ASTM STP 1405, ASTM International, West Conshohocken, PA, 2002, pp. 302–314.
- (78) Nanstad, R.K., et al., “Investigation of Temper Embrittlement in Reactor Pressure Vessels Steels Following Thermal Aging, Irradiation and Thermal Annealing,” *Effects of Radiation on Materials: 20th International Symposium*, ASTM STP 1405, ASTM International, West Conshohocken, PA, 2002, pp. 356–382.

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the ASTM website (www.astm.org/COPYRIGHT/).