



Standard Test Method for Behavior of Materials in a Vertical Tube Furnace at 750°C¹

This standard is issued under the fixed designation E136; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the U.S. Department of Defense.

1. Scope

1.1 This fire-test-response test method covers the determination under specified laboratory conditions of combustion characteristics of building materials.

1.2 Limitations of this fire-test response test method are shown below.

1.2.1 This test method does not apply to laminated or coated materials.

1.2.2 This test method is not suitable or satisfactory for materials that soften, flow, melt, intumesce or otherwise separate from the measuring thermocouple.

1.2.3 This test method does not provide a measure of an intrinsic property.

1.2.4 This test method does not provide a quantitative measure of heat generation or combustibility; it simply serves as a test method with selected (end point) measures of combustibility.

1.2.5 The test method does not measure the self-heating tendencies of materials.

1.2.6 In this test method materials are not being tested in the nature and form used in building applications. The test specimen consists of a small, specified volume that is either (1) cut from a thick sheet; (2) assembled from multiple thicknesses of thin sheets; or (3) placed in a container if composed of granular powder or loose-fiber materials.

1.2.7 Results from this test method apply to the specific test apparatus and test conditions and are likely to vary when changes are made to one or more of the following: (1) the size, shape, and arrangement of the specimen; (2) the distribution of organic content; (3) the exposure temperature; (4) the air supply; (5) the location of thermocouples.

1.3 This test method includes two options, both of which use a furnace to expose test specimens of building materials to a temperature of 750°C (1382°F).

1.3.1 The furnace for the apparatus for Option A consists of a ceramic tube containing an electric heating coil, and two concentric vertical refractory tubes.

1.3.2 The furnace for the apparatus for Option B (Test Method E2652) consists of an enclosed refractory tube surrounded by a heating coil with a cone-shaped airflow stabilizer.

1.4 This test method references notes and footnotes that provide explanatory information. These notes and footnotes, excluding those in tables and figures, shall not be considered as requirements of this test method.

1.5 The values stated in SI units are to be regarded as standard. The values given in parentheses are for information only.

1.6 *This standard is used to measure and describe the response of materials, products, or assemblies to heat and flame under controlled conditions, but does not by itself incorporate all factors required for fire-hazard or fire-risk assessment of the materials, products, or assemblies under actual fire conditions.*

1.7 *Fire testing is inherently hazardous. Adequate safeguards for personnel and property shall be employed in conducting these tests.*

1.8 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 ASTM Standards:²

D1929 Test Method for Determining Ignition Temperature of Plastics

D3174 Test Method for Ash in the Analysis Sample of Coal and Coke from Coal

E84 Test Method for Surface Burning Characteristics of Building Materials

¹ This test method is under the jurisdiction of ASTM Committee E05 on Fire Standards and is the direct responsibility of Subcommittee E05.23 on Combustibility.

Current edition approved Aug. 1, 2012. Published September 2012. Originally approved in 1958. Last previous edition approved in 2011 as E136 – 11. DOI: 10.1520/E0136-12.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

E176 Terminology of Fire Standards

E2652 Test Method for Behavior of Materials in a Tube Furnace with a Cone-shaped Airflow Stabilizer, at 750°C

2.2 ISO Standard:³

ISO 1182 Noncombustibility Test for Building Materials

ISO 13943 Fire Safety-Vocabulary

2.3 Other Standard:

BS 476 Combustibility Test of Materials³

3. Terminology

3.1 Definitions—For definitions of terms found in this test method, refer to Terminology E176 and ISO 13943. In case of conflict, the definitions given in Terminology E176 shall prevail.

4. Summary of Test Method

4.1 This test method uses a furnace to expose building materials to a temperature of 750°C (1382°F) until failure occurs or for at least 30 min.

4.2 This test method offers the choice of two options: Option A (Sections 6 through 9) and Option B (Test Method E2652).

4.3 The furnace for Option A consists of two concentric vertical refractory tubes.

4.4 The furnace for Option B (Test Method E2652) consists of an enclosed refractory tube surrounded by a heating coil with a cone-shaped airflow stabilizer.

4.5 Thermocouples are used to assess the temperature increases resulting from combustion of the building material.

4.6 Visual observation is used to assess the occurrence of flaming.

4.7 Section 15 is the report and acceptance criteria section for this test method (both options).

5. Significance and Use

5.1 While actual building fire exposure conditions are not duplicated, this test method will assist in indicating those materials which do not act to aid combustion or add appreciable heat to an ambient fire.

5.2 Materials passing the test are permitted limited flaming and other indications of combustion.

6. Apparatus for Option A

6.1 The test apparatus shown in Fig. 1, shall be used for Option A and shall consist primarily of the following:

6.1.1 *Refractory Tubes*—Two concentric, refractory tubes, 76 and 102 mm (3 and 4 in.) in inside diameter and 210 to 250 mm (8½ to 10 in.) in length, with axes vertical, and with heat applied by electric heating coils outside of the larger tube. A controlled flow of air is admitted tangentially near the top of the annular space between the tubes and passes to the bottom of the inner tube. The outer tube rests on a refractory bottom and the inner tube rests on three spacer blocks so as to afford

a total opening under the inner tube equal to or greater than that of the annular space. The refractory bottom plate has a removable plug for cleaning.

6.1.2 *Transparent Cover*—A transparent cover of heat-resistant glass or other transparent material shall be provided over the top of the inner tubes. The cover shall have a circular opening 28.7 ± 0.8 mm ($1\frac{1}{8} \pm \frac{1}{32}$ in.) centered over the axis of the tubes. This opening has an area of 645 mm² (1.0 in.²). The cover shall be in two equally-sized, movable parts.

6.1.3 *Thermocouples* and an automatically recording device shall be provided. The thermocouples shall be located as follows:

6.1.3.1 Thermocouple T_1 is located in the center of the air space between the two concentric, refractory tubes; approximately 204 mm (8 in.) down from the top of the 102-mm (4-in.) diameter tube (Note 1).

6.1.3.2 Thermocouple T_3 is located at the approximate geometric center of the specimen.

6.1.3.3 Thermocouple T_4 is located on the surface, in contact with the test specimen; in the same horizontal plane as T_3 .

6.1.3.4 Thermocouples T_1 , T_3 and T_4 shall have a time constant (time to reach 63.2 % of the furnace air temperature of 750°C (1382°F)) of 5 to 10 s (Note 2).

NOTE 1—Thermocouple T_1 is used for better regulation of the temperature of the air in the furnace space.

NOTE 2—Ungrounded, metallic-sheathed thermocouples of 1-mm diameter have been found to meet the time constant requirements.

6.2 *Specimen Holder*—The specimen holder for solid test specimens shall be as shown in Fig. 2.

6.2.1 Test specimens in granular or powder form shall be contained in thin-wall, open-top vessels of inert materials whose outside dimensions conform to the test specimen shape and maximum size specified in 7.2. These vessels shall have walls of either solid or mesh construction.

6.3 *Test Specimen Location*—During the test, the geometric center of the test specimen shall be located at the geometric center ± 3 mm ($\pm \frac{1}{8}$ in.) of the 76-mm (3-in.) diameter tube.

7. Test Specimens for Option A

7.1 The test specimens for Option A shall comply with 7.2 through 7.5.

7.2 All test specimens shall be 38 by 38 by 51 ± 2.5 mm (1.5 by 1.5 by 2.0 ± 0.1 in.).

7.3 The test specimens shall be dried at $60 \pm 3^\circ\text{C}$ ($140 \pm 5^\circ\text{F}$) for not less than 24 h but no more than 48 h.

7.4 Test specimens shall then be placed in a desiccator to cool at least 1 h before testing.

7.5 Not less than four identical specimens shall be tested.


8. Procedure for Option A

8.1 The procedure for Option A shall comply with 8.2 through 8.11.

8.2 *Test Room Setup:*

8.2.1 Conduct the test at room conditions of $21 \pm 3^\circ\text{C}$ ($70 \pm 5^\circ\text{F}$).

³ Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, <http://www.ansi.org>.



in.	3	4	6	10	10 ³ / ₄	1 in. ²	No. 16
mm	76	102	152	254	273	6.4 cm ²	Awg
							1.29

FIG. 1 Cross Section of Furnace Assembly

8.2.2 The test apparatus shall not be exposed to drafts or any other form of direct sunlight or artificial illumination which would adversely affect the observation of flaming inside the furnace.

8.2.3 The room temperature shall not change by more than 3°C(5°F) during a test.

8.3 *Air Flow*—Provide an external air source to supply clean air through a metal tube located near the top of the test apparatus, tangentially between the annular spaced ceramic tubes. The air shall be supplied at a steady and controllable rate of 0.0027 m³/min (0.10 ft³/min) ± 20 %, which will give an air flow of 3 m (10 ft)/min past a loaded test specimen in the furnace at 750°C (1382°F). Measure the air at room temperature, as specified in 8.2.1 and meter by a rotameter or other metering device in line with the metal tube.

8.4 *Stabilized Furnace Temperature*—Prior to the initial heating period insert a thermocouple, T₂, into the furnace from the top and place it where the geometric center of the test specimen will be during the test. Use this thermocouple to establish the stabilized furnace temperature.

8.5 *Test Furnace Setup*—Prepare the furnace by bringing the temperature of thermocouple T₂, located in the furnace at the position to be occupied by the geometric center of the

specimen, to a temperature of 750 ± 5.5°C (1382 ± 10°F). Maintain the temperature in the unloaded furnace for at least 15 min to ensure stability.

8.6 Once the operating temperature has been established by thermocouple, T₂, note the temperature on thermocouple T₁ and control the test chamber during the test to the observed T₁ temperature reading. It is acceptable to use T₃ as T₂.

8.7 *Test Procedure*—As rapidly as possible, insert the test specimen into the furnace with thermocouple T₃ inserted from the top of the test specimen to its geometric center and thermocouple T₄ attached to the side surface of the test specimen.

8.7.1 Close the top cover to the 6.4-cm² (1-in.²) opening immediately after insertion of the test specimen. Readings for thermocouples T₃ and T₄ shall be made at intervals (Note 3) not to exceed 10 s during the first 5 min, and as often as necessary afterwards to produce a smooth curve. Do not change the regulation of the current through the heating coils and the air flow during the test.

NOTE 3—A continuous read-out recording is preferred since it is possible for the maximum temperature to occur between the 10-s intervals.




FIG. 2 Specimen Holder for Solid Specimens

8.7.2 Continue the test until the temperatures at thermocouples T_3 and T_4 have reached maxima, or until it is evident that the specimen does not pass this test.

8.7.3 After 30 min of testing have elapsed, or at any time subsequent to that, testing shall be discontinued if, over the previous 10 minutes, the temperature measured at the center thermocouple T_3 has risen by no more than 1°C in any one minute. The final temperature reading shall be recorded as the maximum temperature.

8.8 Throughout the test make and record visual observations on the test specimens, noting quality, quantity, or intensity and duration of flaming or smoking, or both, and change of state.

8.9 Note and record the time of occurrence of any flaming and the duration of such flaming in seconds.

NOTE 4—Flaming is sometimes difficult to identify. Some specimens exhibit only flame as a steady blue-colored luminous gas zone. Do not ignore this and note it under “observations during test” in the test report.

8.10 Weigh each test specimen before and after testing and record the weight, in g, before and after the test for each test specimen.

8.11 Record the temperatures (initial, maximum and final), in °C, as measured by the appropriate thermocouples.

9. Calculation for Option A

9.1 The calculations for Option A shall be conducted in accordance with 9.2 through 9.3.

9.2 Calculate and record the weight loss for each of the test specimens, expressed as a percentage of the initial weight of the test specimen, to the nearest 1 %.

9.3 Calculate and record the temperature rise, in °C, for each of the test specimens.

9.3.1 Calculate the temperature rise as the difference between the maximum temperature and the initial temperature, as measured by thermocouple, T_3 .

10. Apparatus for Option B

10.1 The apparatus used for Option B shall be in accordance with Section 6 of Test Method E2652.

10.2 When the apparatus of Test Method E2652 is used to assess the behavior of building materials in accordance with Test Method E136, measurements shall be made using both of the optional thermocouples specified in 6.4.6 (test specimen center thermocouple) and 6.4.7 (test specimen surface thermocouple) of Test Method E2652. The values shall be reported as required in Section 15 of Test Method E136.

11. Test Specimens for Option B

11.1 The test specimens used for Option B shall be in accordance with Section 7 of Test Method E2652.

12. Test Setup and Calibration for Option B

12.1 The test specimens for Option B shall be in accordance with Section 8 of Test Method E2652.

13. Test Procedure for Option B

13.1 The test procedure for Option B shall be in accordance with Section 9 of Test Method E2652.

14. Calculations for Option B

14.1 The calculations for Option B shall be in accordance with Section 10 of E2652.

15. Report

15.1 Report the material as passing the test if at least three of the four test specimens tested meet the individual test specimen criteria detailed in 15.2 or 15.3. The three test specimens do not need to meet the same individual test specimen criteria.

15.2 If the weight loss of the test specimen is 50 % or less, the material passes the test when the criteria in 15.2.1 and in 15.2.2 are met:

15.2.1 The recorded temperatures of the surface and interior thermocouples do not at anytime during the test rise more than 30°C (54°F) above the stabilized furnace temperature measured at T_2 prior to the test.

15.2.2 There is no flaming from the test specimen after the first 30 s.

15.3 If the weight loss of the specimen exceeds 50 %, the material passes the test when the criteria in 15.3.1 and in 15.3.2 are met:

15.3.1 The recorded temperature of the surface and interior thermocouples do not, at any time during the test, rise above the stabilized furnace temperature measured at T_2 prior to the test.

15.3.2 No flaming from the test specimen is observed at any time during the test.

15.4 Report the option that was used.

16. Precision and Bias

16.1 No information is presented about the precision and bias of this test method for measuring combustion characteristics since the test results are nonquantitative and are reported as pass or fail. (See X1.6.)

16.2 There have been attempts to determine precision and bias for some of the numerical results for this test method but the results have not been made public.

17. Keywords

17.1 building materials; combustion; heated tube; limited combustion; Setchkin furnace; tube furnace; vertical tube furnace

APPENDIX

(Nonmandatory Information)

X1. COMMENTARY

X1.1 Introduction

X1.1.1 The difference in fire risk between a combustible building material and a noncombustible (or incombustible) one is generally obvious. However, some materials may contain only a limited amount of combustible content and may not contribute appreciably to an ambient fire. The term noncombustible, while in recognized use as indicating a material that will not ignite or burn, is indefinite in its application unless referenced to a well defined testing procedure.

X1.2 Definition

X1.2.1 Most dictionaries have defined noncombustible in simple terms, such as that used in the 1920 edition of the National Building Code promulgated by the National Board of Fire Underwriters (NBFU): Incombustible materials or construction are those that “will not ignite or burn when subjected to fire.” In 1943 the same code redefined incombustible construction as “assemblies which do not involve materials of such kind or quantity or so contained as to burn during exposure in a test fire or continue flaming or ignite after the furnace is shut off.”

X1.2.2 About this same time Committee C05 (now E05) and the New York City Building Code suggested adding a reference of 649°C (1200°F) as the fire exposure temperature. By 1949 the term incombustible was changed to noncombustible in the National Building Code without definition. The first

edition of the BOCA Basic Building Code (1950) defined a noncombustible material as “any material which will neither ignite or actively support combustion in air at a temperature of 649°C [1200°F] during an exposure of five minutes in a vented tube or vented crucible furnace.”

X1.2.3 The 1955 edition of the NBFU National Building Code established a definition for noncombustible material (1)⁴ that was subsequently adopted by other model codes, the Life Safety Code (2), and most local codes. The adopted definition was as follows:

Noncombustible as applied to a building construction material means a material that, in the form in which it is used, falls in one of the following groups (a) through (c). It does not apply to surface finish materials nor to the determination of whether a material is noncombustible from the standpoint of clearances to heating appliances, flues or other sources of high temperature. No material shall be classed as noncombustible which is subject to increase in combustibility or flame spread rating beyond the limits herein established, through the effects of age, moisture or other atmospheric condition. Flame spread rating as used herein refers to ratings obtained in accordance with Test Method E84.

a) Materials no part of which will ignite and burn when subjected to fire. Any material that liberates flammable gas

⁴ The boldface numbers in parentheses refer to the list of references appended to this method.

when heated to a temperature of 750°C (1382°F), for 5 min shall not be considered noncombustible within the meaning of this paragraph.

b) Materials having a structural base of noncombustible material, as defined in (a), with a surfacing not over 1/8-in. thick that has a flame spread rating not higher than 50.

c) Materials, other than as described in (a) or (b), having a surface flame spread rating not higher than 25 without evidence of continued progressive combustion and of such composition that surfaces that would be exposed by cutting through the material in any way would not have a flame spread rating higher than 25 without evidence of continued progressive combustion.

X1.2.4 In adopting this definition, NBFU stated that it was based on a determination of which materials “could be properly classed as noncombustible and then fixing the qualifying conditions in the definition to include these materials.” The definition was considered to apply to materials used for the walls, roofs, or other structural parts of buildings, but not to surface finish materials and not to the determination of whether a material is noncombustible from the standpoint of clearances to heating appliances, flues, or other sources of high temperature.

X1.2.5 After Test Method E136 was promulgated, (initially as a tentative in 1958, then as a full standard in 1965), many building codes replaced either part (a) of the NBFU definition or the entire definition with the specification that materials shall have been successfully tested in accordance with Test

Method E136. In 1973, the American Insurance Association (successor to NBFU) introduced a definition of a limited-combustible material and redefined a noncombustible material as one that, in the form in which it is used and under the conditions anticipated, will not ignite, burn, support combustion, or release flammable vapors, when subjected to fire or heat.

X1.2.6 To avoid misinterpretation in the use of the term noncombustible, Committee E05 has decided to limit the use of this term, and it was eliminated from the title and text of Test Method E136 in 1979. The current title provides a more specific description of the restricted nature of the test method.

X1.3 Origin and Early History of Test Method E136

X1.3.1 In 1912 R. E. Prince developed a furnace apparatus to study the ignitability of various wood species and investigate the effect of fire-retardant chemical treatments on their ignition characteristics (3,4). This apparatus as shown in Fig. X1.1 consisted essentially of a quartz cylinder 76 mm [3 in.] in diameter and 254 mm [10 in.] long, which was wound with a high electrical resistance nichrome ribbon. The cylinder was heavily insulated with asbestos. A lower chamber of about 89 mm (3.5 in.) in diameter and 203 mm (8 in.) deep formed a continuation of the upper chamber. A natural draft was used. No attempt was made to control the temperature or humidity of the air passing through the apparatus. The test temperature was 200°C (392°F). The 32 by 32 by 102-mm (1¼ by 1¼ by 4-in.) specimen was first weighted and then lowered in the hot quartz




FIG. X1.1 Inflammability Apparatus No. 1

cylinder where it remained until it ignited or for 40 min. Ignition time, if it occurred, was recorded and the specimen was then moved into the lower cooler chamber and allowed to burn for not more than 3 min. Loss of weight was then determined. Intensity of burning was also recorded.

X1.3.2 An apparatus quite similar to the Prince-FPL apparatus was later adopted as part of the British Standard 476-1932. In a revision of BS 476 in 1953, the test was renamed, and the furnace was preheated and maintained at 750°C (1382°F) prior to introduction of the specimen. This test specified that a material shall be considered combustible if, during the 15-min test period, any one of six specimens was observed to flame, to produce vapors that were ignited by a pilot flame, or to cause the temperature of the furnace to increase 50°C or more above 750°C (1382°F). In a report dated April 11, 1945, Dr. S. H. Ingberg suggested to Committee C05 (now E05) a method of test quite similar to the British test. The apparatus is shown in Fig. X1.2. A paper describing the test was published in the ASTM proceedings (5,6). The method differed from the British test by having the insulation enclosure round instead of square and employed a constant temperature of 750°C (1382°F) instead of a graduated temperature. Specimen size was 50 by 38 mm [2 by 1½ in.] by T where T equals the normal thickness or a maximum of 38 mm (1½ in.).

X1.3.3 A variation of the 1945 proposed apparatus and a method for determining the ignition temperature of plastics

under well controlled conditions was reported by N. P. Setchin in December 1949 (7). This apparatus is shown in Fig. X1.3. This test was subsequently adopted by Committee D20 as Test Method D1929.⁵ Major changes included elimination of the lower chamber, the provision of two concentric refractory cylinders and a controlled air flow directed between the cylinders, and the location of thermocouples.

X1.3.4 At the request of Subcommittee V (Nomenclature and Definitions) of Committee E05, tests on 47 specimens of solid materials were made in 1952 at the National Bureau of Standards (NBS), the National Research Council of Canada, The Ohio State University, Southwest Research Institute, and Owens-Corning Laboratories for the purpose of evaluating a technique for determining the combustibility classifications of solid materials (8,9). Professor Shank, at The Ohio State University, continued work on the test method. Through his efforts publication of a revised draft of the proposed test in the ASTM Bulletin was authorized at the February 8, 1957, meeting of Committee E05. Publication was for information purposes and comment (10).

X1.3.5 It was reported at the February 12, 1958, meeting of Committee E05 that no comments or criticisms had been received on the test method; a motion to publish it as a tentative

⁵ Published as Test Method D1929 – 62 T, that is, a tentative standard.





FIG. X1.2 Apparatus for Incombustibility Tests



NOTE 1—

Legend:
 Th_1 —Thermocouple on outer wall
 Th_2 —Thermocouple in air stream
 Th_3 —Thermocouple in or on the specimen

FIG. X1.3 Ignition Apparatus for Solids

test method was carried (11). The apparatus described in Tentative Standard Method of Test for Defining Noncombustibility of Building Materials⁶ was as shown in Fig. X1.4. Committee E05 voted for retention of the standard following its October 1963 meeting and at the same meeting voted to advance Test Method E136 to full standard that was published in 1965.⁷ Additional changes, described in X1.5 through X1.8, were incorporated in the 1973 and 1979 revisions of the test method.

X1.4 Other Test Methods

X1.4.1 At the request of the U.S. Coast Guard (June 3, 1970), a test program at the NBS was coordinated by a task subgroup of Subcommittee E05.05 to evaluate two principal tests used to determine combustibility: Test Method E136 and ISO R 1182 (12). A modification of ISO 1182 was adopted in 1973 by the Intergovernmental Maritime Consultative Organi-

zation (IMCO), an agency of the United Nations, for qualifying marine materials as noncombustible. This test is designated Resolution A270 (VIII) and incorporates changes in equipment details plus requirements for approval as noncombustible materials; in this test method, the average duration of flaming is limited to 10 s. This test method was adopted in 1976 as the U.S. Coast Guard test for approval of noncombustible materials for merchant vessels. ISO R 1182-1970 was superseded by ISO 1182-1979 using the apparatus shown in Fig. X1.5. The current version contains improved test method and equipment details and recognition of mass loss for low density polymeric materials. Furthermore, materials are no longer classified as noncombustible; instead, the following (average) test results are reported: (1) maximum readings of the furnace, surface, and center thermocouples; (2) duration of sustained flaming; and (3) mass loss. The annex in ISO R 1182 provides “suggested criteria for evaluation: not more than 50°C rise; not more than 20 s flaming; and not more than 50 % mass loss.”

X1.5 Rationale for Test Method E136 Criteria

X1.5.1 The choice of the 750°C (1382°F) furnace temperature derives basically from the BS 476 temperature limit. To

⁶ This test method was approved Aug. 1, 2012, and published as E136 – 58 T, that is, a tentative standard.

⁷ Method of Test E136 – 65, Determining Noncombustibility of Elementary Materials.




FIG. X1.4 Cross Section of Furnace Assembly




FIG. X1.5 Noncombustibility test apparatus—General arrangement

some extent, it also represents the upper limit of temperatures quoted in early code definitions of noncombustible materials. It is a temperature that is representative of levels that are known to exist during building fires, although temperatures from 1000 to 1200°C (1800 to 2200°F) are attained in intense fires. It is also used for determining the ash content of coal (Test Method D3174) although loss on ignition tests are commonly conducted at 900 to 1000°C (1600 to 1800°F). For many building materials, complete burning of the combustible fraction will occur as readily at 750°C (1382°F) as at 900 to 1000°C (1600 to 1800°F).

X1.5.1.1 The need to measure and to limit the duration of flaming and the rise in temperature arose since a brief period of flaming and a small amount of self heating were not considered serious limitations to the use of building materials which would otherwise be acceptable. Based on a series of tests on a wide variety of materials (9), a 30-s flame duration and a 30°C (54°F) rise were proposed as two criteria that could help to distinguish between clearly combustible and clearly noncombustible materials. The results of these tests indicated that the proposed levels would limit the combustible portion of noncombustible materials to a maximum of 3 %. It was further

suggested that the fire hazard characteristics of materials of uncertain classification should be determined in large-scale tests.

X1.5.2 The need to test at least four identical specimens was acknowledged in the initial 1957 proposal that specified that the results of tests should be averaged (10). In 1958 (or 1959), the test method was written to require that the criteria apply to “three or more of the four specimens tested,” possibly to recognize the variable nature of the measurement and the fact that there were difficulties in observing the presence and duration of flaming.

X1.5.3 The 50 % weight loss limitation (8.2.3) is provided to preclude the possibility that combustion of low density materials will occur so rapidly that the recorded temperature rise and the measured flaming duration will be less than the prescribed limits. The choice of 50 % was considered desirable for materials that contain appreciable quantities of combined water (or gaseous components).

X1.5.4 It appears that the scope limitations to elementary materials (through the 1973 edition) and the exclusion of laminated and coated materials reflected the uncertainties associated with more complex materials and with products that could not be tested in a realistic configuration.

X1.6 Precision, Bias, and Sensitivity

X1.6.1 This test method does not contain a numeric precision and bias statement because the reported results are recorded as pass or fail.

X1.6.2 There have been attempts to determine precision and bias for this method. Two series of interlaboratory tests have been conducted in accordance with previous versions of this test method. In 1947, twelve years prior to the initial adoption of Test Method E136, a total of 47 solid materials were provided for testing by seven laboratories, but no summary report or conclusions on interlaboratory reproducibility appear to have been developed.

X1.6.3 In 1963, several laboratories participated in a limited round robin involving 13 materials and two test methods, E136 – 73 and ISO R 1182. Results from three laboratories that provided data for Test Method E136 were compared in terms of the surface temperature rise and in terms of the classification of combustible or noncombustible (12). The variation in peak surface temperature rise typically ranged from 15 to 20°C (27 to 36°F) for temperature rises near the limiting value, for example, $30 \pm 20^\circ\text{C}$ ($54 \pm 36^\circ\text{F}$) rise. In terms of classification, the three laboratories agreed on a noncombustible classification for four materials and on a combustible classification for eight materials (although not necessarily by the same criteria). One material was classified combustible by one laboratory and noncombustible by two laboratories. However, agreement would probably have been attained if the tests had not been terminated prematurely. No known sensitivity studies have been conducted on Test Method E136, although one laboratory did perform a sensitivity study in 1973 on ISO R 1182 and concluded that the peak surface temperature rise was not sensitive to the prescribed change in furnace

temperature level 730°C versus 750°C or in specimen location (mid-height of furnace versus 20 mm ($\frac{3}{4}$ in.) below mid-height).

X1.7 Recent Considerations

X1.7.1 In addition to the inclusion of the weight loss limitation, the 1973 edition of the test method also included the response characteristics of the measuring thermocouples T_3 and T_4 in terms of a specified time constant. The mandatory caveat established by the ASTM Board of Directors was added editorially in July 1974. During the last few years, there was some support for eliminating the pass-fail feature of the test on the basis that the selection of limit values was arbitrary and that these should properly be set by the building officials using the test method. While physical, thermal, and flammability properties are commonly included in specifications, such endpoints are not normally included in ASTM test methods, except as a means for separating materials into classes or types. However it was also held that the inclusion of a single set of commonly accepted limit values would avoid a possible proliferation of endpoints in different codes and standards.

X1.7.2 A change that has generated controversy is the elimination of the previous restriction to elementary materials and the retention of the exclusion of laminated and coated materials. At the present time, a task group is considering an alternative method of testing laminated and coated materials.

X1.7.2.1 The major changes from E136 – 73 to E136 – 79 are (a) change in title; (b) removal of elementary from the scope; (c) addition of Significance and Use section; and (d) replacement of the Interpretation of Results section containing the phrase “. . . shall be reported as noncombustible if . . .” with a Report section containing the phrase “Report the material as passing the test if . . .” (13).

X1.7.3 During the December 1979 meeting of Committee E05, a question was raised about the length of the ceramic tubes in the Test Method E136 furnace specified to be 254 mm (10 in.) long (outside cover 273 mm ($10\frac{3}{4}$ in.)). A survey was made of Committee E05 members in January 1980 concerning experience with and impact of size of tube on test results. A successful ballot to revise the size of the refractory tubes was accepted at the December 1980 meeting of the committee. The revision is as currently stated in 6.1.1.

X1.7.4 In 1980 a proposal was made to substitute the furnace employed in ISO 1182 for the furnace used in Test Method E136 but to retain all other details of the test method. This proposal was not accepted.

X1.7.5 Additional information can provide comparisons of Test Method E136, ISO 1182, and the IMCO (modified ISO) test methods (14-20). Questions concerning Test Method E136 should be addressed to Subcommittee E05.23 of Committee E05 on Fire Standards.

X1.7.6 In 1992, Subcommittee E05.23 approved an addition to this test method in order to provide a value for the volume air flow rate through the test furnace, in addition to the linear air flow rate that had been listed since the creation of the standard. The volume flow, which is derived from the linear flow, is the value actually used to monitor the air flow rate

during testing. The value for volume flow rate in the 1993 and 1994 versions of this test method was incorrect. This value assumed that the linear flow rate (3.0 m/min) was at room temperature (approximately 21°C), rather than at the elevated furnace temperature 750°C. The difference in the two calculations for the volume flow rate is approximately a factor of three (correct calculation, 0.00267 m³/min; incorrect calculation, 0.00927 m³/min). It was not the intent of the task group or subcommittee to change the test method, which was based on linear air flow rate.

X1.8 Optional Thermocouples in Test Method E2652

X1.8.1 Test Method E2652 does not require the use of the test specimen center thermocouple or of the test specimen surface thermocouple; they are optional. However, measurements using these thermocouples are required in Section 15 of Test Method E136.

X1.8.2 The apparatus used for Option B of Test Method E136 is the apparatus of Test Method E2652.

X1.8.3 Therefore, Section 10.2 of Test Method E136 and Section 6.4.8 of Test Method E2652 explain that when the apparatus of Test Method E2652 is used to assess the behavior of building materials in accordance with Test Method E136, measurements need to be made using both of the optional thermocouples specified in Sections 6.4.6 (test specimen center thermocouple) and 6.4.7 (test specimen surface thermocouple) of Test Method E2652. The sections also explain that the values of these measurements must be reported as required in Section 15 of Test Method E136.

REFERENCES

- (1) "Definition of Noncombustible Building Construction Material," *Special Interest Bulletin No. 294*, revised August 1967, American Insurance Assn., New York, NY.
- (2) "Life Safety Code," *NFPA 101*, National Fire Protection Assn., Quincy, MA 1976.
- (3) Eickner, H. W., "Fire Research at the U.S. Forest Products Laboratory," Approved Technical Article, *Fire Research Abs. and Rev.*, National Academy of Science and National Research Council, Vol 6, No. 1, 1964 Washington, D.C.
- (4) Prince, R. E., "Tests on the Inflammability of Untreated Wood and Wood Treated with Fire-Retarding Compounds," *NFPA Proceedings*, 1915, pp. 108–112.
- (5) Setchkin, N. P. and Ingberg, S. H., "Test Criterion for an Incombustible Material," *Proceedings of the American Society for Testing Materials*, Philadelphia, PA, Vol 45, 1945.
- (6) Ingberg, S. H., Notes on E136 – 59 T and Requirements for Incombustibility, 11 pp. Minutes of ASTM Committee E-5, October 13, 1964 and January 15, 1965 (copy at ASTM Headquarters).
- (7) Setchkin, N. P., "A Method and Apparatus for Determining the Ignition Characteristics of Plastics," *Research Paper RP 2052, Journal of Research*, National Bureau of Standards Vol 43, December 1949, pp. 591–608.
- (8) Sumi, K., *Comparison of Combustibility Test Procedures*, Report No. 43, Division of Building Research, National Research Council of Canada, Ottawa, Ont., July 1955.
- (9) Setchkin, N. P., *Combustibility Tests of 47 ASTM Material Samples* National Bureau of Standards (NBS) Project 1002-43-1029, Report No. 1454, Feb. 6, 1952, Washington, D.C.
- (10) "Proposed Method of Test for Defining Noncombustibility of Building Materials," *ASTM Bulletin*, February 1957. pp. 33–34.
- (11) Yuill, C. H., "Fire Terms and Fire Tests," *Materials Research and Standards*, Vol 10, No. 10. American Society for Testing and Materials, 1970, pp. 24–26.
- (12) Gross, D., Lindauer, R. A., and Willard, R., "Evaluation of Two Test Methods for Noncombustibility: ASTM E136 and ISO R1182," Unpublished NBS Report, 1973.
- (13) Explanation accompanying ballot on ASTM Test Method E136, Item 4, January 1978.
- (14) Loftus, J. J., "Noncombustibility of Mineral Wood and Glass Fiber Insulation Materials," *NBS Report 9988*, Feb. 3, 1969.
- (15) Benjamin, I. A., "ISO Noncombustibility Furnace," *NBS Report 10330*, Aug. 28, 1970.
- (16) Gross, D. and Benjamin, I. A., "Evaluation of ISO Furnace Test for Noncombustibility," Unpublished NBS Report, March 15, 1971.
- (17) McDaniel, D. E., "Noncombustibility: A Marine View," *Ignition, Heat Release, and Noncombustibility of Materials*, ASTM STP 502, Am. Soc. Testing Mats., 1971.
- (18) Herpol, G. A., "Noncombustibility—Its Definition, Measurement, and Applications," *Ignition, Heat Release, and Noncombustibility of Materials*, STP 502, Am. Soc. Testing Mats., 1971.
- (19) Loftus, J. J. and Robertson, A. F., *Experiments with A Proposed Test Procedure for Noncombustible Materials*, NBS Report 9529, May 4, 1967.
- (20) *Report of Test on Five Asbestos Type Insulation Boards for United States Coast Guard—Report No. TG10210-2183: FR 3720*. U.S. National Bureau of Standards.

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; http://www.copyright.com/