



Standard Guide for Evaluating Performance of On-Site Extraction and Field- Portable Electrochemical or Spectrophotometric Analysis for Lead¹

This standard is issued under the fixed designation E1775; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This standard provides guidelines for determining the performance of field-portable quantitative lead analysis instruments.

1.2 This guide applies to field-portable electroanalytical and spectrophotometric (including reflectance and colorimetric) analyzers.

1.3 Sample matrices of concern herein include paint, dust, soil, and airborne particles.

1.4 This guide addresses the desired performance characteristics of field-based sample extraction procedures for lead, as well as on-site extraction followed by field-portable analysis.

1.5 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 ASTM Standards:²

D5438 Practice for Collection of Floor Dust for Chemical Analysis

D6785 Test Method for Determination of Lead in Workplace Air Using Flame or Graphite Furnace Atomic Absorption Spectrometry

D6966 Practice for Collection of Settled Dust Samples Using Wipe Sampling Methods for Subsequent Determination of Metals

D7035 Test Method for Determination of Metals and Metalloids in Airborne Particulate Matter by Inductively

Coupled Plasma Atomic Emission Spectrometry (ICP-AES)

D7144 Practice for Collection of Surface Dust by Microvacuum Sampling for Subsequent Metals Determination

E1605 Terminology Relating to Lead in Buildings

E1613 Test Method for Determination of Lead by Inductively Coupled Plasma Atomic Emission Spectrometry (ICP-AES), Flame Atomic Absorption Spectrometry (FAAS), or Graphite Furnace Atomic Absorption Spectrometry (GFAAS) Techniques

E1644 Practice for Hot Plate Digestion of Dust Wipe Samples for the Determination of Lead

E1645 Practice for Preparation of Dried Paint Samples by Hotplate or Microwave Digestion for Subsequent Lead Analysis

E1726 Practice for Preparation of Soil Samples by Hotplate Digestion for Subsequent Lead Analysis

E1727 Practice for Field Collection of Soil Samples for Subsequent Lead Determination

E1729 Practice for Field Collection of Dried Paint Samples for Subsequent Lead Determination

E1792 Specification for Wipe Sampling Materials for Lead in Surface Dust

E1864 Practice for Evaluating Quality Systems of Organizations Conducting Facility and Hazard Assessments for Lead in Paint, Dust, Airborne Particulate, and Soil in and around Buildings and Related Structures (Withdrawn 2011)³

2.2 U.S. EPA Documents:⁴

EPA 600/R-93/200 Standard Operating Procedure for the Field Analysis of Lead in Paint, Bulk Dust, and Soil by Ultrasonic, Acid Digestion and Colorimetric Measurement (1993)

EPA 747-R-92-001 Laboratory Accreditation Guidelines: Measurement of Lead in Paint, Dust, and Soil (1992)

¹ This guide is under the jurisdiction of ASTM Committee E06 on Performance of Buildings and is the direct responsibility of Subcommittee E06.23 on Lead Hazards Associated with Buildings.

Current edition approved Aug. 1, 2007. Published August 2007. Originally approved in 1996. Last previous edition approved in 2001 as E1775 – 01. DOI: 10.1520/E1775-07.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ The last approved version of this historical standard is referenced on www.astm.org.

⁴ Available from United States Environmental Protection Agency (EPA), Ariel Rios Bldg., 1200 Pennsylvania Ave., NW, Washington, DC 20460, <http://www.epa.gov>.

3. Terminology

3.1 For definitions of terms not listed here, see Terminology E1605.

3.2 *anodic stripping voltammetry*—an electroanalytical technique in which the concentration of analyte metal species dissolved in solution is determined in the following manner: The analyte is first deposited (preconcentrated) electrochemically by reducing the dissolved ion in solution to immobilized metal species at an electrode surface (such as mercury or bismuth). The metal is deposited at an applied potential (voltage) which is negative of the standard oxidation potential for the metal/ion redox couple. After deposition, the preconcentrated metal species is then stripped from the electrode by applying a positive potential sweep, which causes anodic oxidation of the analyte metal species to dissolved ion. The current associated with this reoxidation is measured. The peak current is proportional to the original concentration of dissolved analyte species over a wide range of concentrations.

3.3 *colorimetry*—an analytical technique that is similar to spectrophotometry (see 3.5), except that ultraviolet-visible light of a single, narrow wavelength range is passed through a sample cell containing dissolved analyte, and the absorption measured.

3.4 *reflectance*—a measurement technique (subset of spectrophotometry; see 3.5) in which light is reflected off of a reflecting surface and measured by a detector. The amount of reflected light may be a function of analyte concentration.

3.5 *spectrophotometry*—an analytical technique in which a spectrum of analyte species is obtained and used to determine the analyte concentration in the following manner. Light is directed onto or through analyte species, and the absorption of this light across a range of wavelengths is measured by a detector. The amount of absorbed light is a function of the concentration of analyte species.

4. Significance and Use

4.1 This guide is intended for use in evaluating the performance of field-portable electroanalytical or spectrophotometric devices for lead determination, or both.

4.2 Desired performance criteria for field-based extraction procedures are provided.

4.3 Performance parameters of concern may be determined using protocols that are referenced in this guide.

4.4 Example reference materials to be used in assessing the performance of field-portable lead analyzers are listed.

4.5 Exhaustive details regarding quality assurance issues are outside the scope of this guide. Applicable quality assurance aspects are dealt with extensively in references that are cited in this guide.

5. Performance Evaluation Materials

5.1 *Certified Reference Materials (CRMs)*—These may consist of NIST Standard Reference Materials (SRMs) and are also known as Primary and Secondary Reference Materials:

5.1.1 *Paint*—Examples are NIST paint SRMs, for example, NIST SRMs 2582, 2583, and numerous other CRMs.

5.1.2 *Dust*—Examples are NIST 1648 (urban particulate matter), other NIST dust SRMs, and other CRMs.

5.1.3 *Soil*—Examples are NIST 2704 (river sediment) and NIST soil standards: SRMs 2709, 2710, and 2711 and numerous other CRMs.

5.1.4 *Airborne Particulate Matter*—An example is NIST SRM 2783, which is available for airborne particulate matter collected on filters. Other CRMs are also available.

5.2 Real-World Materials:

5.2.1 *Paint*, collected using Practice E1729 (or equivalent). To obtain reference values, determine lead concentration using Test Method E1613 and Practice E1645 (or equivalent).

5.2.2 *Dust Wipes*, collected using Practice D6966, with wipes meeting the requirements of Specification E1792. To obtain reference values, determine lead concentration using Test Method E1613 and Practice E1644 (or equivalent).

5.2.3 *Vacuumed Dust*, collected using Practices D7144 or D5438. To obtain reference values, determine lead concentration using Test Method E1613 and Practice E1726 (or equivalent).

5.2.4 *Soil*, collected using Practice E1727. To obtain reference values, determine lead concentration using Test Method E1613 and Practice E1726 (or equivalent).

5.2.5 *Airborne Particulate Matter*, collected using Test Method D6785 (or equivalent). To obtain reference values, determine lead concentration using Test Method E1613 and either Test Methods D6785 or D7035 (or equivalent).

5.3 *Secondary Reference Materials*—Examples of these CRMs include samples from the Environmental Lead Proficiency Analytical Testing (ELPAT) program (paints, dusts spiked on wipes, and soils) and the Proficiency Analytical Testing (PAT) program (air filters).⁵ Other examples include secondary reference materials (for example, bag house dust, sludge, and solid waste).⁶

5.3.1 *Paint*—Examples include ELPAT paint samples.

5.3.2 *Dust*—Examples include ELPAT wipe samples spiked with lead-containing dusts.

5.3.3 *Soil*—Examples include ELPAT soil samples.

5.3.4 *Air Filters*—Examples include PAT air filter samples.

6. Performance Criteria

6.1 *Extraction Procedures*—The extraction procedure chosen shall have a demonstrated recovery of at least 80 % for the matrix of concern, and shall be compatible with the lead analysis technique used (EPA 600/R-93/200). (Reference extraction and analytical techniques include those ASTM standards listed in 2.1.)

6.2 Field-Portable Analysis:

6.2.1 *Accuracy*—Overall measurement accuracy of the field-portable analytical technique following field-based extraction: within 25 % of the values obtained by the applicable ASTM extraction procedure (see 2.1) and Test Method E1613.

⁵ Available from the American Industrial Hygiene Association (AIHA), 2700 Prosperity Ave., Suite 250, Fairfax, VA 22031

⁶ Available from Fisher Scientific and Resource Technology Corp., Laramie, WY.

6.2.2 *Precision*—For field-based extraction followed by field-portable analysis, total uncertainties for standard reference materials: 25 % relative standard deviation (RSD) (EPA 747-R-92-001); for real-world materials: 25 % RSD (EPA 747-R-92-001); for secondary reference materials: 25 % RSD.

6.2.3 *Working Range*—Minimum working concentration range for the overall method shall extend from 0.1 times the applicable action level to 2 times the applicable action level (NIOSH SOP 018)⁷ for the sample matrix of concern.

6.3 *Sample Size*—Follow applicable ASTM sample collection and sample preparation practices listed in 2.1.

NOTE 1—Performance data from interlaboratory testing of a portable anodic stripping voltammetric procedure have been published⁸

⁷ National Institute for Occupational Safety and Health (NIOSH), “Guidelines for Air Sampling and Analysis,” available from NIOSH Publications, 4676 Columbia Parkway, Cincinnati, OH 45226, www.cdc.gov/niosh.

⁸ Ashley, K., Song, R., Esche, C.A., Schlecht, P. C., Baron, P.A., and Wise, T.J., “Ultrasonic extraction and portable anodic stripping volumetric measurement of lead in paint, dust wipes, soil, and air—An interlaboratory evaluation. *Journal of Environmental Monitoring*, Vol. 1, pp. 459–464 (1999).

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the ASTM website (www.astm.org/COPYRIGHT/).

7. Quality Assurance (QA) and Quality Control (QC)

7.1 *Field and Laboratory QA/QC*—Follow QA/QC procedures delineated in the applicable ASTM sample preparation practices for the pertinent sample matrix (2.1) and in Test Method E1613.

7.2 *QA System*—Follow the requirements delineated in Practice E1864.

NOTE 2—Participation in proficiency testing programs, for example, ELPAT and other similar round robin schemes, is recommended.

8. Keywords

8.1 electroanalysis; extraction; lead; portable analysis; spectrophotometry