



Standard Specification for Wrought Seamless and Welded and Drawn Cobalt Alloy Small Diameter Tubing for Surgical Implants (UNS R30003, UNS R30008, UNS R30035, UNS R30605, and UNS R31537)¹

This standard is issued under the fixed designation F2527; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

1. Scope*

1.1 This specification covers the requirements for wrought seamless and welded and drawn cobalt alloy small diameter tubing used for the manufacture of surgical implants. Material shall conform to the applicable requirements of Specifications **F90**, **F562**, **F688**, **F1058** or **F1537**, Alloy 1. This specification addresses those product variables that differentiate small diameter medical tubing from the bar, wire, sheet and strip product forms covered in these specifications.

1.2 This specification applies to straight length tubing with 6.3 mm [0.250 in.] and smaller nominal outside diameter (OD) and 0.76 mm [0.030 in.] and thinner nominal wall thickness.

1.3 The specifications in **2.1** are referred to as the ASTM material standard(s) in this specification.

1.4 The values stated in either SI units or inch-pound units are to be regarded separately as standard. The values stated in each system may not be exact equivalents; therefore, each system shall be used independently of the other. Combining values from the two systems may result in non-conformance with the standard.

2. Referenced Documents

2.1 ASTM Material Standards:²

F90 Specification for Wrought Cobalt-20Chromium-15Tungsten-10Nickel Alloy for Surgical Implant Applications (UNS R30605)

F562 Specification for Wrought 35Cobalt-35Nickel-20Chromium-10Molybdenum Alloy for Surgical Implant Applications (UNS R30035)

F1058 Specification for Wrought 40Cobalt-20Chromium-16Iron-15Nickel-7Molybdenum Alloy Wire and Strip for Surgical Implant Applications (UNS R30003 and UNS R30008)

F1537 Specification for Wrought Cobalt-28Chromium-6Molybdenum Alloys for Surgical Implants (UNS R31537, UNS R31538, and UNS R31539)

2.2 ASTM Standards:

E8 Test Methods for Tension Testing of Metallic Materials
E29 Practice for Using Significant Digits in Test Data to Determine Conformance with Specifications

E112 Test Methods for Determining Average Grain Size
SI 10 American National Standard for Use of the International System of Units (SI): The Modern Metric System

2.3 ISO Standards:³

ISO 5832- 5 Implants for Surgery—Metallic Materials Part 5: Wrought Cobalt, Chromium, Tungsten, Nickel Alloy

ISO 5832- 6 Implants for Surgery—Metallic Materials Part 6: Wrought Cobalt, Nickel, Chromium, Molybdenum Alloy

ISO 5832- 7 Implants for Surgery—Metallic Materials Part 7: Wrought Cobalt, Chromium, Molybdenum Alloy

ISO 5832- 8 Implants for Surgery—Metallic Materials Part 8: Wrought Cobalt, Nickel, Chromium, Molybdenum, Tungsten, Iron Alloy

ISO 5832- 12 Implants for Surgery—Metallic Materials Part 12: Wrought Cobalt, Chromium, Molybdenum Alloy

ISO 6892 Metallic Materials—Tensile Testing

ISO 9001 Quality Management Systems—Requirements

2.4 ASME Standard:

ASME Y14.5.1M 1994 (R2004) Mathematical Definition of Dimensioning and Tolerancing Principles⁴

3. Terminology

3.1 Definitions of Terms Specific to This Standard:

¹ This specification is under the jurisdiction of ASTM Committee **F04** on Medical and Surgical Materials and Devices and is the direct responsibility of Subcommittee **F04.12** on Metallurgical Materials.

Current edition approved Dec. 1, 2010. Published January 2011. Originally approved in 2005. Last previous edition approved in 2005 as F2527 –05 ^{ε1}. DOI: 10.1520/F2527-10.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, <http://www.ansi.org>.

⁴ Available from American Society of Mechanical Engineers (ASME), ASME International Headquarters, Three Park Ave., New York, NY 10016-5990, <http://www.asme.org>.

3.1.1 *average wall thickness*—the arithmetic average of the minimum wall thickness and the maximum wall thickness measured on any one transverse cross section of the tube.

3.1.2 *individual wall thickness measurement*—Any one of the wall thickness measurements taken around the circumference on any one transverse cross section of a single sample of the tube.

3.1.3 *lot*—The total quantity of product produced from the same melt heat under the same conditions, at essentially the same time.

3.1.4 *lot average concentricity*—The arithmetic average of the sample concentricities measured on a statistically representative number of samples from the lot.

3.1.5 *lot average wall thickness*—The arithmetic average of the sample average wall thicknesses measured on a statistically representative number of samples from the lot.

3.1.6 *nominal outside diameter (OD)*—the outside diameter specified on the customer order or engineering drawing without regard to tolerance.

3.1.7 *nominal wall thickness*—the wall thickness specified on the customer order or engineering drawing without regard to tolerance.

3.1.8 *sample average wall thickness*—The arithmetic average of all individual wall thickness measurements measured on a single sample.

3.1.9 *sample concentricity*—two times the offset between the centers of two circles, representing the outside diameter (OD) and the inside diameter (ID) of the tube.

3.1.9.1 *Discussion*—For purposes of this specification, the minimum wall and the maximum wall measured on any one transverse cross section shall be used to calculate concentricity. The percent concentricity shall be calculated using the equation:

$$\text{Sample Concentricity Percent} = 2 \times \left(\frac{A - B}{A + B} \right) \times 100 \quad (1)$$

where:

A = sample maximum wall, and
B = sample minimum wall.

3.1.10 *sample maximum wall thickness*—The largest individual wall thickness measurement taken around the circumference on any one transverse cross section of a single sample of tube.

3.1.11 *sample minimum wall thickness*—The smallest individual wall thickness measurement taken around the circumference on any one transverse cross section of a single sample of tube.

3.1.12 *seamless tubing*—tubing made by a process in which the tube periphery is continuous at all stages of the process.

3.1.13 *welded and drawn tubing*—tubing fabricated from strip or sheet using welding, drawing, and annealing operations.

3.1.13.1 *Discussion*—Welding shall be performed using a liquid phase weld process with no filler metal. Typical weld processes are tungsten inert gas (TIG) and laser. The drawing

and annealing operations shall be performed in such a way that the weld bead and heat affected zone are virtually indistinguishable microstructurally and dimensionally from the parent metal when examined per 11.3.

4. General Requirements for Delivery

4.1 In addition to the requirements of this specification, all applicable requirements of the appropriate ASTM material standard shall apply.

5. Ordering Information

5.1 Inquiries and orders for material under this specification should include the following information:

- 5.1.1 Quantity (weight, total length, or number of pieces),
- 5.1.2 This ASTM specification and date of issue,
- 5.1.3 The appropriate ASTM material standard and date of issue,
- 5.1.4 Units to be certified—SI or inch-pound,
- 5.1.5 Method of manufacture (seamless or welded and drawn; see 6.1),
- 5.1.6 Condition (see 6.2),
- 5.1.7 Surface finish (see 6.3),
- 5.1.8 Applicable dimensions including OD and ID, OD and wall or ID and wall, length (exact, random, multiples) or engineering drawing reference number,
- 5.1.9 Dimensional tolerances (see Section 9 and Table 1),
- 5.1.10 Special requirements or supplementary requirements, if any, and
- 5.1.11 Certification requirements.

6. Materials and Manufacture

6.1 Method of Manufacture:

6.1.1 Seamless tubing shall be made from bar, hollow bar, rod, or hollow rod raw material forms that meet the chemical requirements of the appropriate material specification.

6.1.1.1 Seamless tubing shall be made by a process consistent with the definition in 3.1.12.

6.1.2 Welded and drawn tubing shall be made from strip or sheet raw material forms that meet the chemical requirements of the appropriate material specification.

6.1.2.1 Welded and drawn tubing shall be made by a process consistent with the definition in 3.1.13.

6.2 *Condition*—Tubing shall be furnished, as specified, in the annealed, solution annealed, warm worked or cold worked and aged condition as defined in the appropriate ASTM material standard.

6.3 Surface Finish:

TABLE 1 Permissible Variation in OD and ID Dimensions

Nominal OD or ID mm [in.]	Permissible Variation from Nominal ^A mm [in.]
Less than 1.54 [0.060]	±0.013 [0.0005]
1.54 to 6.30 [0.060 to 0.250] incl.	±0.025 [0.001]

^A Unless otherwise specified, size tolerances are plus and minus as shown in the table. When required by the purchaser, tolerances may be specified all plus and nothing minus, or all minus and nothing plus, or any combination of plus and minus if the total range of size tolerance is not less than the total range shown in the table.

6.3.1 The tubing outer surface shall be furnished with a cold-drawn, bright annealed, ground or polished finish. Outer surface roughness shall be a maximum of 0.6 μm [25 $\mu\text{in.}$] Ra.

6.3.2 The tubing inner surface shall be furnished with an as-drawn finish, bright annealed or conditioned finish. Inner surface roughness shall be a maximum of 0.8 μm [30 $\mu\text{in.}$] Ra.

6.3.3 The method used to determine surface roughness shall be agreed upon between purchaser and supplier.

7. Chemical Composition

7.1 The heat analysis limits and product analysis tolerances of the appropriate ASTM material specification shall apply.

7.2 Alternative chemistries with more restrictive limits than those in the ASTM material specifications may be specified as agreed upon by purchaser and supplier.

8. Mechanical Properties

8.1 The required mechanical properties shall be selected from the tables for similar product forms in the appropriate material specification. Where bar or wire data is presented, the mechanical properties listed for bar or wire of similar OD size shall apply. Where sheet or strip data is presented, the mechanical properties for sheet or strip with thickness similar to the tubing wall thickness shall apply. Tensile testing shall be in accordance with Test Methods E8 using unmachined tubular specimens. Alternative mechanical properties may be agreed upon between purchaser and supplier.

8.2 If both tensile properties and hardness are specified on the purchase order, tensile properties shall be used to accept or reject. Hardness shall be reported for information only.

8.3 Elongation of bar and wire material 1.6 mm [0.063 in.] or greater in diameter (D) shall be measured using a gauge length of 50 mm [2 in.], or 4D. The gauge length must be reported with the test results. The method for determining elongation of material under 1.6 mm [0.063 in.] shall be agreed upon between purchaser and supplier. Alternatively, a gauge length corresponding to ISO 6892 (5.65 times the square root of S_o , where S_o is the original cross sectional area) may be used when agreed upon between purchaser and supplier.

8.4 Elongation for sheet and strip product shall be tested and reported as required in the appropriate material specification.

9. Dimensions and Permissible Variation

9.1 Units of Measure:

9.1.1 *Selection*—This specification requires that the purchaser selects the units of measure (SI or inch-pound) to be used for product certification. In the absence of a stated selection of units on the purchase order, this selection may be expressed by the purchaser in several alternate forms listed in order of precedence.

9.1.1.1 If the purchaser and supplier have a history of using specific units, these units shall continue to be certified until expressly changed by the purchaser.

9.1.1.2 In the absence of historic precedence, if the units used to define the product on the purchaser's PO, specification, and engineering drawing are consistent, these units shall be used by the supplier for product certification.

9.1.1.3 If the purchaser's selection of units is unclear, the units of measure shall be agreed upon between purchaser and supplier.

9.1.2 *Conversion of Units*—If the supplier's test equipment does not report in the selected units, the test equipment units may be converted to the selected units for certification purposes. Accurate arithmetic conversion and proper use of significant digits should be observed when performing this conversion. ASTM SI 10 provides guidelines for the use of SI units. Annex A provides conversion tables and Annex B provides rules for conversion and significant digits.

9.2 Permissible Variation in Dimensions:

9.2.1 *OD and ID*—Permissible variations of OD and ID from the nominal dimension on the purchase order or engineering drawing are listed in Table 1.

9.2.2 OD may be measured by hand micrometer, by linear variable displacement transducer (LVDT), by laser micrometer or by other non-contact method.

9.3 Wall Thickness:

9.3.1 For wall thickness of 0.10 mm [0.004 in.] or greater, the range of total wall variation (including concentricity and average wall variation) shall not exceed 14 % (± 7 %) of nominal wall thickness. Tolerance for wall thickness less than 0.10 mm [0.004 in.] will be agreed upon between purchaser and supplier.

9.3.2 For wall thickness of 0.10 mm [0.004 in.] or greater, concentricity shall not exceed 10 % (± 5 %) of average wall thickness for tubing with nominal wall thickness greater than or equal to 10 % of the nominal OD dimension. For tubing with nominal wall thickness less than 0.10 mm [0.004 in.] or 10 % of the nominal OD dimension, concentricity shall be agreed upon between purchaser and supplier.

9.3.3 Wall thickness measurement shall be made directly with a hand micrometer, LVDT, CMM, by optical measurement on a transverse metallographic cross section, or by some other appropriate method. The method of wall thickness measurement shall be agreed upon between purchaser and supplier.

9.4 Length:

9.4.1 For exact length orders, length variation on all lengths up to and including 7.3 m [24 ft] shall be plus or minus 3 mm [0.125 in.].

9.4.2 For random length orders, a maximum and minimum length shall be specified by the purchaser. Up to 5 % of the order may ship short of the minimum length specified. No length shall be less than 0.6 m [2 ft], unless permitted by the purchaser.

9.5 *Straightness*—The deviation from straightness shall not exceed 0.30 mm per 300 mm [0.012 in. per foot] of tube length. The method of measuring straightness shall be negotiated between purchaser and supplier. Alternative requirements may be agreed upon between purchaser and supplier.

10. Permissible Outer and Inner Surface Imperfections

10.1 Outer surface imperfection shall not exceed 10 % of wall thickness in depth. Outer surface imperfections may be removed by grinding or polishing prior to shipment, providing

that the resultant wall thickness meets the minimum wall thickness, and that the ground or polished surface meets the surface finish requirements of 6.3.1.

10.2 Inner surface imperfections shall not exceed 10 % of wall thickness in depth.

10.3 The method of inspecting for these imperfections shall be agreed upon between the purchaser and supplier.

11. Special Tests

11.1 The material shall conform to the special test requirements of the appropriate ASTM material specification listed in 2.1. Ultrasonic inspection will be limited to wall thickness of 0.5 mm [0.020 in.] or thicker.

11.2 The grain size shall be ASTM 6 or finer when evaluated after the final annealing operation in accordance with Test Method E112. In addition, on any one of the transverse metallographic sections examined, there must be a minimum of three grains intercepted by any radial line drawn across the wall thickness. The number of grains required for wall thickness less than 0.1 mm [0.004 in.] shall be agreed upon between purchaser and supplier.

11.2.1 If samples are selected after a final cold working operation, specimens shall be tested in accordance with Test Method E112 or as agreed upon between purchaser and supplier.

11.3 For welded and drawn tubing, a transverse cross-section through the weld bead shall be metallographically mounted, polished, etched, and viewed at 100 times magnification. The microstructures of the weld bead and heat affected zone will exhibit a grain size and grain morphology similar to the parent metal. The ASTM grain size in the weld bead, heat affected zone and parent metal will not differ by more than 1 ASTM number. The wall thickness at the weld bead shall be the same as the parent metal.

11.4 The raw material supplier will rate non metallic inclusion content per Test Methods E45, Method A except using plate I-r on material with a diameter or shortest dimension of 7.6 mm [3.0 in.] or larger. The rating will meet the non metallic inclusion requirements listed in Table 2.

11.4.1 If the non metallic inclusion requirement for a particular type and heaviness in the appropriate ASTM material spec is more restrictive than that in Table 2, the non metallic

TABLE 2 Maximum Allowable Inclusion Rating

NOTE 1—The inclusion type description in parentheses is not intended to represent the chemistry of the rated inclusion. The inclusion type will be determined by choosing the inclusion morphology on chart 1-r that most closely matches the rated inclusion.

Inclusion Type	A (Sulfides)	B (Alumina)	C (Silicate)	D (Globular Oxide)
Thin	1.5	1.5	1.5	1.5
Heavy	1.0	1.0	1.0	1.0

inclusion requirements in the appropriate ASTM material specification shall apply.

11.4.2 Alternative methods of rating and reporting non metallic inclusions on tubing at finish size may be agreed upon between purchaser and supplier.

12. Significance of Numerical Limits

12.1 The following applies to all specified numerical limits in this specification. To determine conformance to these limits, an observed or calculated value shall be rounded to the nearest unit in the last right hand digit used in expressing the specification limit, in accordance with the Rounding Method of Practice E29.

13. Certification

13.1 The supplier shall provide certification that the material meets the requirements of this specification. Certification of raw material compliance to chemistry and non metallic inclusion requirements may be provided as evidence of compliance of finished tube to this requirement. A report of the test results shall be furnished at the time of shipment.

13.2 The method of manufacture (seamless or welded and drawn) shall be stated on the certification.

14. Quality Program Requirements

14.1 The supplier shall maintain a quality program such as defined in ISO 9001 or similar quality program.

14.2 The purchaser may audit the producer's quality program for conformance to the intent of ISO 9001 or other recognized quality programs.

15. Keywords

15.1 cobalt alloy; small diameter, metals (for surgical implant); surgical applications, tubing; surgical implants; tubing

SUPPLEMENTARY REQUIREMENTS

The following supplementary requirements will apply only when specified by the purchaser in the inquiry, contract, or order.

S1. Inside Surface Cleanliness

S1.1 Tubing with ID size of greater than or equal to 1.5 mm [0.060 in.] shall meet the requirements of Specification A632, Supplement 3 for cleanliness. The method for inspecting inside

surface cleanliness for smaller ID sizes shall be agreed upon between purchaser and supplier.

APPENDIXES

(Nonmandatory Information)

X1. RATIONALE

X1.1 The primary reason for this specification is to establish a tubular product standard for cobalt alloy tubing used in fabricated stents and other small diameter implantable devices.

X1.2 ISO Standards are listed for reference only. Although the ISO 5832-5, ISO 5832-6, ISO 5832-7, ISO 5832-8, and ISO 5832-12 standards listed in section 2.3 are similar respectively to the Specifications F90, F562, F1058, and F1537 standards listed in section 2.1, they are not identical. Use of the ISO standard instead of the preferred ASTM standards may be agreed upon between the purchaser and supplier.

X1.3 When measuring wall thickness, tubing to be measured shall be sufficiently prepared to eliminate any burr or other material that shall interfere with accurate mechanical or optical measurement. This preparation can be done by end finishing procedures such as reaming and deburring, electrochemical machining (ECM) cutting or electrodischarge machining (EDM) wire cutting (for micrometer and LVDT measurement) or metallographic mounting, grinding and polishing (for optical measurement).

X1.3.1 Metallographic preparation for optical measurement must be performed in such a way as to maximize sample edge retention and minimize sample deviation from perpendicular.

X1.3.2 Micrometers used for wall measurement must have a pin diameter or effective anvil diameter less than the minimum tube ID size.

X1.3.3 LVDTs and coordinate measurement machines (CCMs) must have a precision consistent with the required wall thickness tolerance.

X1.4 *Precision and Bias*—The choice of wall thickness measurement technique is critical for tubing with very thin walls. Once a method is agreed upon between purchaser and supplier, the bias and precision of the method should be evaluated to insure the method is accurate and repeatable. In the absence of bias and precision data, no test method shall be used to reject tubing with measured wall thickness within 0.005 mm [0.0002 in.] of the specification limits.

X1.5 Percent concentricity as defined in 3.1.9 represents the full range of concentricity. This definition is consistent with the general definition of concentricity offered in ASME Y14.5.1M. It is preferred that purchasers specify this full range of concentricity with no $\pm$ modifier. For purposes of tolerancing, however, the percent concentricity may be divided by two and the resulting value may be used as a plus and minus tolerance which when applied to the nominal wall thickness shall define the allowable range of wall variation due to concentricity. In addition, the percent concentricity calculated using equation in

3.1.9 when divided by two may be added to and subtracted from the average wall thickness to express the actual range of wall variation due to concentricity.

X1.6 If OD, ID, and wall thickness are specified on the purchase order, the supplier and purchaser shall resolve which two of these shall apply.

X1.7 Concentricity may be used in conjunction with OD, ID, or wall tolerances to better define the allowable variation in wall thickness. For example, when a tube is specified as OD and ID, concentricity may be used to limit wall variation within the larger range allowed by a comparison of the upper and lower OD and ID tolerance limits. In this application, concentricity will not be interpreted as a wall thickness specification requiring resolution per section X1.6.

X1.8 Surface imperfections may be detected by a number of methods, including visual inspection. The suspect defect may be metallographically prepared and measured using a measuring reticule on a light microscope. This method is particularly suited for measuring long continuous imperfections such as “scratches” or “draw lines.” Other methods that may be used to evaluate surface imperfection depth include removal of some amount of material from the surface containing the imperfection (to see if the imperfection is still visible at a specified material removal), or use of a Z-axis measuring microscope to directly measure the depth. These same methods may be applied to ID defects by carefully splitting or exposing the tube ID for inspection using wire EDM, diamond saw, fine abrasive saw, laser cut, or grinding to remove some portion of the tube.

X1.9 *Units of Measure—ASTM Policy*—ASTM is promoting the use of rationalized SI (metric) units in their standards. The F04.12 sub committee has modified this specification to facilitate the transition by the medical materials industry to SI units between now and 2018. In the first phase of this transition, running to 2013, the specifications will be structured to allow the use of either SI or inch-pound units. The choice of primary units in each specification will be determined by the industry using the specification. The change to SI units during this period may be initiated by the purchaser through his purchase documentation. In the second phase of this transition the specifications will be written with SI units as the primary units. Harmonization with corresponding ISO documents will be considered when assigning the SI values.

X1.10 *Lot Definition*—The definition of lot in 3.1.3 includes the conversion from solid billet or bar by extrusion, gundrilling, or other method.

X2. BIOCOMPATIBILITY

X2.1 Biocompatibility is addressed in the appropriate ASTM material standards.

SUMMARY OF CHANGES

Committee F04 has identified the location of selected changes to this standard since the last issue (F2527 – 05^{e1}) that may impact the use of this standard. (Approved Dec. 1, 2010.)

- | | |
|--|--|
| <ul style="list-style-type: none">(1) Changed primary units from inch-pounds to SI.(2) Added wording to subsections 1.4, 5.1, 9.1, and X1.9 to support certifying in SI units.(3) Added reference to ASTM SI 10 for use of SI units.(4) Added Section 12 for the significance of numerical limits.(5) Added reference to Practice E29.(6) Changed definitions and made numerous editorial changes to reflect the current language used in the more recent F04 tube specifications. | <ul style="list-style-type: none">(7) Editorial corrections have been made in order to meet terminology and formatting guidelines established for implant material standards within F04.12.(8) Deleted ASQ C1 quality system and reference. |
|--|--|

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; <http://www.copyright.com/>