



Standard Specification for Metric and Inch-sized Crosslinked Polyethylene (PEX) Pipe¹

This standard is issued under the fixed designation F2788/F2788M; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope*

1.1 This specification covers crosslinked polyethylene (PEX) pipe that is outside diameter controlled in metric pipe sizes 16 mm to 100 mm and inch pipe sizes 3 in. to 54 in., made in nominal pipe dimension ratios, and pressure rated for water at three temperatures (see [Appendix X1](#)). Included are requirements and test methods for material, workmanship, dimensions, burst pressure, hydrostatic sustained pressure, excessive temperature-pressure, environmental stress cracking, stabilizer functionality, bent-pipe hydrostatic pressure, oxidative stability in potable chlorinated water, and degree of crosslinking. Requirements for pipe markings are also given. The pipe covered by this specification is intended for buried pressure piping applications (such as, industrial and general-purpose pipelines, potable water pipelines, fire – extinguishing pipelines). This specification also includes carbon black requirements for PEX pipe used for aboveground pressure piping applications.

1.2 The text of this specification references notes, footnotes, and appendixes, which provide explanatory material. These notes and footnotes (excluding those in tables and figures) shall not be considered as requirements of the specification.

1.3 The values stated in either SI units or inch-pound units are to be regarded separately as standard. The values stated in each system may not be exact equivalents; therefore, each system shall be used independently of the other. Combining values from the two systems may result in non-conformance with the standard.

NOTE 1—Metric sized (SI units) pipe should only be joined with corresponding metric-sized fittings and inch-sized pipe should only be joined with corresponding inch-sized fittings. Inch sized fittings should not be used for metric sized pipe, and metric sized fittings should not be used for inch-sized pipe.

¹ This specification is under the jurisdiction of ASTM Committee F17 on Plastic Piping Systems and is the direct responsibility of Subcommittee F17.26 on Olefin Based Pipe.

Current edition approved Nov. 1, 2013. Published December 2013. Originally approved in 2009. Last previous edition approved in 2011 as F2788–11. DOI: 10.1520/F2788_F2788M-13.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 ASTM Standards:²

- D618 Practice for Conditioning Plastics for Testing
- D792 Test Methods for Density and Specific Gravity (Relative Density) of Plastics by Displacement
- D1505 Test Method for Density of Plastics by the Density-Gradient Technique
- D1598 Test Method for Time-to-Failure of Plastic Pipe Under Constant Internal Pressure
- D1599 Test Method for Resistance to Short-Time Hydraulic Pressure of Plastic Pipe, Tubing, and Fittings
- D1600 Terminology for Abbreviated Terms Relating to Plastics
- D1898 Practice for Sampling of Plastics (Withdrawn 1998)³
- D2122 Test Method for Determining Dimensions of Thermoplastic Pipe and Fittings
- D2765 Test Methods for Determination of Gel Content and Swell Ratio of Crosslinked Ethylene Plastics
- D2837 Test Method for Obtaining Hydrostatic Design Basis for Thermoplastic Pipe Materials or Pressure Design Basis for Thermoplastic Pipe Products
- D3895 Test Method for Oxidative-Induction Time of Polyolefins by Differential Scanning Calorimetry
- F412 Terminology Relating to Plastic Piping Systems
- F2023 Test Method for Evaluating the Oxidative Resistance of Crosslinked Polyethylene (PEX) Tubing and Systems to Hot Chlorinated Water

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ The last approved version of this historical standard is referenced on www.astm.org.

2.2 *ANSI Standard*.⁴

B36.10 Standards Dimensions of Steel Pipe (IPS)

2.3 *Federal Standard*.⁵

FED-STD-123 Marking for Shipment (Civil Agencies)

2.4 *Military Standard*.⁵

MIL-STD-129 Marking for Shipment and Storage

2.5 *NSF Standard*.⁶

NSF/ANSI 14 for Plastic Piping Components and Related Materials

2.6 *ISO Standards*.⁷

ISO 1167 Thermoplastics pipes, fittings and assemblies for the conveyance of fluids — Determination of the resistance to internal pressure — Part 1: General method

ISO 4427 Plastic piping systems - Polyethylene (PE) pipes and fittings for water supply

ISO 13760 Plastics pipes for the conveyance of fluids under pressure — Miner's rule ~ Calculation method for cumulative damage

ISO R 161-1690 Pipes of Plastic Materials for the Transport of Fluids (Outside Diameters and Nominal Pressures) Part 1, Metric Series

2.7 *PPI Standards*.⁸

PPI TR-3 Policies and Procedures for Developing Hydrostatic Design Basis (HDB), Pressure Design Basis (PDB), Strength Design Basis (SDB), and Minimum Required Strength (MRS) Ratings for Thermoplastic Piping Materials or Pipe

PPI TR-4 PPI Listing of Hydrostatic Design Basis (HDB), Strength Design Basis (SDB), Pressure Design Basis (PDB) and Minimum Required Strength (MRS) Ratings for Thermoplastic Piping Materials or Pipe

3. Terminology

3.1 *Definitions*—Definitions are in accordance with Terminology **F412**, and abbreviations are in accordance with Terminology **D1600**, unless otherwise specified. The abbreviation for crosslinked polyethylene is PEX. Plastic pipe denotes a particular diameter schedule of plastic pipe in which outside diameter of the pipe conforms with ISO 4427.

3.2 *Definitions of Terms Specific to This Standard*:

3.2.1 *crosslinked polyethylene plastics*—plastics prepared by crosslinking (curing) polyethylene compounds.

3.2.2 *hydrostatic design stress (HDS)*—the estimated maximum tensile stress the material is capable of withstanding continuously with a high degree of certainty that failure of the pipe will not occur. This stress is circumferential when internal hydrostatic water pressure is applied. The HDS is equal to the

hydrostatic design basis (HDB) times the design factor (DF) for water. For this standard, the design factor is equal to 0.50.

$$HDS = HDB \times DF \quad (1)$$

$$= HDB \times 0.50 \text{ (for this standard)}$$

3.2.3 *hydrostatic design basis (HDB)*—one of a series of established stress values (specified in Test Method **D2837**) for a plastic compound obtained by categorizing the long-term hydrostatic strength determined in accordance with Test Method **D2837**.

3.2.3.1 *Discussion*—A listing of HDB and HDS values are contained in PPI publication PPI TR-4

3.2.4 *pressure rating (PR)*—the estimated maximum water pressure the pipe is capable of withstanding continuously with a high degree of certainty that failure of the pipe will not occur.

3.2.5 *relation between dimensions, hydrostatic design stress, and pressure rating*—the following expression, commonly known as the ISO equation⁹ is used in this specification to relate dimensions, hydrostatic design stress, and pressure rating:

$$2S/P = (D_o/t) - 1 \text{ or} \quad (2)$$

$$2S/P = R - I$$

S = hydrostatic design stress, psi (or MPa),

P = pressure rating, psi (or MPa),

D_o = average outside diameter, in. (or mm),

t = minimum wall thickness, in. (or mm), and

R = standard dimension ratio (SDR) or dimension ratio (DR)

3.2.6 *standard dimension ratio (SDR)/dimension ratio (DR)*—the ratio of outside diameter to wall thickness. For PEX-pipe, it is calculated by dividing the average outside diameter of the pipe by the minimum wall thickness. If the calculated dimension ratio is a Preferred Number Series R 10 modified by +1 (7, 9, 11 etc.), then it is called an SDR (standard dimension ratio); for all other numbers, it is called a DR.

3.2.7 *standard pipe material designation code*—The pipe material designation code shall consist of the abbreviation for the type of plastic (PEX) followed by four Arabic digits that describe short-term properties in accordance with applicable ASTM standards and as shown in **Table 1**.

3.2.7.1 *Discussion*—The first digit is for chlorine resistance tested in accordance with Test Method **F2023**.

(1) A digit “0” indicates that the PEX pipe either has not been tested for chlorine resistance or that the PEX pipe does not meet the minimum requirement for chlorine resistance.

(2) A digit “1” indicates the PEX pipe has been tested and meets the F XXXX requirement for minimum chlorine resistance at the end use condition of 25% at 140°F (60°C) and 75% at 73°F (23°C).

(3) A digit “2” is reserved for future application.

(4) A digit “3” indicates that the PEX pipe has been tested and meets the F XXXX requirement for minimum chlorine resistance at end use condition of 50% at 140°F and 50% at 73°F.

⁴ Available from American National Standards Institute (ANSI), 25 W. 43rd St., 4th Floor, New York, NY 10036, <http://www.ansi.org>.

⁵ Available from Standardization Documents Order Desk, DODSSP, Bldg. 4, Section D, 700 Robbins Ave., Philadelphia, PA 19111-5098, <http://www.dodssp.daps.mil>.

⁶ Available from NSF International, P.O. Box 130140, 789 N. Dixboro Rd., Ann Arbor, MI 48113-0140, <http://www.nsf.org>.

⁷ Available from International Organization for Standardization (ISO), 1, ch. de la Voie-Creuse, Case postale 56, CH-1211, Geneva 20, Switzerland, <http://www.iso.ch>.

⁸ Available from Plastics Pipe Institute (PPI), 105 Decker Court, Suite 825, Irving, TX 75062, <http://www.plasticpipe.org>.

⁹ ISO R161-1690.

TABLE 1 Material Designation Code Cells

Property	Standard	0	1	2	3	4	5	6	7	8	9
Chlorine Resistance	F2023	Not tested or rated	75 % at 73°F and 25 % at 140°F	Re-served	50 % at 73°F and 50 % at 140°F	Re-served	100 % at 140°F	...	...	...	...
Reserved	...	...	...	...	...	...	...	...	...	...	...
HDS for water at 73°F	...	...	...	...	...	...	...	630	...	800	...

(5) A digit “4” is reserved for future application.

(6) A digit “5” indicates that the PEX pipe has been tested and meets the requirement for minimum chlorine resistance at end use conditions of 100% of the time at 140°F.

3.2.7.2 *Discussion*—The second digit is a “0”. This digit is reserved for a currently unspecified PEX pipe property.

3.2.7.3 *Discussion*—The last two digits are the hydrostatic design stress for water at 73°F (23°C) in units of 100 psi with any decimal figures dropped. Where the hydrostatic design stress code contains less than two figures, a zero is used before the number. Thus, a complete material designation code for PEX pipe shall consist of the three letters “PEX” and four digits.

4. Pipe Classification

4.1 *General*—This specification covers one PEX pipe material having pressure ratings for water at three temperatures. The pressure ratings decrease as the temperature is increased.

4.2 *Standard Dimension Ratio (SDR)*—This specification covers PEX pipe in various standard dimension ratios and dimension ratios for nominal diameters 16 mm (1/2 in) and larger. The pressure ratings are uniform for all nominal pipe sizes with the same DR or SDR.

5. Materials

5.1 *General*—Crosslinked polyethylene pipe, meeting the requirements of this specification, are primarily defined by means of three criteria, namely, (1) nominal density, (2) degree

of crosslinking, and (3) long-term strength tests. There is a strong correlation between nominal density and results of short-term strength tests.

NOTE 2—PEX pipe intended for use in the transport of potable water should be evaluated and certified as safe for this purpose by a testing agency acceptable to the local health authority. The evaluation should be in accordance with requirements for chemical extraction, taste, and odor that are no less restrictive than those included in NSF/ANSI 14. The seal or mark of the laboratory making the evaluation should be included on the pipe.

5.2 *Basic Materials*—PEX pipe shall be made from polyethylene compounds which have been crosslinked by peroxides, Azo compounds, or silane compounds in extrusion, or by electron beam after extrusion, or by other means such that the pipe meets the performance requirements of Section 6. For the use temperatures that the pipe will be marked for, the materials, procedure for mixing, and the process for crosslinking shall result in a product with long term hydrostatic stress ratings equal better than those shown in Table 2, when determined in accordance with procedures no less restrictive than those of PPI TR-3⁹. See Appendix X1 for additional information on PPI hydrostatic stress ratings.

NOTE 3—Pipe produced by crosslinking by peroxides, Azo compounds, or silane compounds in extrusion, or by electron beam after extrusion have met the requirements of Section 6. There are several other processes for producing crosslinked polyethylene pipe. However, each process must be established as meeting the requirements of this specification.

5.3 *Pipe Material Designation*—The pipe meeting the requirements of this specification shall be designated PEX.

TABLE 2 Material Designation Code Cells

DR/SDR	Rated Temperature		Hydrostatic Design Stress		Pressure Rating for Water	
	°F	°C	psi	MPa	Psig	MPa
DR 6	73.4	23	630	4.34	210	1.45
	180	82.2	400	2.76	160	1.10
	200	93.3	315	2.17	125	0.86
DR 7.4	73.4	23	630	4.34	200	1.60
	180	82.2	400	2.76	125	0.86
	200	93.3	315	2.17	100	0.69
SDR 9	73.4	23	630	4.34	160	1.10
	180	82.2	400	2.76	100	0.69
	200	93.3	315	2.17	80	0.55
SDR 11	73.4	23	630	4.34	125	0.86
	180	82.2	400	2.76	80	0.55
	200	93.3	315	2.17	60	0.41
DR 13.6	73.4	23	630	4.34	100	0.69
	180	82.2	400	2.76	60	0.41
	200	93.3	315	2.17	50	0.35
DR 16.2	73.4	23	630	4.34	41	0.28
	180	82.2	400	2.76	26	0.18
	200	93.3	315	2.17	21	0.14
SDR 17	73.4	23	630	4.34	80	0.55
	180	82.2	400	2.76	50	0.35
	200	93.3	315	2.17	40	0.28

5.4 Carbon Black—When black PEX pipe is intended for aboveground applications, the black PEX compound shall contain 2% to 3% carbon black. When PEX pipe is intended for applications other than above ground (UV exposed), see [Appendix X2](#) for UV labeling guidelines.

NOTE 4—Plastics Pipe Institute literature states, “It has been demonstrated that a minimum of 2% well-dispersed very fine particle carbon black is sufficient protection for continuous outdoor service”.

6. Requirements

6.1 Workmanship—The pipe shall be homogeneous throughout and free of visible cracks, holes, foreign inclusions, or other defects. The pipe shall be as uniform as commercially practicable in color, opacity, density, and other physical properties.

6.2 Out-of Roundness—The maximum out-of roundness requirements, shown in [Table 3](#) for pipe, apply to the average, measured diameter after rounding with a rounding tool recommended by the manufacturer.

6.3 Dimensions and Tolerances:

6.3.1 Outside Diameters—The outside diameters and tolerances shall be as shown in [Table 3](#) for metric sizes or [Table 4](#) for inch sizes, when measured in accordance with [7.4](#) and [7.4.1](#).

6.3.2 Wall Thickness—The wall thickness shall be as shown in [Table 5](#) for metric sizes and [Table 6](#) for inch sizes, when measured in accordance with [7.4](#) and [7.4.2](#). The tolerance for all wall thicknesses is plus 12%.

TABLE 4 Inch-sized Outside Diameters and Tolerances for PEX Pipe

Pipe Size	Average Outside Diameter	Tolerances for Average Diameter
in.	in.	in.
3	3.500	0.016
4	4.500	0.020
5	5.563	0.025
6	6.625	0.030
8	8.625	0.039
10	10.750	0.048
12	12.750	0.057
14	14.000	0.063
16	16.000	0.072
18	18.000	0.081
20	20.000	0.090
22	22.000	0.099
24	24.000	0.108
26	26.000	0.117
28	28.000	0.126
30	30.000	0.135
32	32.000	0.144
34	34.000	0.153
36	36.000	0.162
42	42.000	0.189
48	48.000	0.216
54	54.000	0.243

NOTE 5—Pipe diameters less than 25 mm (1 in.) diameter have minimum wall thicknesses based on both hydrostatic and mechanical strength.

6.4 Density—When determined in accordance with [7.5](#), the crosslinked polyethylene pipe material shall have a minimum density of 0.926 Mg/m³.

6.5 Hydrostatic Sustained Pressure Strength—The pipe shall not fail, balloon, burst, or weep as defined in Test Method [D1598](#), at the test pressures shown in [Table 7](#) when tested in accordance with [7.6](#). The test pressure is based on the formula:

$$P (\text{test pressure}) = 2 (\text{fiber stress}) / [(\text{average OD/minimum wall}) - 1]$$

For most of the pipe sizes, average OD/minimum wall is the DR or SDR. For the smaller pipe sizes, the calculated value is slightly lower than the DR or SDR value, and this will result in a slightly higher test pressure, as seen in [Table 7](#). The fiber stress values are provided in [Table 7](#) for the three temperatures.

6.6 Hydrostatic Burst Pressure—The minimum burst pressure for PEX plastic pipe shall be as shown in [Table 8](#), when determined in accordance with [7.7](#). The minimum burst pressure is based on the formula:

$$P (\text{burst pressure}) = 2 (\text{fiber stress}) / [(\text{average OD/minimum wall}) - 1]$$

For most of the pipe sizes, average OD/minimum wall is the DR or SDR. For the smaller pipe sizes, the calculated value is slightly lower than the DR or SDR value, and this will result in a slightly higher burst pressure, as seen in [Table 1](#). The fiber stress values are provided in [Table 1](#) for the three temperatures.

6.7 Environmental Stress Cracking—There shall be no loss of pressure in the pipe, when tested in accordance with [7.8](#).

6.8 Degree of Crosslinking—When tested in accordance with [7.9](#), the degree of crosslinking for PEX pipe material shall

TABLE 3 Metric-sized Outside Diameters and Tolerances for PEX Pipe

Pipe Size	Average Outside Diameter	Tolerances for Average Diameter
mm	mm	mm
16	16.15	±0.15
20	20.15	±0.15
25	25.15	±0.15
32	32.15	±0.15
40	40.20	±0.20
50	50.20	±0.20
63	63.20	±0.20
75	75.25	±0.25
90	90.30	±0.30
110	110.35	±0.35
125	125.40	±0.40
140	140.45	±0.45
160	160.50	±0.50
180	180.55	±0.55
200	200.60	±0.60
225	225.70	±0.70
250	250.75	±0.75
280	280.85	±0.85
315	315.95	±0.95
355	356.10	±1.10
400	410.20	±1.20
450	451.35	±1.35
500	501.50	±1.50
560	561.70	±1.70
630	631.90	±1.90
710	713.20	±3.20
800	813.60	±3.60
900	904.05	±4.05
1000	1004.50	±4.50

TABLE 5 Metric-sized Wall Thickness and Tolerances for PEX Plastic Pipe Minimum Wall Thickness (t), (mm) (Tolerance is plus 12%)

Pipe DR/SDR							
Nominal Size	DR 6	DR 7.4	SDR 9	SDR 11	DR 13.6	DR 16.2	SDR 17
16	3.0	2.3	2.0	...	...	...	...
20	3.4	3.0	2.3	2.0	...	...	...
25	5.4	3.5	3.0	2.3	2.0	...	...
32	5.4	4.4	3.6	3.0	2.4	2.0	2.3
40	6.7	5.5	4.5	3.7	3.0	2.5	2.8
50	8.3	6.9	5.6	4.6	3.7	3.1	3.4
63	10.5	8.6	7.1	5.8	4.7	3.9	4.3
75	12.5	10.3	8.4	6.8	5.6	4.6	5.1
90	15.0	12.3	10.1	8.2	6.7	5.6	6.1
110	18.3	15.1	12.3	10.0	8.1	7.7	7.4
125	20.8	17.1	14.0	11.4	9.2	7.7	8.3
140	23.3	19.2	15.7	12.7	10.3	8.7	9.3
160	26.6	21.9	17.9	14.6	11.8	9.9	10.6
180	29.9	24.6	20.1	16.4	13.3	11.1	11.9
200	33.2	27.4	22.4	18.2	14.7	12.4	13.2
225	37.4	30.8	25.2	20.5	16.6	13.9	14.9
250	41.5	34.2	27.9	22.7	18.4	15.5	16.4
280	46.5	38.3	31.3	25.4	20.6	17.3	18.4
315	52.3	43.1	35.2	28.6	23.2	19.5	20.7
355	59.0	48.5	39.7	32.2	26.1	21.9	23.4
400	...	54.7	44.7	36.3	29.4	24.7	23.7
450	...	61.5	50.3	40.9	33.1	27.8	29.5
500	...	...	55.8	45.4	36.8	30.9	32.8
560	...	...	62.5	50.8	41.2	34.6	36.7
630	...	...	70.3	57.2	46.3	38.9	41.3
710	...	...	79.3	64.5	52.2	43.9	46.5
800	...	...	89.3	72.6	58.8	49.4	52.3
900	...	...	...	81.7	66.2	56.6	58.8
1000	...	...	...	90.2	72.5	61.8	65.4

TABLE 6 Inch-sized Wall Thickness and Tolerances for PEX Plastic Pipe Minimum Wall Thickness (t), (in.) (Tolerance is plus 12%)

Pipe DR/SDR								
Nominal Size	DR 7.3	DR 8.3	SDR 9	SDR 11	DR 13.5	DR 15.5	SDR 17	SDR 21
3	0.479	0.422	0.389	0.318	0.259	0.226	0.206	0.167
4	0.616	0.542	0.500	0.409	0.333	0.290	0.265	0.214
5	0.762	0.670	0.618	0.506	0.412	0.359	0.327	0.265
6	0.908	0.798	0.736	0.602	0.491	0.427	0.390	0.315
8	1.182	1.039	0.958	0.784	0.639	0.556	0.507	0.411
10	1.473	1.295	1.194	0.977	0.796	0.694	0.632	0.512
12	1.747	1.536	1.417	1.159	0.944	0.823	0.750	0.607
14	1.918	1.687	1.556	1.273	1.037	0.903	0.824	0.667
16	2.192	1.928	1.778	1.455	1.185	1.032	0.941	0.762
18	2.466	2.169	2.000	1.636	1.333	1.161	1.059	0.857
20	...	2.409	2.222	1.818	1.481	1.290	1.176	0.952
22	...	...	2.444	2.000	1.630	1.419	1.294	1.048
24	...	...	2.667	2.182	1.778	1.548	1.412	1.143
26	...	...	...	2.364	1.926	1.677	1.529	1.238
28	...	...	...	2.545	2.074	1.806	1.647	1.333
30	...	...	...	2.727	2.222	1.935	1.765	1.429
32	...	...	...	2.909	2.370	2.065	1.882	1.524
34	...	...	...	3.091	2.519	2.194	2.000	1.619
36	...	...	...	3.273	2.667	2.323	2.118	1.714
42	...	...	...	...	...	2.710	2.471	2.000
48	...	...	...	...	...	3.097	2.824	2.286
54	...	...	...	...	...	...	3.176	2.571

be within the range from 65 to 89 % inclusive. Depending on the process used, the following minimum percentage crosslinking values shall be achieved: 70 % by peroxides, 65 % by Azo compounds, 65 % by electron beam, or 65 % by silane compounds.

NOTE 6—Techniques as found in Test Methods [D2765](#).

6.9 Stabilizer Functionality—Stabilizer Functionality shall be tested in accordance with [7.10](#).

NOTE 7—For example PEX pipe marked with the material designation code PEX 1006 is a PEX pipe meeting the chlorine resistance requirement for 25% of the time at 140°F and 75% of the time at 73°F and having an HDS for water at 73°F of 630psi (HDB of 1250 psi) as follows:

TABLE 7 Minimum Hydrostatic Sustained Pressure Requirements for PEX SDR 9 Pipe (For other DRs or SDRs use fiber stress values below to determine the pressure) P (pressure) = 2 (fiber stress)/ [(average OD/ minimum wall)-1]


Nominal Size		Pressure Required for Test, psi ^A (MPa)					
mm	in.	73.4°F	23°C	180°F	82.2°C	200°F	93.3°C
18	¾	370	2.55	220	(1.52)	185	(1.28)
20	¾	340	2.34	200	(1.38)	170	(1.17)
25	1	350	2.41	210	(1.45)	175	(1.21)
32	1¼	330	2.28	195	(1.34)	165	(1.14)
40 and larger	1½ and larger	325	2.24	190	(1.31)	165	(1.14)

^A The fiber stresses used to derive these test pressures are:
 at 73.4°F (23.0°C) 1300 psi (8.96 MPa).
 at 180°F (82.2°C) 770 psi (5.31 MPa).
 at 200°F (93.3°C) 650 psi (4.48 MPa).

TABLE 8 Burst Pressure Requirements for Water at Different Temperatures for PEX SDR 9 Plastic Pipe

Nominal Size		Minimum Burst Pressures at Different Temperatures, psi ^A (MPa)					
mm	in.	73.4°F	(23°C)	180°F	(82.2°C)	200°F	(93.3°C)
16	(½)	540	(3.72)	240	(1.65)	205	(1.41)
20	(¾)	500	(3.45)	220	(1.52)	190	(1.31)
25	(1)	510	(3.52)	230	(1.59)	195	(1.34)
32	(1¼)	480	(3.31)	215	(1.48)	185	(1.28)
40 and larger	(1½ and larger)	475	(3.27)	210	(1.45)	180	(1.24)

^A The fiber stresses used to derive these test pressures are:
 at 73.4°F (23.0°C) 1900 psi (13.10 MPa).
 at 180°F (82.2°C) 850 psi (5.86 MPa).
 at 200°F (93.3°C) 720 psi (4.96 MPa).



6.10 Oxidative Stability in Potable Chlorinated Water Applications—PEX pipe intended for use in the transport of potable water shall have a minimum extrapolated time-to-time failure of 50 years when tested and evaluated in accordance with 7.11.

6.11 Bent Pipe Hydrostatic Sustained Pressure Strength:

6.11.1 General—PEX pipe, up to and including 25 mm (1 in.) nominal diameter, shall meet 6.11.2 and 6.11.3.

NOTE 8—PEX pipe, larger than 25 mm (1 in.) nominal diameter, is typically installed as main distribution lines and is installed in straight runs. Fittings are used when a change in direction of 90° or greater and a bend radius of 6 times the outside diameter is needed. The test procedures in 6.11.2 and 6.11.3 are intended to evaluate PEX pipe installed in tight bend applications in accordance with the procedures in X3.2.4 and X3.2.5. This application applies to pipe up to and including 1 in nominal diameter only.

6.11.2 Hot-bent pipe, with a radius of 2.5 times the outside diameter and consisting of a continuous bend length inducing not less than 90° angle, shall meet the minimum hydrostatic sustained pressure strength requirements for 180°F as shown in

Table 7 when tested in accordance with 7.6. The bend length and bend angle is kept throughout the testing period by rigid supports immediately outside the bend.

6.11.3 Cold-bent pipe, with a radius of 6 times the outside diameter and consisting of a continuous bend length inducing not less than 90° angle, shall meet the minimum hydrostatic sustained pressure strength requirements for 180°F as shown in Table 7 when tested in accordance with 7.6. The bend length and bend angle is kept throughout the testing period by rigid secures immediately outside the bend.

6.12 Excessive Temperature—Pressure Capacity:

6.12.1 General—In the event of a water heating system malfunction, PEX pipe shall have adequate strength to accommodate short-term conditions, 48 h of 210°F (99°C). 150 psi (1034 kPa) until repairs can be made.

6.12.2 Excessive Temperature Hydrostatic Sustained Pressure—Pipe shall not fail as defined in Test Method D1598 in less than 30 days (720 h) when tested in accordance with 7.12.

7. Test Methods

7.1 Conditioning—Condition the specimens at 73.4 ± 3.6°F (23 ± 2°C) and 50 ± 5% relative humidity for not less than 40 h prior to test in accordance with Procedure A of Practice D618, for those tests where conditioning is required. In cases of disagreement, the tolerances shall be ±1.8°F (±1°C) and ±2 % relative humidity.

7.2 Test Conditions—Conduct the test in the standard laboratory atmosphere of $73.4 \pm 3.6^{\circ}\text{F}$ ($23 \pm 2^{\circ}\text{C}$) and $50 \pm 5\%$ relative humidity, unless otherwise specified in the test methods or in this specification. In cases of disagreement, the tolerances shall be $\pm 1.8^{\circ}\text{F}$ ($\pm 1^{\circ}\text{C}$) and $\pm 2\%$ relative humidity.

7.3 Sampling—A sufficient quantity of pipe, as agreed upon by the purchaser and the seller, shall be selected and tested to determine conformance with this specification (see Practice D1898). In the case of no prior agreement, random samples selected by the testing laboratory shall be deemed adequate.

7.3.1 Test Specimens—Not less than 50 % of the test specimens required for any pressure test shall have at least a part of the marking in their central sections. The central section is that portion of pipe that is at least one pipe diameter away from an end closure.

7.4 Dimensions and Tolerances—Use any length of pipe to determine the dimensions. Measure in accordance with Test Method D2122.

7.4.1 Outside Diameter—Measure the outside diameter of the pipe in accordance with Test Method D2122. The referee method of measurement is to be by circumferential wrap tape. The tolerance for out-of-roundness shall apply only to pipe prior to shipment. Averaging micrometer or vernier caliper measurements, four (4) maximum and minimum diameter measurements at any cross section, may be used for quality control checks if desired.

7.4.2 Wall Thickness—Make micrometer measurements of the wall thickness in accordance with Test Method D2122 to determine the maximum and minimum values. Measure the wall thickness at both ends of the pipe to the nearest 0.001 in. (0.025 mm).

7.5 Density—Determine the density of the pipe compound in accordance with Test Method D1505, or Test Methods D792, using three specimens.

7.6 Hydrostatic Sustained Pressure Test—Select the test specimens at random. Test individually with water at the three controlled temperatures and under the pressures given in Table 7, 18 specimens of pipe, each specimen at least ten times the nominal diameter in length, but not less than 10 in. (25.4 cm) or more than 3 ft (91.4 cm) between end closures and containing the permanent marking on the pipe. Test six specimens at each temperature. Condition the specimens for at least 2 h to within $\pm 3.6^{\circ}\text{F}$ ($\pm 2^{\circ}\text{C}$) of the specified test temperatures. Maintain the specimens at the pressures indicated for the appropriate temperatures for a period of 1000 h. Hold the pressure as closely as possible, but within ± 10 psi (± 0.070 MPa). Maintain the test temperatures within $\pm 3.6^{\circ}\text{F}$ ($\pm 2^{\circ}\text{C}$) of the specified temperature. Test in accordance with Test Method D1598 except maintain the pressure at the values given in Table 7 for 1000 h. Failure of two of the six specimens tested at either temperature constitutes failure in the test. Failure of one of six specimens tested at either temperature is cause for retest of six additional specimens at that temperature. Failure of one of six specimens tested at either temperature in retest constitutes failure in the test. Failure of the pipe shall be defined in accordance with Test Method D1598, namely:

7.6.1 Failure—Any continuous loss of pressure resulting from the transmission of the test liquid through the body of the specimen under test.

7.6.2 Ballooning—Any abnormal localized expansion of a pipe specimen while under internal hydraulic pressure.

7.6.3 Bursting—Failure by a break in the pipe with immediate loss of test liquid and continued loss at essentially no pressure.

7.6.4 Seepage or Weeping—Failure that occurs through essentially microscopic breaks in the pipe wall, frequently only at or near the test pressure.

NOTE 9—At lower pressures, the pipe may carry liquids without evidence of loss of liquids.

7.7 Hydrostatic Burst Pressure—Determine the minimum burst pressure with at least five specimens in accordance with Test Method D1599. The time of testing of each specimen shall be between 60 and 70 s. The pressure values are given in Table 8.

7.8 Environmental Stress Cracking Test—Use six randomly selected 10-in. (250-mm) long specimens for this test. Make a notch on the inside of the pipe wall in the axial direction. The notch depth shall be 10 % of measured minimum wall thickness and the notch length 1 in. (25 mm). Use a sharp blade mounted in a jig to make this imperfection. Use a depth micrometer or other means for setting the blade in the jig so that the notch depth is controlled as specified. The notch shall be placed, at its nearest point, at least 1.5 times the nominal diameter away from end closures. Fill the pipe with the test medium which is 5 % "Igepal CO-630"¹⁰ mixed with 95 % of untreated water. The test is then made in accordance with 7.6, under the pressures given in Table 7, except maintain the pressure for 100 h.

7.9 Degree of Crosslinking—Place a pipe sample in a lathe with automatic feeding. Shave a strip that consists of the full wall thickness. The strip thickness shall be approximately 0.004 in. (0.1 mm), which is obtained by setting the lathe feeding accordingly. Test the specimens in accordance with Test Methods D2765, Method B, with the only deviation: test specimen preparation. For the purpose of this specification, degree of crosslinking (V) is defined as 100 % minus extract percent equals V.

NOTE 10—This method provides a test method for measuring the average degree of crosslinking over the pipe wall thickness. That, however, does not mean that the degree of crosslinking is allowed to vary outside the limits for the grade in question at any part of the pipe. In case of disagreement, strips of the same thickness, 0.004 in. (0.1 mm), can be taken in tangential, axial, or radial direction at any angle section or wall thickness depth, or both, etc. to measure the degree of crosslinking.

7.10 Stabilizer Functionality—The functionality of a stabilizer in a specific PEX compound shall be verified by hydrostatic testing of pipe made from the compound. Test six pipe samples continuously for 3000 h at a hoop stress of 0.70 MPa at 120°C , or for 8000 h at a hoop stress of 2.8 MPa at 110°C . This test is used to demonstrate the specific compound's ability

¹⁰ This method is based on the use of "Igepal Co-630," a trademark for a nonylphenoxypoly (ethylenoxy) ethanol, which may be obtained from GAF Corp., Dyestuff and Chemical Div., 140 W. 51st St., New York, NY 10020.

to withstand long term temperature conditions set forth elsewhere in this standard.

7.10.1 Procedure—The test procedure shall be conducted in accordance with Test Method **D1598** or ISO 1167. Test six (6) samples at one of the temperature conditions in **7.10**. The internal medium is water the external medium is air. Failure of any one of the specimens constitutes failure of the test.

7.10.2 Significance—The test need only be performed for the original validation of pipe made from a particular compound.

7.11 Oxidative Stability in Potable Chlorinated Water Applications—The test shall be conducted, and the extrapolated time-to-failure shall be determined in accordance with Test Method **F2023**. The test fluid shall be prepared in accordance with 9.1.1 of Test Method **F2023**. The extrapolated time-to-failure shall be calculated in accordance with 13.3 of Test Method **F2023** and as follows:

7.11.1 For a chlorine resistance cell of "1" using the coefficients from Test Method **F2023**, 13.1 and using Miners Rule, calculate the estimated time to-failure for a hoop stress corresponding to a sustained internal pressure of 80 psig (551.7 kPa) for the DR of the tested specimens at temperature exposure conditions of 25 % of the total time at 140°F (60°C) and 75% of the total time at 73°F (23°C) in accordance with ISO 13760.

7.11.2 For a chlorine resistance cell of "3" using the coefficients from Test Method **F2023**, 13.1, and using Miners Rule, calculate the estimated time to-failure for a hoop stress corresponding to a sustained internal pressure of 80 psig (551.7 kPa) for the DR of the tested specimens at temperature exposure conditions of 50 % of the total time at 140°F (60°C) and 50% of the total time at 73°F (23°C) in accordance with ISO 13760.

7.11.3 For a chlorine resistance cell of "5", using the coefficients from Test Method **F2023**, 13.1, calculate the estimated time-to-failure at a hoop stress corresponding to a sustained internal pressure of 80 psig (551.7 kPa) for the DR of the tested specimens at temperature of 100% of the time at 140°F (60°C).

NOTE 11—The conditions described in Test Method **F2023**, 13.3 only apply to intermittent service such as might be found in normal residential use. This does not validate the use of PEX pipe in continuous recirculation applications.

7.11.4 Significance—The test need only be performed on representative pipe samples for the original validation of pipe made from a particular compound.

7.12 Excessive Temperature and Pressure Capability:

7.12.1 Hydrostatic Sustained Pressure—Determine in accordance with Test Method **D1598**, except for the following requirements:

7.12.1.1 Test at least six specimens from randomly selected specimens diameter ½ in. or greater. Specimens shall be at least 5 pipe diameters long.

7.12.1.2 Condition pipe in accordance with **7.1**.

7.12.1.3 Test temperature shall be 210 ± 4°F (99 ± 2°C).

7.12.1.4 The external test environment shall be air.

7.12.1.5 Fill the specimens with water and condition for 2 h at a temperature of 210 ± 4°F (99 ± 2°C) and a pressure of 30 ± 3psi(207±21kPa).

7.12.1.6 Pressurize test specimens to the required pressure and maintain for 30 days (720 h). The pressure for PEX pipe shall be 150 psi (1034 kPa), for SDR9 diameters. The fiber stress used to derive this test pressure is 595 psi (4.1 MPa).

8. Retest and Rejection

8.1 If the results of any test(s) do not meet the requirements of this specification, the tests(s) shall be conducted again only by agreement between the purchaser and seller. Under such agreement, minimum requirements shall not be lowered, changed, or modified, nor shall specification limits be changed. If upon retest, failure occurs, the quantity of product represented by the test(s) does not meet the requirements of this specification.

9. Certification

9.1 PEX pipe intended for use in the transport of potable water shall be evaluated and certified as safe for this purpose by a testing agency acceptable to the local health authority. The evaluation shall be in accordance with the requirements for chemical extraction, taste, and odor that are no less restrictive than those included in NSF/ANSI Standard 14**NSF/ANSI 14/61**.

10. Marking

10.1 Quality of Marking—The marking shall be applied to the pipe in such a manner that it remains legible (easily read) after installation and inspection. Markings shall be applied without indentation in some permanent manner so as to remain legible under normal handling and installation practice

10.2 Marking on the pipe shall include the following, spaced at intervals of not more than 5 ft:

10.2.1 Manufacturer's name (or trademark) and production code indicating the date of production.

10.2.2 Pipe size and sizing system—millimetre or inch— (for example, 90 mm or 12 in.).

10.2.3 Type of plastic pipe material in accordance with the designation code given in **3.2.7**.

10.2.4 Standard dimension ratio or dimension ratio, for example - SDR 9.

10.2.5 Pressure rating(s) for water and temperature(s) for which the pressure(s) rating are valid.

10.2.6 This ASTM designation, F2788.

10.2.7 Pipe intended for the transport of potable water shall also include the seal or mark of the laboratory making the evaluation for this purpose, spaced at intervals specified by the laboratory.

10.2.8 Standard designation(s) of the fitting system(s) for which the pipe is recommended for use by the pipe manufacturer.

10.2.9 Black PEX pipe meeting the material requirements of **5.4** and intended for aboveground installation shall be marked "Suitable for aboveground applications."

11. Quality Assurance

11.1 When the product is marked with this designation, F2788, the manufacturer affirms that the product was manufactured, inspected, sampled, and tested in accordance with this specification and has been found to meet the requirements of this specification.

12. Keywords

12.1 crosslinked polyethylene; hydrostatic stress; PEX; PPI; pipe; pressure

SUPPLEMENTARY REQUIREMENTS

GOVERNMENT/MILITARY PROCUREMENT

These requirements apply *only* to federal/military procurement, not domestic sales or transfers.

S1. *Responsibility for Inspection*—Unless otherwise specified in the contract or purchase order, the producer is responsible for the performance of all inspection and test requirements specified herein. The producer may use his own or any other suitable facilities for the performance of the inspection and test requirements specified herein, unless the purchaser disapproves. The purchaser shall have the right to perform any of the inspections and tests set forth in this specification where such inspections are deemed necessary to ensure that material conforms to prescribed requirements.

NOTE S1.1—In U.S. federal contracts, the contractor is responsible for inspection.

S2. *Packaging and Marking for U.S. Government Procurement*:

S2.1 *Packaging*—Unless otherwise specified in the contract, the materials shall be packaged in accordance with the supplier's standard practice in a manner ensuring arrival at destination in satisfactory condition and which will be acceptable to the carrier at lowest rates. Containers and packing shall comply with Uniform Freight Classification rules or National Motor Freight Classification rules.

S2.2 *Marking*—Marking for shipment shall be in accordance with FED. STD. No. 123 for civil agencies and MIL-STD-129 for military agencies.

NOTE S2.1—The inclusion of U.S. Government procurement requirements should not be construed as an indication that the U.S. Government uses or endorses the products described in this specification.

APPENDIXES

(Nonmandatory Information)

X1. SOURCE OF HYDROSTATIC DESIGN STRESSES

X1.1 The hydrostatic design stress recommended by the Plastics Pipe Institute is used to pressure rate PEX plastic pipe. These hydrostatic design stresses are: 630 psi (4.34 MPa) for water at 73.4°F (23°C), 400 psi (2.76 MPa) for water at 180°F (82.2°C), and 315 psi (2.17 MPa) for water at 200°F (93.3°C). These hydrostatic design stresses apply only to pipe meeting all the requirements of this specification.

X1.2 Refer also to Test Method **D2837**. Additional information regarding the method of test and other criteria used in developing these hydrostatic design stresses may be obtained from the Plastics Pipe Institute. These hydrostatic design stresses may not be suitable for materials that show a wide departure from a straight-line plot of log stress versus log time to failure. All the data available to date on PEX-pipe materials made in the United States exhibit a straight-line plot under these plotting conditions.

X1.3 The hydrostatic design stresses and pressure ratings in **Table 5** apply to PEX SDR 9 pipe meeting the requirements of this specification.

X1.4 The hydrostatic design stresses recommended by the Plastics Pipe Institute are based on tests made on pipe ranging in size from ½ to 2 in.

X1.5 The stabilizer functionality test is not intended to determine the long term hydrostatic strength of the pipe but to serve as indicator of the individual PEX compound stabilization.

X1.6 Stabilizer Verification: The oxidation induction time (OIT) as described in Test Method **D3895** may be used to monitor stabilizer content of a PEX material or freshly extruded pipe. Once the initial OIT value has been established for a specific compound, subsequent OIT values can be used to validate the stabilizer level in the pipe or compound without the need to run additional temperature tests. It should be mentioned that OIT tests are not an indicator of life expectancy, nor should differences in OIT values between compounds be construed to indicate differences in the stabilizer effectiveness of respective formulations.

NOTE X1.1—As of this writing no precision and bias statement is available for the OIT tests and will have to be determined for each

compound as data is developed.

X2. UV LABELING GUIDELINES FOR PEX PIPE

X2.1 PEX pipe should be kept in original packaging until time of use, and it should not be used in direct sunlight. To inform customers and users about the need to prevent accidental overexposure of PEX pipe to sunlight (UV light), it is recommended that a UV CAUTION label be applied to all PEX pipe packaging by the manufacturer.

X2.2 The text and content of the recommended label is as shown X2.4. "X" is the maximum cumulative time period as recommended by the pipe manufacturer for direct sunlight exposure without harm to the long-term performance characteristics of the PEX pipe.

X2.3 The recommended text may be incorporated into existing labels with other information. The universal "no-sun" symbol may be shown in color, black-and-white or grayscale, and should be positioned close to the recommended text.

X2.4 *Caution Label*—Do not store PEX pipe unprotected outdoors.

Keep PEX pipe in the original packaging or under protective cover until time of installation.

Ensure that exposure to sunlight during installation does not exceed the maximum recommended UV exposure time of "X".

X3. DESIGN, ASSEMBLY, AND INSTALLATION CONSIDERATIONS

X3.1 Design

X3.1.1 *Thermal Expansion*—The linear expansion rate for PEX is approximately 1.1 in./10°F temperature change for each 100 ft of pipe, or 28 mm/5.6°C temperature change for each 30 m of pipe. When installing long runs of pipe, allow 1/8 to 3/16 in. longitudinal clearance per ft (10 to 14 mm/m) of run to accommodate thermal expansion. pipe should not be anchored rigidly to a support but allowed freedom of movement to expand and contract.

X3.1.2 *Water Heaters*—Components covered by this specification may not be suitable for use with the instantaneous-type (coil or immersion) water heaters. They are suitable for use with storage-type water heaters with connections made in an approved manner.

X3.1.3 *Sweating*—Even though the thermal conductivity of PEX is several orders of magnitude lower than that of metal. sweating or condensation, at a slow rate may occur under certain temperature and humidity conditions.

X3.1.4 *Water Hammer and Surge*—A PEX water system will withstand repeated pressure surges, well in excess of its rated pressure, but water hammer arrestors may be advisable when solenoid valves or other quick-closing devices are used in the system. In designing for such situations, it is advisable to consult the pipe manufacturer for recommended surge pressure limits. Water hammer and surge pressure calculations are reviewed in AWWA Manual M-1 1. Steel Pipe Design and Installation, Chapter 7¹¹.

X3.1.5 *Horizontal Support Spacing*—The maximum recommended spacing between horizontal supports is 32 in. (800 mm) for diameters up to 1 1/4 in. Crosslinked polyethylene pipe should not be rigidly secured to a stud or joist but should be

secured with smooth plastic strap hangers, which permit ease of movement during expansion/contraction cycles.

X3.1.6 When PEX pipe is to be used in sealed central heating systems, the fact that all plastics allow for a certain amount of oxygen diffusion should be taken into consideration.

X3.2 Installation

X3.2.1 *Storage and Handling*—PEX pipe should be stored under cover to avoid unnecessary dirt accumulation and long-term exposure to sunlight. Pipe can be stored in coils of number size and length recommended by the manufacturer. Care should be used in handling to ensure that unnecessary abuse, such as abrasion on concrete or crashing, is avoided.

X3.2.2 *Repairs*—If a leak is discovered, that portion of the system should be drained and the actual, part should be cut out. The pipe should be thoroughly dried and mechanical fitting(s) and if necessary, short length(s) of pipe should be installed.

X3.2.3 *Soldering in the Area*—Soldered metal fittings should not be made closer than 18 in. (460 mm) to an installed PEX-to-metal adapter in the same piece of pipe.

X3.2.4 *Hot Bending of Pipe*—For hot bending use a hot-air-gun with a so-called diffuser nozzle, not an open flame. The hot air temperature meeting the pipe surface must not exceed 338°F (170°C) and the heating up time must not exceed 5 min. The pipe shall be heated until the material, at the bending point becomes translucent, approximately 265°F (130°C), for non-colored pipes. Colored pipes will turn soft to allow the bending. Experience will show how much heat is enough. Bend and fix the pipe in the bent position, using conventional tube bending tools with side support. Cool the pipe in water or air before removal of bending tool. Fix the pipe by supports on both sides of the bend at installation. The minimum hot bending radius for PEX SDR 9 pipe is 2.5 times outside diameter. Outside diameter is equal to nominal diameter plus 1/8 in. (see 4.2).

¹¹ Available from American Water Works Association (AWWA), 6666 W. Quincy Ave., Denver, CO 80235, <http://www.awwa.org>.

X3.2.5 Cold Bending of Pipe—PEX SDR 9 pipe shall be bent at room temperature without the use of bending tools down to a minimum bending radius of 6 times outside diameter. Outside diameter is equal to nominal diameter plus $\frac{1}{8}$

in. (see 4.2). Normal precaution is taken to avoid buckling or flattening. Fix the pipe by supports on both sides of the bend at installation

X4. OPTIONAL PERFORMANCE QUALIFICATION AND IN-PLANT QUALITY-CONTROL-PROGRAM FOR PEX HOT-WATER DISTRIBUTION SYSTEM COMPONENTS

X4.1 Scope

X4.1.1 The following program covers performance qualification and in-plant quality control for component design and manufacture respectively to provide reasonable assurance that PEX hot-water distribution system components supplied under this specification shall consistently meet its requirements.

X4.2 Performance Qualifications

X4.2.1 Performance qualification tests shall be run initially on each component design, size, and formulation in accordance with the requirements of this specification. The test results shall be independently certified and shall be made available to the purchaser on request.

X4.3 In-Plant Quality Control

X4.3.1 *Material*—The pipe material shall be PEX as defined in Section 8.1 of this specification. The manufacturer shall so certify.

X4.3.2 Pipe quality-control tests shall be run for each extrusion line in accordance with the requirements of this

specification at a frequency agreed upon between the purchaser and the manufacturer. The program outlined in Table X4.1 is recommended. The test results shall be recorded and filed for inspection on request. Should a specimen fail to meet the specification in any test, production should be sampled back to the previous acceptable test result and tested to determine which specimens produced in the interim do not meet the requirement. Specimens that do not meet the requirements of this specification shall be rejected. See Table X4.2.

TABLE X4.1 Suggested Quality-Control Program

Component	Property	Frequency	Requirements
Pipe	Workmanship	continuously	6.1
	Dimensions	hourly	6.2
	Density	weekly	5.3
	Burst Pressure	daily	5.5
	Sustained pressure	3 months	5.4
	Environmental stress cracking	yearly	5.6
	Degree of crosslinking	3 days	5.7
	Bent pipe	yearly	6.6

TABLE X4.2 Type Test Program

Component	Property	Requirement
Pipe	Hydrostatic design basis for each temperature	ASTM D2837
	Potable Water	NSF/ANSI 14

SUMMARY OF CHANGES

Committee F17 has identified the location of selected changes to this standard since the last issue (F2788-11) that may impact the use of this standard.

- (1) Changes Title and Scope to include inch pipe sizes.
- (2) Added Table 4 for inch-sized outside diameters.

- (3) Added Table 6 for inch-sized wall thicknesses.
- (4) Added pipe size to Marking section.



ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org). Permission rights to photocopy the standard may also be secured from the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, Tel: (978) 646-2600; <http://www.copyright.com/>