


PIPE HANGER

Design & Engineering



ANVIL[®]
INTERNATIONAL, INC.
Formerly Grinnell

www.anvilintl.com



PIPING and PIPE HANGER DESIGN and ENGINEERING

WEIGHTS OF PIPING MATERIALS

The material in this booklet has been compiled to furnish pipe hanger engineers with the necessary data and procedures to determine pipe hanger loads and thermal movements of the pipe at each hanger location.

The tabulation of weights has been arranged for convenient selection of data that formerly consumed considerable time to develop. In many instances this information was not available for general distribution. This made it necessary to develop average or approximate weights that may be substituted with actual weights whenever practical.

LOAD CALCULATION PROBLEM

The "Hanger Load Calculation Problem" is typical of the actual steps required in the solution of any pipe hanger installation.

Great care was taken in collecting and printing data in this booklet to assure accuracy throughout. However, no representation or warranty of accuracy of the contents of this booklet is made by Anvil. The only warranties made by Anvil are those contained in sales contracts for design services or products.

CONTENTS	Page
Design of Pipe Hangers	4
Determination of Hanger Locations	4
Hanger Load Calculations	6
Thermal Movement Calculations	11
Selection of the Proper Hangers	13
Typical Pipe Support Specification	21
Nuclear pipe Hangers	24
Seismic Supports	24
Supports for Grooved Piping	27
Application Examples	30
Weights of Piping Materials	37
Charts and Tables	63

INTRODUCTION

To avoid confusion, it is necessary to define the terms pipe hanger and pipe support and clarify the difference between the two. Pipe hangers are generally considered to be those metal elements which carry the weight from above with the supporting members being mainly in tension. Pipe supports are considered to be those elements which carry the weight from below with the supporting members being mainly in compression.

It has become widely recognized that the selection and design of pipe hangers is an important part of the engineering study of any modern steam generating or process installation. Problems of pipe design for high temperature, high pressure installations have become critical to a point where it is imperative that such aspects of design as the effect of concentrated hanger loads on building structure, pipe weight loads on equipment connections, and physical clearances of the hanger components with piping and structure be taken into account at the early design stages of a project.

Engineers specializing in the design of pipe hangers have established efficient methods of performing the work required to arrive at appropriate hanger designs. However, the engineer who devotes varying portions of his time to the design of pipe hangers often must gather a considerable amount of reference data peculiar only to the hanger calculations for his current project.

It is the purpose of this article to present a compilation of all information necessary for the design of hangers, including a technical section devoted to the listing of piping material, weights, and thermal expansion data. Also, the discussions of the various steps involved in designing supports, presented here in their proper sequence, should serve as a good reference source for the engineer who only occasionally becomes involved in the essentials of hanger design.

The first of these steps is that of determining and obtaining the necessary amount of basic information before proceeding with calculations and detailing of the pipe supports. No design is complete unless the engineer has had the opportunity to review the equivalent of the following project data:

- The pipe hanger specification, when available (A typical hanger specification is shown on pages 21 and 22).
- A complete set of piping drawings.
- A complete set of steel and structural drawings including equipment foundation and boiler structure details.
- A complete set of drawings showing the location of ventilating ducts, electrical trays, pumps, tanks, etc.
- The appropriate piping specifications and data, which will include pipe sizes and composition identification, wall thicknesses, and operating temperatures.
- A copy of the insulation specifications with densities.
- Valve and special fittings lists, which will indicate weights.
- The movements of all critical equipment connections such as boiler headers, steam drums, turbine connections, etc.
- The results of the stress, flexibility and movement calculation performed for critical systems such as Main Steam, High Temperature Reheat, etc.

The steps in which the engineer applies this information are:

- (1) Determine hanger locations.
- (2) Calculate hanger loads.
- (3) Determine thermal movement of the piping at each hanger location.
- (4) Select hanger types: spring assembly, either constant support, variable spring type, rigid assembly, etc.
- (5) Check clearance between the hanger components and nearby piping, electrical cable trays, conduits, ventilating ducts, and equipment.

The final step will not be discussed to any great degree. This aspect of design is governed solely by the requirements and layouts of the individual job. Instead, attention will be devoted to steps 1 to 4, where the scope of good hanger practice can be generally defined for any installation.

Recognizing that each new piping design presents many new challenges to the engineer, no attempt is made to state fixed rules and limits applicable to every hanger design. Rather, the intention is to illustrate ideas which will serve as a guide to a simple, practical solution to any pipe support problem.

INTEGRAL ATTACHMENTS

Integral attachments are fabricated so that the attachment is an integral part of the piping component. Examples of integral attachments include ears, shoes, lugs, cylindrical attachments, rings and skirts. Integral attachments are used in conjunction with restraints or braces where multi-axial restraint in a single member is required. Of particular importance is the localized stresses induced into the piping or piping component by the integral attachments. Several methods to determine the local stresses are available including relatively simple hand/cookbook calculations provided in Welding Research Council (WRC) Bulletins 107, 198, and 297, ASME Code Cases N-318 and N-392, or through a detailed finite element analysis. Section 121 of ASME B31.1 discusses additional considerations for integral attachments.

HANGER SPANS

Support locations are dependent on pipe size, piping configuration, the location of heavy valves and fittings, and the structure that is available for the support of the piping.

No firm rules or limits exist which will positively fix the location of each support on a piping system. Instead, the engineer must exercise his own judgement in each case to determine the appropriate hanger location.

The suggested maximum spans between hangers listed in table below reflect the practical considerations involved in determining support spacings on straight runs of standard wall pipe. They are normally used for the support spacings of critical systems.

		SPAN BETWEEN SUPPORTS																
Nom. Pipe Size (In.)	1	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24	30
Span Water (Ft.)	7	9	10	11	12	13	14	16	17	19	22	23	25	27	28	30	32	33
Steam, Gas, Air (Ft.)	9	12	13	14	15	16	17	19	21	24	26	30	32	35	37	39	42	44

The spans in table are in accordance with MSS Standard Practice SP-69. They do not apply where concentrated weights such as valves or heavy fittings or where changes in direction of the piping system occur between hangers.

For concentrated loads, supports should be placed as close as possible to the load in order to minimize bending stresses.

Where changes in direction of the piping of any critical system occur between hangers; it is considered good practice to keep the total length of pipe between the supports less than $\frac{3}{4}$ the full spans in table below.

When practical, a hanger should be located immediately adjacent to any change in direction of the piping.

SAMPLE PROBLEM

In the sample problem (Figure 1) seven supports are shown on the 12 inch line, and two on the 6 inch pipe.

Note that the hanger **H-1** has been placed adjacent to the valve weight concentration. The proximity of the hanger to the valve is helpful in keeping the load at terminal connection **A** to a minimum. Also, the bending stresses induced in the pipe by the valve weight are kept to a minimum.

The selection of the location for hanger **H-2** entails a change in direction of the pipe between two hangers. In order to avoid excessive overhang of the pipe between hangers **H-1** and **H-2**, the length of pipe between these hangers is made less than

three fourths the suggested maximum span shown in the table on the previous page.

In considering the vertical section of the pipe on which **H-3** and **H-4** are shown, it should first be noted that this section of the pipe could be supported by one hanger rather than two as indicated. Two hangers will certainly provide greater stability than will a single hanger. Another deciding factor as to whether one hanger or a multiple hangers should be used is the strength of the supporting steel members of the structure. The use of two hangers will permit the total riser weight to be proportioned to two elevations of the structure, avoiding the concentration of all the riser load at one building elevation.

The locations for hangers **H-5** and **H-6** are governed by the suggested maximum span as well as the position of the concentrated valve weight. Consequently, **H-6** has been located adjacent to the valve, and **H-5** at a convenient location between the valve and the 12 inch riser.

The location of hanger **H-7** will be determined by calculation to satisfy the condition that no pipe load is to be applied to terminal connection **C**. It is obvious that by moving the hanger along the 12 foot section of pipe, the amount of load on connection **C** will vary. One support location exists where the entire section will be "balanced", and the load at **C** equal to zero.

The calculations to determine the exact location of **H-7** are shown in the section entitled "Hanger Load Calculation".




FIGURE 1 – SAMPLE PROBLEM

NOTE:

- Allowable load at connection **A** is 500 lbs.
- Allowable load at connection **B** and **C** is zero.
- All bends are 5 diameter bends.
- All elbows are L.R. Ells.
- Operating temperature is 1,050°F.
- All pipe is Sch. 160 A 335 P12.

Consider next the 6 inch section of pipe on which H-8 and H-9 are shown. One of the requirements for this hanger problem is that the load at terminal connection B shall be zero. By placing H-9 directly over connection B, we can easily assure that this load will be zero. Also, this hanger location eliminates any bending stresses in the pipe that would be caused by the weight of the valve and vertical pipe at point B. If H-9 could not be located at this point due to structural limitations, it would be desirable to place it as close as possible to the vertical section of pipe to keep the cantilever effect to a minimum.

Hanger H-8 is located at a convenient distance between H-9 and the intersection of the 6 inch and 12 inch pipes. In this instance, the location of adequate building structure will determine the hanger position.

The methods involved in locating hangers for this problem are typical of those employed by the hanger engineer in the design of pipe supports. Although the individual piping configurations and structure layout will vary in practically every instance, the general methods outlined above will apply for any critical piping system.

HANGER LOAD CALCULATIONS

The thermal expansion of piping in modern high pressure and temperature installations makes it necessary for the designer to specify flexible supports, thereby requiring considerable thought to the calculation of hanger loads.

Turbine and boiler manufacturers are especially concerned about the pipe weight on their equipment and often specify that the loads at pipe connections shall be zero. The hanger designer must be certain that the loads on the equipment connections of a piping system do not exceed the limits specified by the equipment manufacturers.

The majority of supports for a high temperature system are of the spring type. The designer must work to a high degree of accuracy in determining the supporting force required at each hanger location to assure balanced support, in order to select the appropriate size and type of spring support.

We have prepared a sample problem (Figure 1), in which all of the hangers except H-7 have been located. This illustration is limited to as few pipe sections as possible, but incorporates most of the problems encountered in hanger load calculations.

The calculation of loads for hangers involves dividing the system into convenient sections and isolating each section for study. A free body diagram of each section should be drawn to facilitate the calculations for each hanger load. Most of the free body diagrams presented here include as large a section of the piping system as is practical for a simple arithmetical solution to the problem.

The following solution is not intended to illustrate the only acceptable solution. Rather, it shows a composite of various accepted methods which, for the problem under consideration, produce a well balanced system. Of the approaches that could be made to the solution of any problem, there will be one method that will produce the best balanced system. Although the individual loads may vary, the total of all hanger loads would be the same in every case.

The first step in the solution of a hanger load problem is to prepare a table of weights. The table for our sample problem (Figure 1) is:


TABLE OF WEIGHTS – SAMPLE PROBLEM (FIGURE 1)				
Description	Weight	Insulation Weight (Ca-Si)	Total Weight	Weight Used In Calc.
12" Sch.160 Pipe	160.3 lb./ft.	20.4 lb./ft.	180.7 lb./ft.	180.7 lb./ft.
12" Sch. 160 L.R. Elbow	375 lb.	61.2 lb.	436.2 lb.	436 lb.
12" 1500 lb. Check Valve	3370 lb.	163.2 lb.	3533.2 lb.	3533 lb.
12" 1500 lb. Gate Valve	4650 lb.	163.2 lb.	4813.2 lb.	4813 lb.
12" 1500 lb. W.N. Flange	843 lb.	30.6 lb.	873.6 lb.	874 lb.
12" 5 Dia. Bend	1258 lb.	160.2 lb.	1418.2 lb.	1418 lb.
6" Sch. 160 Pipe	45.3 lb./ft.	11.5 lb./ft.	56.8 lb./ft.	56.8 lb./ft.
6" Sch. 160 90° L.R. Elbow	53 lb.	17.2 lb.	70.2 lb.	70 lb.
6" Sch. 160 45° Elbow	26 lb.	6.9 lb.	32.9 lb.	33 lb.
6" 1500 lb. Gate Valve	1595 lb.	80.5 lb.	1675.5 lb.	1676 lb.

Draw a free body diagram of the piping between point A and H-2, showing all supporting forces and all valve and pipe weights (Fig. 2). We will consider the loads and supporting forces between A, H-1 and H-2 acting about the axes x-x' and y-y', and apply the three equations:


$$\Sigma M_{x-x'} = 0$$

$$\Sigma M_{y-y'} = 0$$

$$\Sigma V = 0.$$



Note that the value for **H-2** on this section of the piping system represents only a part of the total hanger force at **H-2**. For clarity, we have labeled this force **H-2'**. In the calculations for the next section of pipe beginning at **H-2**, we will call the hanger force at this point **H-2''**.



Also, note that we have considered the weight of the 90° bend acting at the center of gravity of the bend. The distance **B** is determined from the Chart on page 10 which has been drawn for convenience:

$$B = \text{Radius} \times .637, \text{ or } 5 \text{ ft.} \times .637 = 3.185 \text{ ft.}$$

STEP 1 - TAKING MOMENTS ABOUT AXIS Y-Y' (FIG. 2),

$$\begin{aligned} \Sigma M_{y-y'} = 0, & 1.81(1418) + 8(1084) - 11(H-2') = 0 \\ & 2,567 + 8,672 = 11(H-2') \\ & H-2' = 1,022 \text{ lb.} \end{aligned}$$

STEP II - TAKING MOMENTS ABOUT AXIS X-X' (FIG. 2),

$$\begin{aligned} \Sigma M_{x-x'} = 0, & 1.81(1418) + 6.5(542) - 7(H-1) + 9.5(3,533) - 11(A) = 0 \\ & 2,567 + 3,523 + 33,564 = 7(H-1) + 11(A) \\ & 39,564 = 7(H-1) + 11(A) \end{aligned}$$

STEP III - ADDING FORCES $\Sigma V = 0$,

$$\begin{aligned} A + H-1 + H-2' - 3,533 - 542 - 1,418 - 1,084 &= 0 \\ A + H-1 + H-2' &= 6,577 \text{ lb.} \end{aligned}$$

Substituting the value **H-2'**, calculated as 1,022 lb. in Step I,

$$\begin{aligned} A + H-1 + 1,022 &= 6,577 \text{ lb.} \\ A &= 5,555 - H-1 \end{aligned}$$

STEP IV - SOLVING THE THREE EQUATIONS

- (1) **H-2' = 1,022** Step I
- (2) $39,654 = 7(H-1) + 11(A)$ Step II
- (3) $A = 5,555 - (H-1)$ Step III

Solving Equation (2) by substituting for $A = 5555 - H-1$,

$$\begin{aligned} 39,654 &= 7(H-1) + 11(5,555 - H-1) \\ H-1 &= 5,363 \text{ lb.} \end{aligned}$$

Substituting for **H-1** in Equation 3,


$$\begin{aligned} A &= 5,555 \text{ lb.} - 5,363 \text{ lb.} \\ A &= 192 \text{ lb.; which is below the allowable load at } A \text{ of } 500 \text{ lb.} \end{aligned}$$

Next, consider the section of pipe between **H-2** and **H-3** to determine the weight distribution, between these two points, of the 4ft. section of pipe and the five diameter bend.

$$\begin{aligned} \Sigma M_{H-2'} = 0, & 2(723) + 7.19(1418) - 9(H-3') = 0 \\ & H-3' = 1,293 \text{ lb.} \end{aligned}$$

$$\begin{aligned} \Sigma M_{H-3'} = 0, & 1.81(1,418) + 7(723) - 9(H-2'') = 0 \\ & H-2'' = 848 \text{ lb.} \end{aligned}$$

$$H-2 = H-2' + H-2'' = 1,022 \text{ lb.} + 848 \text{ lb.} = 1,870 \text{ lb.}$$



In the next free body diagram (Figure 4) consider the 65 ft. vertical section of the piping system to determine the supporting forces for **H-3''** and **H-4'**.

It is apparent that the combined forces **H-3''** and **H-4'** equals 65 ft. x 180.7 lb./ft. Further, both **H-3''** and **H-4'** could be any value, provided the relationship

$$H-3'' + H-4' = 11,746 \text{ lb.}$$

is maintained. It is not recommended, however, to select arbitrary values for these two forces; instead, the load for each hanger should be such that the elevation of the pipe attachment is above the midpoint of the length of pipe supported by the hanger. Thus, the support will be located above the point where one could consider the weight of the pipe column acting, thereby avoiding a condition where the location of the support lends itself to the "tipping" tendency of the pipe when the support is located below this point.

Since there is 10 ft. of vertical pipe above **H-3''** and 40 ft. of pipe between **H-3''** and **H-4'**, let **H-3''** support 10 ft. plus 30 ft. of pipe load:

$$H-3'' = (10 \text{ ft.} + 30 \text{ ft.})(180.7 \text{ lb./ft.}) = 7,228 \text{ lb.}$$

Since $H-3 = H-3' + H-3''$ and $H-3' = 1,293 \text{ lb.}$ (see Figure 3),

$$H-3 = 1,293 \text{ lb.} + 7,228 \text{ lb.} = 8,521 \text{ lb.}$$


$$H-4' = (10 \text{ ft.} + 15 \text{ ft.})(180.7 \text{ lb./ft.}) = 4,518 \text{ lb.}$$




Consider the piping between **H-4'** and **H-5** to determine the weight distribution of the 5 diameter bend and the 5 ft. of horizontal pipe:

$$\begin{aligned} \Sigma M_{H-4'} = 0 & \\ & 1.81(1,418) + 7.5(904) - 10(H-5') = 0 \\ & H-5' = 935 \text{ lb.} \end{aligned}$$

$$\begin{aligned} \Sigma M_{H-5'} = 0 & \\ & 2.5(904) + 8.1(914) - 10(H-4'') = 0 \\ & H-4'' = 1,387 \text{ lb.} \end{aligned}$$

$$H-4 = H-4' + H-4'' = 4,518 \text{ lb.} + 1,387 \text{ lb.} = 5,905 \text{ lb.}$$





It is obvious that some portion of the weight of the 6 in. pipe between the 12 in. line and H-8 must be supported by H-5 and H-6. Therefore, before proceeding through H-5 and H-6, calculate this pipe weight load R_1 , and introduce it into the free body diagram for H-5 and H-6.

$$\sum M_{y-y'} = 0 \quad .07(33) + 2.34(341) + 4.81(70) + 5(2,031) - 5(H-9) = 0$$

$$H-9 = 2,258 \text{ lb.}$$

$$\sum M_{x-x'} = 0 \quad 19(70) + 2.66(341) + 5.03(33) - 9(H-8) + 12.78(849) + 20.73(70) - 21R_1 = 0$$

$$13,387 = 9(H-8) + 21(R_1)$$

$$\sum V = 0, \quad R_1 + H-8 + H-9 - 2,031 - 70 - 341 - 33 - 849 - 70 = 0$$

$$R_1 + H-8 + H-9 = 3,394 \text{ lb.}$$

Since H-9 has been calculated as 2,258 lb.

$$R_1 + H-8 = 3,394 \text{ lb.} - 2,258 \text{ lb.} = 1,136 \text{ lb.}$$

$$H-8 = 1,136 \text{ lb.} - R_1$$

Substituting this value for H-8 in the Equation

$$13,387 = 9(H-8) + 21R_1$$

$$13,387 = 9(1,136 \text{ lb.} - R_1) + 21(R_1)$$

$$R_1 = 264 \text{ lb.}$$

$$H-8 = 1,136 - R_1 = 1,136 \text{ lb.} - 264 \text{ lb.} = 872 \text{ lb.}$$



FIGURE 8 – ELEVATION VIEW





FIGURE 9



Dimension E is determined from the Chart on page 10.

For the sample problem,
 $E = .726 \times 1.5 \text{ ft.} = 1.09 \text{ ft.}$

The free body diagram shown in Figure 8 extends from **H-5** through the 12 in. 90° elbow. This is intended to illustrate that the weight of the 90° elbow may be considered as supported on a beam which passes through the center of gravity of the elbow and rests on the extensions of the tangents as shown in Figure 9.

In Figure 8,

$$\Sigma M_{H-5} = 0, \quad 2(449) + 5(1,807) + 11.5(4,813) - 15(H-6) + 15.75(994) + 18.91(218) = 0$$

$$H-6 = 5,671 \text{ lb.}$$

$$\Sigma M_{H-6} = 0, \quad 3.5(4,813) + 10(1,807) + 13(449) - .75(994) - 3.91(218) - 15(H-5) = 0$$

$$H-5 = 2,610 \text{ lb.}$$

$$H-5 = H-5' + H-5'' = 935 \text{ lb.} + 2,610 \text{ lb.} = 3,545 \text{ lb.}$$

Solving for distance X,


$$\begin{aligned} \Sigma M_C &= 0, \\ .54(436) - X(H-7) + 6(1,626) + 10.91(218) &= 0 \\ X(H-7) &= 12,369 \\ X(3515) &= 12,369 \\ X &= 3.52 \text{ ft.} \end{aligned}$$

As a final step, check to ensure that the weight of the entire piping system is equal to the total supporting forces of the hangers plus the pipe weight load to be supported by the equipment connections:

SUMMARY — SUPPORT FORCES

Piping System	Weight (Lbs)	Support Forces Plus Terminal Point Loads, lb
109.5 ft. of 12" Pipe @ 180.7 lb./ft.	19,787	A = 192
(3) 12" 5 Dia. Bends @ 1418 lb.	4,254	H-1 = 5,363
(2) 12" 90° L.R. Ells @ 436 lb.	872	H-2 = 1,870
30.45 ft. of 6" Pipe @ 56.8 lb./ft.	1,730	H-3 = 8,521
(2) 6" 90° L.R. Ells @ 70 lb..	140	H-4 = 5,905
(1) 6" 45° Ell @ 33 lb.	33	H-5 = 3545
(1) 12" 1,500 lb. Check Valve @ 3,533 lb.	3,533	H-6 = 5,671
(1) 12" 1,500 lb. Gate Valve @ 4,813 lb.	4,813	H-7 = 3,515
(1) 12" 1,500 lb. WN Flange @ 874 lb.	874	H-8 = 872
(1) 6" 1,500 lb. Gate Valve @ 1,676 lb.	1,676	H-9 = 2,258
Total Weight of Piping System.	37,712	Total = 37,712

FIGURE 10 – ELEVATION VIEW




The Figure 10 diagram shows a method for arriving at the location of **H-7** which will allow zero load on connection **C**.


The value of **H-7** is equal to the weight of the piping section:

$$H-7 = 218 \text{ lb.} + 1,626 \text{ lb.} + 436 \text{ lb.} + 1,235 \text{ lb.} = 3,515 \text{ lb.}$$

CALCULATED ARC DISTANCES FOR BENDS AND WELDING ELBOWS



CENTER OF GRAVITY OF AN ARC



THERMAL MOVEMENTS

The next step in the design of pipe hangers involves the calculation of the thermal movements of the pipe at each hanger location. Based on the amount of vertical movement and the supporting force required, the engineer can most economically select the proper type hanger (i.e. Constant Support, Variable Spring, or Rigid Assembly).

The determination of piping movements to a high degree of accuracy necessitates a highly complicated study of the piping system. The simplified method shown here is one which gives satisfactory approximations of the piping movements.

Whenever differences occur between the approximations and actual movements, the approximation of the movement will always be the greater amount.

STEP 1 – CHART VERTICAL MOVEMENTS

Draw the piping system of Figure 1 and show all known vertical movements of the piping from its cold to hot, or operating, position (see Figure 11). These movements will include those supplied by the equipment manufacturers for the terminal point connections. For the illustrated problem, the following vertical movements are known:

Point A -- 2 in. up, cold to hot


Point B -- $\frac{1}{16}$ in. up, cold to hot

Point C -- $\frac{1}{8}$ in. down, cold to hot

H-4 - 0 in., cold to hot

The operating temperature of the system is given as 1,050°F.

FIGURE 11 – VERTICAL MOVEMENTS



Referring to the thermal expansion table (page 63), the coefficient of expansion for low-chrome steel at 1,050°F is .0946 in.


Calculate the movements at points **D** and **E** by multiplying the coefficient of the expansion by the vertical distance of each point from the position of zero movement on the riser **D E**:

$$55 \text{ ft.} \times .0946 \text{ in./ft.} = 5.2 \text{ in. up at D}$$

$$20 \text{ ft.} \times .0946 \text{ in./ft.} = 1.89 \text{ in. down at E}$$

STEP 2 – SECTION A-D

Make a simple drawing of the piping between two adjacent points of known movement, extending the piping into a single plane as shown for the portion between **A** and **D**.



The vertical movement at any hanger location will be proportional to its distance from the end points:

$$\Delta_1 = \frac{4}{31} \times 3.20 = .41 \text{ in.}$$

The vertical movement at **H-1** = .41 in. + 2 in.

$$\Delta_{H-1} = 2.41 \text{ in. up}$$

$$\Delta_2 = \frac{22}{31} \times 3.20 = 2.27 \text{ in.}$$

The vertical movement at **H-2** = 2.27 in. + 2 in.

$$\Delta_{H-2} = 4.27 \text{ in. up}$$


STEP 3 – MOVEMENT AT H-3

To calculate the vertical movement at **H-3**, multiply its distance from **H-4** by the coefficient of expansion.

$$\Delta_{H-3} = 40 \text{ ft.} \times .0946 \text{ in./ft.} = 3.78 \text{ in. up}$$

$$\Delta_{H-3} = 3.78 \text{ in. up}$$

FIG. 13A – MOVEMENT AT H-3





STEP 4 – SECTION E-J

The next section with two points of known movement is the length **E-J**. Movement at **E** was calculated as 1.89 in. down. Movement at **J** is equal to the movement at the terminal point **C** (1/8 in. down) plus the amount of expansion of the leg **C-J**:

$$\Delta_J = .125 \text{ in.} + (3.5 \text{ ft.} \times .0946 \text{ in./ft.}) = .46 \text{ in. down}$$

FIG. 13B – SECTION E-J



$$\Delta_7 = 3.5/42 \times 1.43 = 0.12 \text{ in.}$$

$$\Delta_7 = 30/42 \times 1.43 = 1.02 \text{ in.}$$

$$\Delta_{H-7} = 0.12 \text{ in.} + 0.46 \text{ in.} = 0.58 \text{ in. down}$$

$$\Delta_F = 1.02 \text{ in.} + 0.46 \text{ in.}$$

$$= 1.48 \text{ in. down}$$

$$\Delta_6 = 17/42 \times 1.43 = 0.58 \text{ in.}$$

$$\Delta_{H-6} = 0.58 \text{ in.} + 0.46 \text{ in.} = 1.04 \text{ in. down}$$

$$\Delta_5 = 32/42 \times 1.43 = 1.09 \text{ in.}$$

$$\Delta_{H-5} = 1.09 \text{ in.} + 0.46 \text{ in.}$$

$$= 1.55 \text{ in. down}$$

STEP 5

Draw the section **G-H**. The movement at **G** is equal to the movement at **F** minus the expansion of the leg **G-F**:

$$\Delta_G = 1.48 \text{ in. down} - (4 \text{ ft.} \times .0946 \text{ in./ft.})$$

$$\Delta_G = 1.10 \text{ in. down}$$

FIGURE 14 – SECTION G-H





FIGURE 15A – SECTION B-H



The movement at **H** is equal to the movement of the terminal point **B** (1/16 in. up) plus the expansion of the leg **B-H**:

$$\Delta_H = .0625 \text{ in. up} + (9 \text{ ft.} \times .0946 \text{ in./ft.})$$

$$\Delta_H = 0.91 \text{ in. up}$$


Since **H-9** is located at point **H**,

$$\Delta_{H-9} = \Delta_H = 0.91 \text{ in. up}$$

$$\Delta_Y = 12/23.1 \times 2.01 \text{ in.} = 1.04 \text{ in.}$$

$$\Delta_{H-8} = 1.10 \text{ in.} - 1.04 \text{ in.} = .06 \text{ in. down}$$

FIGURE 15B – SECTION G-H





SELECTION OF THE PROPER HANGER

Selection of the appropriate type hanger for any given application is governed by the individual piping configuration and job requirements. Job specifications covering hanger types, however, are of necessity written in broad terms, and some emphasis is placed on the good judgement of the hanger engineer to ensure a satisfactory, yet economical, system.

The type of hanger assemblies are generally classified as follows:

- (1) Flexible hangers, which include hangers of the constant support and variable spring types.
- (2) Rigid hangers, such as rod hangers and stanchions.
- (3) Rollers

The location of anchors and restraints is not usually considered a responsibility of the hanger designer. Since it is necessary to determine the location of anchors and restraints before accurate and final stress analysis is possible, they are considered a part of piping design.


FLEXIBLE HANGERS

When a pipe line expands vertically as a result of thermal expansion it is necessary to provide flexible pipe supports which apply supporting force throughout the expansion and contraction cycle of the system.

There are two types of Flexible hangers:

- Variable Spring
- Constant Support.

Constant Support hangers provide constant supporting force for piping throughout its full range of vertical expansion and contraction. This is accomplished through the use of a helical coil spring working in conjunction with a bell crank lever in such a way that the spring force times its distance to the lever pivot is always equal to the pipe load times its distance to the lever pivot.



Because of its constancy in supporting effect the Constant Support hanger is used where it is desirable to prevent pipe weight load transfer to connected equipment or adjacent hangers. Consequently, they are used generally for the support of critical piping systems.

Variable Spring hangers are used to support piping subject to vertical movement where Constant Supports are not required.

The inherent characteristic of a Variable Spring is such that its supporting force varies with spring deflection and spring scale. Therefore, vertical expansion of the piping causes a corresponding extension or compression of the spring and will

cause a change in the actual supporting effect of the hanger. The variation in supporting force is equal to the product of the amount of vertical expansion and the spring scale of the hanger. Since the pipe weight is the same during any condition, cold or operating, the variation in supporting force results in pipe weight transfer to equipment and adjacent hangers and consequently additional stresses in the piping system. When Variable Spring hangers are used, the effect of this variation must be considered.

Variable Spring hangers are recommended for general use on non-critical piping systems and where vertical movement is of small magnitude on critical systems. Accepted practice is to limit the amount of supporting force variation to 25% for critical system applications on horizontal piping.

To illustrate the difference in the effect of using a Variable Spring as compared with a Constant Support hanger, refer to the sample problem shown in Figure 1, page 5.

The load for Hanger H-1 was calculated as 5,363 lb. The vertical movement at H-1 was calculated as 2.41 in. up, from the cold to the hot position of the pipe.

If a Variable Spring hanger were used at H-1, the effect of the variation in supporting force would have to be considered. The amount of variation can be determined by multiplying the spring scale in lbs./in. by the amount of vertical expansion in inches.

For example, if the Anvil Figure B-268 Variable Spring hanger were considered, the proper spring size would be number 16 which has a spring scale of 1,500 lbs./in. (For convenience, we have neglected the weight of the pipe clamp, rod and hex nuts. In designing hangers for an actual problem, the weight of components should be added to the calculated load.)

The amount of variation is 1,500 lb/in. x 2.41 in. = 3,615 lb. Standard practice is to calibrate the hanger in such a way that when the piping is at its hot position the supporting force of the hanger is equal to the calculated load of the pipe. This means that the maximum variation in supporting force occurs when the piping is at its cold position, when stresses added to the piping as a result of variations in supporting forces are less critical.

The hot load for the variable spring, then is 5,363 lb.

As the direction of movement from cold to hot is upward, the cold load is 5,363 lb. + 3,615 lb., or 8,978 lb. Figure 18 shows the pipe and spring in both the cold and hot condition.

FIG. 17 – VARIABLE HANGER





FIGURE 18 – CONSTANT SUPPORT HANGER



The purpose of the considerations given to the variation in supporting effect is apparent when you recall that the pipe weight does not change throughout its cold to hot cycle, while the supporting force varies. In Figure 18 (hot condition), the supporting force is equal to the pipe weight. However, in the cold condition, the supporting force is 8,978 lb. while the pipe weight is 5,363 lb. The hanger would exert an unbalanced force on the pipe equal to the amount of variation, or 3,615 lb. Most of this force would be imposed directly on connection **A**, where limits are established for the force which may be applied.

Further, safe piping design must be based on total pipe stress which includes bending, torsional, shear, longitudinal, and circumferential stresses. The addition of large forces resulting from spring variations can cause stresses which will greatly reduce the factor of safety of the entire spring system.

It is possible to reduce the amount of variability by using a variable spring which has a smaller spring scale, as an Anvil Figure 98 (Variable Spring Hanger).

The #16 Fig. 98 has a spring scale of 750 lb/in., one-half that of the B268. The amount of variability would be reduced by one-half, or $2.41 \times 750 = 1,808$ lb. However, it should be obvious that even this change in supporting force is too great for the critical location at **H-1**.

The appropriate hanger type for **H-1** is a constant support hanger. This hanger would be calibrated to the calculated pipe weight. It would apply a constant supporting force, ensuring complete support of the pipe throughout the piping expansion.

That is, its supporting force would be 5,363 lb. when the pipe was at its cold position, and 5,363 lb. also when the pipe was at its hot position.

Hanger **H-2** has a calculated load of 1,870 lb. The vertical movement at this location is 4.27 in. up, cold to hot. Although the load may be considered slight, the magnitude of the vertical movement is great, and a considerable amount of supporting force change would occur if a variable spring were used.

For example, the appropriate size variable spring is a #12 Figure 98 (the 4.27 in. travel is beyond the travel capacity of the Fig. B-268), which has a spring scale of 225 lb. in. The amount of variation equals $4.21 \text{ in.} \times 225 \text{ lb./in.} = 947$ lb.

This variation, expressed as a percentage, is $947 \text{ lb.} / 1,870 \text{ lb.} \times 100$, or greater than 50%.

Unless the hanger engineer were willing to perform some rather elaborate stress calculations to determine the effect of this variation, it would be safer to apply the accepted rule which limits variability to 25% for critical systems, and rule out the selection of a variable spring in favor of the constant support type hanger.

The vertical movement of the pipe at **H-3** was calculated as 3.78 in. up, and the load as 8,521 lb.

In selecting the spring type for the hanger assembly, it should be recognized that any variation in supporting force will not produce bending stresses in the piping system. As the supporting forces at **H-3** and **H-4** are concurrent, no bending is produced as a result of spring variation at **H-3**. Rather, any supporting force variation will merely result in a corresponding load change at the rigid hanger **H-4**.


The hanger type for **H-3** may be variable spring type. It is only necessary that the variable spring have a travel capacity which is greater than the calculated pipe movement of 3.78 in.

Such a variable spring hanger is the Fig. 98, which has a working travel range of 5 inches.

As this assembly is a riser "trapeze" type, two spring units will be used, each supporting one-half the total load of 8,521 lb, or 4,261 lb. The appropriate size hanger is a #15 Fig. 98 with a spring scale of 540 lb. inch.

The amount of variation per spring is 3.78 in. $\times$ 540 lb./in., or 2,041 lb. The hot load setting for each hanger is equal to $\frac{1}{2}$ the calculated load, or 4,261 lb. As the direction of movement, cold to hot, is upward, the cold load setting will be 4,261 lb. + 2,041 lb. = 6,302 lb.

Figure 19 shows the supporting forces at **H-3** and **H-4** when the pipe is at its cold and its hot position. The weight of riser clamps, rods, etc., are not included, for convenience.



The design load for **H-3** should allow for a calculated cold load of 6,302 lb. $\times$ 2 = 12,604 lb.

The load at rigid hanger **H-4** is 1,823 lb. cold, 5,905 lb. hot. All hanger components should be designed for the larger load.

Variation in supporting forces at hangers **H-5**, **H-6**, **H-7** and **H-9** will produce reactions at connections **B** and **C**. As one of the requirements of the problem under study is that weight loads at **B** and **C** shall be zero, these hangers must be of the constant support type.

Although it holds true that at **H-8** any hanger force variation will cause weight loads at **B** and **C**, the load and movement at this hanger location are so slight that the spring variation effect can be considered negligible. The load was calculated as 872 lb, the movement as .06 in. down.

The variability of a #8 Fig. B-268 is .06 in. $\times$ 150 lb/in., or 9 lb. For practical purposes, a 9 lb. change in supporting force could be neglected and a variable spring selected for Hanger **H-8**.

The selection of hanger types for supports **H-1** through **H-9** in the sample problem illustrates the many considerations which should be given in selecting the appropriate flexible hanger at each support location for any major piping system.



In selecting flexible hanger types the engineer should consider that:

- Wherever constant support hangers are used, the supporting force equals the pipe weight throughout its entire expansion cycle, and no pipe weight reactions are imposed at equipment connections and anchors.
- Wherever variable spring hangers are used, the engineer must check to assure that the total variation in supporting effect does not result in harmful stresses and forces within the piping system.
- Where piping stresses and reactions are known to be close to allowable, the simplest and, in the long run, most economical type of flexible support is obviously the constant support hanger.
- Where piping stresses and end reactions are known to be low, variable spring hangers can be used satisfactorily for most non-critical piping support, and for the support of critical systems where vertical movements are of small magnitude.

RIGID HANGERS

Rigid hangers are normally used at locations where no vertical movement of the piping occurs.

The design considerations for a rigid hanger are pipe temperature, for selection of appropriate pipe clamp material, and load, for selection of components suitable for the pipe weights involved.

Pipe clamp material is usually carbon steel for temperatures up to 750°F, and alloy steel for temperatures above 750°F. Malleable iron pipe clamps may be used at temperatures up to 450°F.

For piping systems of low operating temperature, where vertical expansion is usually not a factor, the rigid hanger assembly components are selected and designed on the basis of calculated or approximated loads.

In some instances, however, the rigid hanger is used in a manner where it does more than merely support the pipe weight, but acts as a restraint against vertical piping movements. It is in these cases that the engineer should exercise care in the location of the rigid hanger and the design load he uses in the selection of components.


The location and effect of any restraint, guide or anchor on a high temperature and high pressure system is of necessity a function of the stress analyst. The indiscriminate placing of a restraining device on a piping system could alter the piping stresses and end reactions to a serious degree, changing a conservatively designed system into one which exceeds the limits of good design practices.

The hanger engineer, though not as well acquainted with the total stress picture of a piping system as is the stress analyst, must usually decide if the problem is of this "critical" nature, or whether the system under study is such that the effect of adding a restraint for convenience will be negligible. The decision is based on the factors of operating temperature, operating pressure, and the configuration of the system. Recognizing that pipe design is based on total pipe stress, one must determine whether the stresses produced by the addition of a rigid hanger, or vertical restraint, are critical.

This article is not intended to present a short-cut method for the stress analysis of a piping system. In any instance where it is not obvious to an engineer that he is dealing with a noncritical case, the problem should either be reviewed formally from a total stress view-point, or the decision to use a rigid hanger should be changed and a flexible support be utilized.

This article is intended to provide the engineer with a simple and quick method of deciding how he can most economically treat vertical thermal movement on a long, horizontal section of a non-critical piping system. Often, the problem can be expressed in the simple terms of whether he will be able to use a rigid hanger rather than a flexible hanger without producing obviously harmful stresses in the system.

Consider a simple example, shown in Figure 20, where the hanger engineer is confronted with the problem of how to best treat vertical movement resulting from thermal expansion of the riser. The horizontal sections at both the top and the bottom of the riser are of any hangers **H-2**, **H-3**, **H-4**, etc., should be spring hangers and which will be rigid hangers (vertical restraints in this instance). The solution must satisfy a condition that the bending stress produced by the restraining action of the hanger is no greater than some acceptable amount, say, in this instance, 10,000 psi.



For an operating temperature of 300°F, the expansion for carbon steel pipe is .0182in. per foot.


$$\Delta = 40\text{ft.} \times .0182\text{in./ft.} = .728\text{in. down.}$$

(see "Thermal Movement Calculations", page 11.)

From the Chart on Page 67 using values of 6 in. pipe and a deflection of $\frac{3}{4}$ in., read 17.5 ft. This is the minimum distance from the riser where the first rigid hanger may be placed for this problem.

If the locations of the hangers are fixed, as they are for this case, then **H-2** must be a spring hanger assembly because it is located only 12 ft. from the riser. Therefore, the nearest rigid hanger will be hanger **H-3**, located 29 ft. from the riser.


The amount of vertical movement at hanger **H-2** will be proportional to its distance between **H-3** and the riser, and can be approximated as shown in Figure 21:



Thus, **H-2** would be selected as a variable spring hanger for .43 in. of downward vertical movement, and **H-3** would be designed as a rigid hanger.

In the above problem the hanger locations were fixed. If this were not the case, and the hangers could be placed at any convenient location subject to usual hanger span limits, then **H-2** would be placed at any distance 17.5 ft. or more from the riser. This would satisfy the condition that a maximum bending stress of 10,000 psi would result from the restraining effect of the hanger. If the allowable effect was given as a higher stress, then the hanger could be placed closer to the riser; if lower, the nearest rigid hanger would be placed a greater distance from the riser.

If the hanger were located closer to the riser, a greater restraining force would be applied to the pipe by the hanger. As the location is changed to a greater distance from the riser, a lesser force is required. As illustrated in the following sample problem, this force can be an important factor in the design load of the hanger.




PROBLEM

Given 10 in. Sch. 40 pipe, and allowable bending stress of 10,000 psi produced by the restraining effect of the hangers, Find:

- (1) L-1 and L-2 the distances to the nearest rigid hangers **H-1** and **H-3**, see Figure 22.
- (2) The forces which the hangers must apply to the pipe to allow the 1/4 in. and 1/2 in. deflections resulting from the thermal expansion of the vertical pipe.


Solution:

From the Chart on page 67 using values of 1/2 in. deflection and 10 in. pipe, read L-1, as 18.5 ft., the distance from the riser to the rigid hanger **H-1**. Thus, at a distance of 18.5 ft., the hanger will exert sufficient force to deflect the pipe 1/2 in., producing 10,000 psi bending stress. (See Fig. 23).




Use the Chart on page 69 to find the value of force P. For a pipe size of 10 in. and a span of 18.5ft., read P as approximately 2,700 lb.

This force is applied by the pipe hanger **H-1**, and, therefore, must be included in the design load for **H-1**. In this instance, where the piping movement is in the downward direction, the force P is added to the pipe weight to be supported by Hanger **H-1**. If the pipe weight for **H-1** were calculated as 2,000 lb., then the design load for the hanger components is 2,000 lb.+2,700 lb., or 4,700 lb., as shown in Figure 24.




To solve for L-2 refer to the Chart on page 67 and, using values of 1/4 in. deflection and 10in. pipe, read L-2 as 13 ft., the distance to the proposed rigid hanger **H-3**. As discussed for H1 of this problem, hanger **H-3** must apply sufficient force to restrain the pipe vertically against the force resulting from the thermal expansion of the vertical piping above **H-2**.


The force P which is required at **H-3** can be determined from the Chart on page 69. Using values for 10 in. pipe and a 13 ft. span, P is approximately 3,800 lb. Since this force restrains the upward movement of the pipe, it should be checked against the pipe weight load to assure that the hanger assembly can exert a force equal to the difference of the force P and the pipe weight load.



To illustrate, assume that the pipe load at **H-3** was calculated as 5,000 lb. The difference between the pipe weight and the force **P** would equal 5,000 lb. - 3,800 lb. = 1,200 lb., as shown in Figure 26.



The design load used for hanger **H-3** should equal 5,000 lb, or pipe weight only in this instance. Where the vertical movement is in the upward direction, and the force **P** approaches the pipe weight load, the rigid hanger will tend to unload. This is, as the pipe expands upward the net force applied to the pipe by the hanger becomes less. If the force **P** becomes greater than the pipe weight at the hanger, the net force on the hanger becomes compressive rather than tensile. When the system has expanded its full amount, the pipe will tend to lift from the hanger, and the supporting effect of the hanger will be zero.




If the pipe weight for the sample problem had been calculated as 3,000 lb., then the net force is 3,000 lb. - 3,800 lb., or 800 lb. upward, as shown in Figure 27. The hanger, in this case, would not be considered as a support for the pipe, but a vertical restraint against upward movement. Therefore, either a greater span should be used in order to reduce the force **P**, or a spring hanger should be used if **L-2** is maintained as 13 ft., in order to provide support and allow the piping to move upward at this hanger location. Using the values of **L-1** and **L-2**, as determined in the original problem, the forces **P**

at each hanger are as shown in Figure 28.

The forces at **H-1** and **H-3** have been discussed in some detail, but it should also be noted that the design load for **H-2** should include these forces as well. For this example, the design load for **H-2** equals the pipe weight plus 3,800 lb., minus 2,700 lb, or design load = pipe weight load + 1,100 lb.

In the preceding problems, the allowable bending stress due to the restraining effect of the hanger was given as 10,000 psi. This allowable stress will, of course, vary with the individual case.


Where the stress is other than 10,000 psi, use the Chart on page 67 to read the minimum span, and multiply the span in



feet by the factor indicated in the Chart below for the specific stress.

Correction Factor for Stresses Other Than 10,000 PSI	
For Bending Stress (PSI) Of:	Multiply Length By:
2,000	2.24
3,000	1.83
4,000	1.58
5,000	1.41
6,000	1.29
8,000	1.12
10,000	1.00
12,000	.91
15,000	.82
20,000	.71

ILLUSTRATIVE EXAMPLE



Given:

4in. Sch. 40 pipe, $\Delta = 3$ in., and 3,000 psi maximum bending stress through the restraining effect of the first rigid hanger.


Find:

L, the distance from the riser to the first rigid support.

From the Chart on page 67 using values of 4 in. pipe and 3 in. deflection, read a span of 29 ft. This span is based on a stress of 10,000 psi, and, to correct for 3,000 psi, refer to the correction factor chart on the previous page. For a stress of 3,000 psi, the correction factor for spans is 1.83. Multiplying 29 ft. by 1.83, the span for 4 in. pipe with 3 in. deflection at 3,000 psi is 29×1.83 , or 53 ft. Thus, L, the minimum distance to the first rigid hanger, is 53 ft.

The first rigid hanger in the above problem will be **H-5**, located 60 ft. from the riser. The force P required to restrain the piping vertically can be determined from the Chart on page 69 as about 83 lb., using values of 4 in. pipe and a span of 60 ft. The effect of this force will be considered negligible for this problem.

The vertical movements at hanger locations between **H-5** and the riser are as shown in Figure 30.




The above results are based on an approximate but conservative analysis. Whenever the appropriate charts are used, the values listed should assist the engineer in arriving at an economical, safe design for any rigid hanger assembly.

The examples described represent situations not frequently encountered in pipe support design, but do point out that the rigid hanger in some instances is more than a simple pipe support, and that good design must allow for all applicable conditions.

ROLLERS


The pipe attachment and structural attachment of a hanger assembly should be such that they will permit the hanger rod to swing to allow for lateral movement of the piping where horizontal pipe expansion is anticipated.

In some instances, where piping expansion is slight and hanger rods are long, the swing permitted by the pivoting of the rod at the upper and lower connections is sufficient, as shown in Figure 31.




In other instances the angularity caused by the horizontal piping movements can appreciably effect the position of the piping system, and can cause harmful horizontal forces within the piping system.

In Figure 32, note that, because of the large axial piping movement and short hanger rod, the pipe is pulled $3/4$ in. off elevation when it expands 6 in. horizontally.



The condition shown in Figure 32 also places a horizontal force component into the piping system. For example, assume a pipe weight of 1000 lb. for the above hanger, as in Figure 33.


FIGURE 33 - HORIZONTAL FORCE



The 258 lb. horizontal force by itself may not be of great consequence, but where there is a series of hangers located on the same long section of pipe, the effect of the total horizontal force can be serious. (See Figure 34)

$$\text{Total horizontal force} = 86 + 172 + 258 + 344 = 860 \text{ lb}$$

FIGURE 34 - TOTAL HORIZONTAL FORCE




Certainly, for any system subject to horizontal expansion, the rod angularity from the vertical will result in a horizontal force component. The point where this angularity becomes critical cannot be defined for every case, but accepted practice is to limit the swing from the vertical to 4°.

Where this angle is greater than 4°, a pipe roller should be considered.

Pipe roller supports are of two basic types: those which attach to overhead structure, and those which are placed beneath the pipe as base supports (see Figure 35).

FIGURE 35 - PIPE ROLLERS



It should be noted that where rollers are required, the pipe operating temperatures usually are sufficiently high that pipe insulation is used to reduce heat loss and for personnel protection. In these cases a pipe covering protection saddle should be used in conjunction with the rollers to keep the insulation from crushing.

Where the piping is not insulated, the pipe will rest directly on the roller. This is common practice for the support of long transmission lines where the gas or fluid transported is not of elevated operating temperatures, but where the pipe run is subject to some change in ambient temperature, as from summer to winter variances.

For example, a pipe line 300 ft. long subject to ambient changes from 70° F to 110° F expands only .00306 in./ft. from the low to high temperature. Multiplied by 300 ft., however, the total axial expansion is 300 ft. x .00306 in./ft., or .918 in.


In instances of this nature, rollers will be used, but the pipe covering protection saddles will not be required.

For economy in the support of low pressure, low temperature systems, and long outdoor transmission lines, hanger spans may be based on the allowable total stresses of the pipe and the amount of allowable deflection between supports.

In steam lines with long spans the deflection caused by the weight of the pipe may be large enough to cause an accumulation of condensate at the low points of the line. Water lines, unless properly drained, can be damaged by freezing. These conditions can be avoided by erecting the line with a downward pitch in such a manner that succeeding supports are lower than the points of maximum deflection in preceding spans as shown in Figure 36.

The stresses indicated in the Chart on page 65 and the Chart on page 66 are bending stresses resulting from the weight of the pipe between supports. It should be realized that this

FIGURE 36 - DEFLECTIONS



stress must be considered with other stresses in the piping, such as those due to the pressure of the fluid within the pipe, the bending and torsional stresses resulting from thermal expansion, etc., in order to design the system for total allowable stress.

The stresses and deflections indicated in the Charts on pages 64, 65 and 66 are based on a single span of pipe with free ends, and make no allowances for concentrated loads of valves, flanges, etc., between hangers.

The stress and deflection values shown in the Charts on pages 64, 65 and 66 are based on a free end beam formula and reflect a conservative analysis of the piping. Actually, the pipe line is a continuous structure partially restrained by the pipe supports, and the true stress and deflection values lie between those calculated for the free end beam and a fully restrained structure.

The deflections and bending stress values indicated represent safe values for any schedule pipe from Sch. 10 to XS pipe.

For fluids other than water, the bending stress can be found by first finding the added stress caused by water from the Charts on pages 65 and 66 and multiplying by the specific gravity of the fluid. Add this to the stress value of the pipe empty.

For lines which are thickly insulated, find the deflection or bending stress resulting from the weight of pipe bare and multiply by a ratio of the weight of pipe per foot plus insulation to the weight of bare pipe per foot.

To illustrate the use of the deflection and stress charts, consider the following examples:

PROBLEM:

Find: The maximum economical hanger spacing for a 10 in. non-insulated steam transmission line, 1,200 ft. long, which will provide sufficient drainage with minimum deflection within an allowable bending stress limit of 10,000 psi. The maximum difference in elevations of the ends of the line is 5ft.

SOLUTION:

$$\text{Maximum Slope} = \frac{(5 \text{ ft.} \times 12 \text{ in./ft.})}{1,200 \text{ ft.}} = 1 \text{ in./20ft.}$$


From the Chart on page 64 find the intersection of the Curve 1 in. in 20 ft., and 10 in. nominal pipe size. Read left to find the allowable pipe span of 40 ft.

From the Chart on page 65, the bending stress for 10 in. pipe with a support span of 40 ft. is 3,250 psi, which is below the allowable 10,000 psi.

ANSWER:

Span = 40 ft .

FIGURE 37 - DETERMINATION OF SPAN



PROBLEM:

Find: The maximum economical spacing to provide sufficient drainage for an 8 in. water filled line 600 ft. long. The allowable bending stress is 6,000 psi, and the difference in elevations between the ends of the pipe line is 5 ft.

SOLUTION:

$$\text{Maximum Slope} = \frac{(5 \text{ ft.} \times 12 \text{ in./ft.})}{600 \text{ ft.}} = 1 \text{ in./10ft.}$$

From the Chart on page 64, find the intersection of the curve 1 in. in 10 ft. and 8 in. pipe, and read left to a span of 43 ft.

From the Chart on page 66, for an 8 in. water filled line with a support span of 43 ft., the bending stress is 8,300 psi, which is greater than the allowable 6,000 psi. Therefore, the maximum span should be based on the allowable bending stress of 6,000 psi.

Referring to the Chart on page 66, the maximum span for 8 in. pipe and an allowable bending stress of 6000 psi is 37 ft.

ANSWER:

Span = 37 ft

PROBLEM:

Find: The maximum spacing and slope for a 6 in. water filled line where the allowable bending stress is 10,000 psi. The difference in the elevations of the ends of the system is not limited.

From the Chart on page 66, the maximum span for a 6 in. water filled line with an allowable bending stress of 10,000 psi is 42 ft.

On the Chart on page 64 read from the 42 foot span value to the 6in. pipe curve. Interpolating between the slope curves 1 in. in 10 ft. and 1 in. in 5 ft., read the slope 1 in. in 6 ft.

ANSWER:

Span = 42 ft

Pipe is sloped at 1 in. in 6 ft. (A difference in elevation of 7 in. between supports.)



TYPICAL PIPE HANGER SPECIFICATION

1. SCOPE

This specification shall apply for the design and fabrication of all hangers, supports, anchors, and guides. Where piping design is such that exceptions to this specification are necessary, the particular system will be identified, and the exceptions clearly listed through an addendum which will be made a part of the specification.

2. DESIGN

- (a) All supports and parts shall conform to the latest requirements of the ASME Code for Pressure Piping B31.1.0, and MSS Standard Practice SP-58, SP-69, SP-89 and SP-90 except as supplemented or modified by the requirements of this specification.
- (b) Designs generally accepted as exemplifying good engineering practice, using stock or production parts, shall be utilized wherever possible.
- (c) Accurate weight balance calculations shall be made to determine the required supporting force at each hanger location and the pipe weight load at each equipment connection.
- (d) Pipe hangers shall be capable of supporting the pipe in all conditions of operation. They shall allow free expansion and contraction of the piping, and prevent excessive stress resulting from transferred weight being introduced into the or connected equipment.
- (e) Wherever possible, pipe attachments for horizontal piping shall be pipe clamps.
- (f) For critical high-temperature piping, at hanger locations where the vertical movement of the piping is $\frac{1}{2}$ in. or more, or where it is necessary to avoid the transfer of load to adjacent hangers or connected equipment, pipe hangers shall be an approved constant support design, as Anvil Fig. 80-V and Fig.81-H Where transfer of load to adjacent hangers or equipment is not critical, and where the vertical movement of the piping is less than $\frac{1}{2}$ in., variable spring hangers may be used, provided the variation in supporting effect does not exceed 25% of the calculated piping load through its total vertical travel.
- (g) The total travel for constant support hangers will be equal to actual travel plus 20%. In no case will the difference between actual and total travel be less than 1 in. The constant support hanger will have travel scales on both sides of the support frame to accommodate inspections.
- (h) Each constant support hanger should be individually calibrated before shipment to support the exact loads specified. The calibration record of each constant support shall be maintained for a period of 20 years to assist the customer in any redesign of the piping system. Witness marks shall be stamped on the Load Adjustment Scale to establish factory calibration reference point.
- (i) In addition to the requirements of ASTM A-125 all alloy springs shall be shot peened and examined by magnetic particle. The spring rate tolerance shall be $\pm 5\%$. All three critical parameters (free height, spring rate and loaded height) of spring coils must be purchased with a C.M.T.R. and be of domestic manufacture.
- (j) Constant supports should have a wide range of load adjustability. No less than 10% of this adjustability should be provided either side of the calibrated load for plus or minus field adjustment. Load adjustment scale shall be provided to aid the field in accurate adjustment of loads. Additionally, the constant support should be designed so that the load adjustments can be made without use of special tools and not have an impact on the travel capabilities of the supports.
- (k) Constant supports shall be furnished with travel stops which shall prevent upward and downward movement of the hanger. The travel stops will be factory installed so that the hanger level is at the "cold" position. The travel stops will be of such design as to permit future re-engagement, even in the event the lever is at a position other than "cold", without having to make hanger adjustments.
- (l) For non-critical, low temperature systems, where vertical movements up to 2 in. are anticipated, an approved pre-compressed variable spring design similar to Anvil Fig. B268 may be used. Where the vertical movement is greater than 2 in., a variable spring hanger similar to Anvil Fig. 98 may be used. Where movements are of a small magnitude, spring hangers similar to Anvil Fig. 82 may be used.
- (m) Each variable spring shall be individually calibrated at the factory and furnished with travel stops. Spring coils must be square to within 1° to insure proper alignment. Each spring coil must be purchased with a C.M.T.R. and be of domestic manufacture.
- (n) All rigid rod hangers shall provide a means of vertical adjustment after erection.
- (o) Where the piping system is subject to shock loads, such as seismic disturbances or thrusts imposed by the actuation of safety valves, hanger design shall include provisions for rigid restraints or shock absorbing devices of approved design, such as Anvil Fig. 200 shock and sway suppressor.
- (p) Selection of vibration control devices shall not be part of the standard hanger contract. If vibration is encountered after the piping system is in operation, appropriate vibration control equipment shall be installed.
- (q) Hanger rods shall be subject to tensile loading only (see Table III, Page 37). At hanger locations where lateral or axial movement is anticipated, suitable linkage shall be provided to permit swing.

- (r) Where horizontal piping movements are greater than ½ in. and where as the hanger rod angularity from the vertical is less than or equal to 4° from the cold to hot position of the pipe, the hanger pipe and structural attachments shall be offset in such manner that the rod is vertical in the hot position. When the hanger rod angularity is greater than 4° from vertical, then structural attachment will be offset so that at no point will the rod angularity exceed 4° from vertical.
- (s) Hangers shall be spaced in accordance with Tables I and II (Shown below).
- (t) Where practical, riser piping shall be supported independently of the connected horizontal piping. Pipe support attachments to the riser piping shall be riser clamp lugs. Welded attachments shall be of material comparable to that of the pipe, and designed in accordance with governing codes.
- (u) Supports, guides, and anchors shall be so designed that excessive heat will not be transmitted to the building steel. The temperature of supporting parts shall be based on a temperature gradient of 100°F per 1 in. distance from the outside surface of the pipe.
- (v) Hanger components shall not be used for purposes other than for which they were designed. They shall not be used for rigging and erection purposes.
- (w) Hydraulic Snubbers — The hydraulic units shall have a temperature stable control valve. The valve shall provide a locking and bleed rate velocity that provides for tamper proof settings. The fluid system shall utilize a silicone fluid with proven compatible seals made of approved compounds. The reservoir shall provide a fluid level indicator for exact reading of reservoir fluid level in any snubber orientation.

The valve device shall offer a minimum amount of resistance to thermal movement. Any shock force shall cause the suppressor valve to close. With the suppressor valve closed the fluid flow shall essentially stop, thereby causing the unit to resist and absorb the disturbing forces. After the disturbing forces subside the

suppressor valve shall open again to allow free thermal movement of the piping. The suppressor shall have a means of regulating the amount of movement under shock conditions up to the design load for faulted conditions without release of fluid. The suppressor design shall include a fluid bleed system to assure continued free thermal movement after the shock force subsides. The suppressor shall have a hard surfaced, corrosion resistant piston rod supported by a bronze rod bushing. The assembly shall have self-aligning lubricated bushings and shall be designed so that it is capable of exerting the required force in tension and compression, utilizing the distance.

- (y) Paint — Variable spring and constant support units will be furnished prime painted. All other material will receive one shop coat of a red chromate primer meeting the requirements of Federal Specification TT-P-636. For corrosive conditions, hangers will be galvanized or painted with Garbo-Zinc #11.

3. HANGER DESIGN SERVICE

Hangers for piping 2½ in. and larger, and all spring support assemblies, shall be completely engineered.

- (a) Engineered hanger assemblies shall be detailed on 8½ in. x 11 in. sheets. Each sketch will include a location plan showing the location of the hanger in relation to columns of equipment. Each sketch will include an exact bill of material for the component parts making up each assembly.
- (b) Each engineered hanger assembly will be individually bundled and tagged as far as practical, ready for installation. Hanger material for piping 2 in. and smaller shall be shipped as loose material, identified by piping system only. A piping drawing marked with approximate hanger locations and types, and hanger sketches showing typical support arrangements will be furnished.
- (c) Hanger inspections shall be performed in accordance with MSS-SP89 (Section 7.7) and ASME B31.1 (Appendix V).

TABLE I

MAXIMUM HORIZONTAL SPACING BETWEEN PIPE SUPPORTS FOR STANDARD WEIGHT STEEL PIPE

Nom. Pipe Size (in) —>	½	¾	1	1 ½	2	2 ½	3	3 ½	4	5	6	8	10	12	14	16	18	20	24
Max Span, Water Serv. (ft.) —>	7	7	7	9	10	11	12	13	14	16	17	19	22	23	24	27	28	30	32
Max Span, Vapor Serv. (ft.) —>	8	9	9	12	13	14	15	16	17	19	21	24	26	30	32	35	37	39	42

TABLE II

MAXIMUM HORIZONTAL SPACING BETWEEN COPPER TUBING SUPPORTS

Nom. Pipe Size (in) —>	½	¾	1	1 ¼	1 ½	2	2 ½	3	3 ½	4
Max Span, Water Serv. (ft.) —>	5	5	6	7	8	8	9	10	11	12
Max Span, Vapor Serv. (ft.) —>	6	7	8	9	10	11	13	14	15	16



FIELD ENGINEERING WALKDOWNS

Critical piping systems shall be observed visually, as frequently as deemed necessary, and any unusual conditions shall be brought to the attention of the operating company. Only qualified and trained personnel shall be utilized for these observations. Observations shall include determination of interferences with or from other piping or equipment, vibrations, and general condition of the supports, hangers, guides, anchors, supplementary steel, and attachments, etc.

Hanger position scale readings of variable and constant support hangers shall be determined periodically. It is recommended that readings be obtained while the piping is in its fully hot position, and if practical, when the system is reasonably cool or cold sometime during the year as permitted by plant operation. Pipe temperature at time of reading hangers shall be recorded.

Variable and constant support hangers, vibration control devices, shock suppressors, dampeners, slide supports and rigid rod hangers shall be maintained in accordance with the limits specified by the manufacturers and designers. Maintenance of these items shall include, but not necessarily be limited to, cleaning, lubrication and corrosion protection.

Pipe location readings and travel scale readings of variable and constant support hangers shall be recorded on permanent log sheets in such a manner that will be simple to interpret. Records of settings of all hangers shall be made before the original commercial operation of the plant and again after startup.

After visually observing piping, hangers, and supports, repairs and/or modifications are to be carried out by qualified maintenance personnel for all of the following items:

- A. Excessively corroded hangers and other support components
- B. Broken springs or any hardware item which is part of the complete hanger or support assembly
- C. Excessive piping vibration; valve operator shaking or movements
- D. Piping interferences
- E. Excessive piping deflection which may require the installation of spring units having a greater travel range
- F. Pipe sagging which may require hanger adjustment or the reanalysis and redesign of the support system
- G. Hanger unit riding at either the top or the bottom of the available travel
- H. Need for adjustment of hanger load carrying capacity
- I. Need for adjustments of hanger rods or turnbuckle for compensation of elevation changes
- J. Loose or broken anchors

- K. Inadequate clearances at guides
- L. Inadequate safety valve vent clearances at outlet of safety valves
- M. Any failed or deformed hanger, guide, U-bolt, anchor, snubber, or shock absorber, slide support, dampener, or supporting steel
- N. Leaks at flanges, valve bonnets and valve stems
- O. Excessively corroded valves
- P. Defective traps, separators, strainers, silencers, flexible hose, flexible fittings, and water level gage glasses
- Q. Unacceptable movements in expansion joints

The use of photographs can be an important tool in recording piping systems, hangers and supports. These can be stored with the other records and are beneficial for future reference and will establish a system history for future reference.

Each plant should maintain and file the following documentation that exists for each unit:

- A. current piping drawings
- B. construction isometrics
- C. pipeline specifications covering material, outside diameter, and wall thickness
- D. flow diagrams
- E. support drawings
- F. support setting charts
- G. records of any piping system modifications

NUCLEAR PIPE SUPPORTS

Nuclear pipe support design has evolved from a relatively simple design-by-rule approach to a complex design-by-analysis approach. Pipe support design has presented some major challenges for the nuclear power industry. The ASME Boiler and Pressure Vessel Code, Section III, Division 1, Subsection NF, "Component Supports", contains very detailed requirements for nuclear pipe supports. The NF Code contains requirements for material design, fabrication and installation, examination, nameplates, stamping, and reports. The principal differences between nuclear and non-nuclear pipe supports lie in the more sophisticated and demanding design, analysis, additional non-destructive examination (NDE), quality assurance, and Code inspection and stamping. However, the type of pipe supports and materials used for nuclear pipe supports are essentially the same as those used for non-nuclear.

The design of nuclear pipe supports is dependent upon a piping analysis which provides the appropriate support loading and displacements. The pipe support designer/analyst must be aware of specific assumptions that the piping analyst used in performing the piping analysis. Typical assumptions are:

- (1) no excessive support mass on pipe;
- (2) support is provided in directions shown with type support shown;
- (3) support is sufficiently rigid to permit decoupling of the analysis of the support from the pipe;
- (4) support allows for essentially unrestricted movement in the unsupported direction.

Nuclear pipe supports are designed to the same loadings that fossil power plants experience, i.e., thermal, deadweight, thermal equipment displacement loadings, and operating loadings, including turbine trip, rapid valve closure, etc. In addition to these normal loadings, nuclear power plants require detailed analysis for seismic loadings on the piping system. This detailed seismic requirement results in the significant difference between the design of nuclear pipe support versus a conventional power plant.

The seismic requirement resulted in piping systems which were considerably stiffer when compared to similar systems without seismic requirements. This was the direct result of providing additional lateral and vertical restraints to resist the seismic loadings on the piping system. The additional restraints reduced seismic stresses, but resulted in increased thermal stresses. To minimize this impact, pipe snubbers were utilized in piping systems. Snubbers are devices which are essentially only active during an earthquake or other dynamic event and offer little resistance to the slow pipe movement resulting from thermal growth. Although snubbers have seen limited use in conventional plants, their primary use was in nuclear facilities. Since the use of snubbers requires a significant amount of functional testing and inspection, their use has been considerably reduced. In addition, most nuclear plants have initiated programs to eliminate as many snubbers as possible. Although the use of snubbers should generally be avoided, they may, in certain circumstances, present the most simple and cost effective solution.

SEISMIC SUPPORTS

The following is for reference only. Refer to MSS-SP127 for detailed requirements). Seismology and its effect on building structures, components and attachments affect almost every building code and standard. Increasingly, codes and standards are requiring seismic restraints in critical areas. There are several codes and standards across the country that contain entire sections devoted to seismic restraints and bracing. Some of the more common codes are the Uniform Building Code 1991 and the 1991 California Building Standard Code (CAC Title 24, Part II).

The progressive CAC Title 24 states in Section 2330 (a):

"Every building or structure and every portion thereof, including the nonstructural components, shall be designed and constructed to resist stresses and limit deflections calculated on the basis of dynamic analysis or equivalent static lateral forces analysis ..."

It continues in Section 2336(a)

"Parts and portions of structure and their attachments, permanent nonstructural components and their attachments, and the attachments for permanent equipment supported by a structure shall be designed to resist the total design lateral seismic force, F_p , given by the following formula:

$F_p = Z \times I \times C_p \times W_p$, Where:

F_p = Total Design Lateral Seismic Force.

Z = Seismic Zone Factor, Numerical Coefficient as shown in Table 23-1 and derived from Seismic Zones Map on Page 26.

I = Importance Factor, as shown on Table No. 23-L and derived from Occupancy Categories shown on Table No. 23-K.

C_p = Horizontal Force Factor ("... conduit, ductwork and piping ..." has a C_p of 0.75 per the CAC Title 24 and a C_p of 0.45 per the 1991 Uniform Building Code).

W_p = Weight of Element or Component (Weight of pipe, ductwork and conduit)

The following conduit, ductwork and piping do NOT require bracing per CAC Title 24, Part II: Table No. 23-P, note 12.

- a. Gas piping less than 1 in. diameter.
- b. Piping in boiler and mechanical equipment rooms less than 1.25 in. inside diameter.
- c. All piping less than 2.5 in. inside diameter.
- d. All piping suspended by individual hangers 12 in. or less in length from the top of pipe to the bottom of the support for the hanger.
- e. All electrical conduit less than 2.5 in. inside diameter.
- f. All rectangular air-handling ducts less than 6 sq. ft. in cross-sectional area.
- g. All round air handling ducts less than 28 in. in diameter.
- h. All ducts suspended by hangers 12 in. or less in length from the top of the duct to the bottom of the support for the hanger.



TABLE 23-K
OCCUPANCY CATEGORIES

- (I) Essential Facilities (Essential facilities are those structures which are necessary for the emergency operations subsequent to a natural disaster.)
- Hospitals and other medical facilities having surgery and emergency treatment areas.
 - Fire, Sheriff and Police Stations
 - Municipal, county and state government disaster operation and communication centers deemed vital in emergencies.
 - Tanks of other structures containing, housing or supporting water or other fire-suppression materials or equipment required for the protection of essential or hazardous facilities, or special occupancy structures.
 - Emergency vehicle shelters and garages.
 - Standby power-generating equipment for essential facilities.
- (II) Hazardous Facilities
- Structures housing, supporting or containing sufficient quantities of toxic or explosive substances to be dangerous to the safety of general public if released.
- (III) Special Occupancy Structure
- Covered structures whose primary occupancy is public assembly - capacity ≥ 300 persons.
 - Buildings for schools through secondary or day-care centers - capacity ≥ 250 students.
 - Buildings for colleges or adult education schools - capacity ≥ 500 students
 - Medical facilities with 50 or more resident incapacitated patients, not included above.
 - Jails and detention facilities.
 - All structures with occupancy $\geq 5,000$ persons.
 - Structures and equipment in power-generating stations and other public utility facilities not included above, and required for continued operation.
- (IV) Standard Occupancy Structure
- All structures having occupancies or functions not listed above.

TABLE 23-L

EARTHQUAKE IMPORTANCE FACTOR (I), BASED ON OCCUPANCY CATEGORY





Occupancy Category	1991 Uniform Building Code	CAC Title 24
I. Essential Facility	1.25	1.50
II. Hazardous Facilities	1.25	1.50
III. Special Occupancy Structures	1.00	1.15
IV. Standard Occupancy Structures	1.00	1.00

TABLE 23-I

SEISMIC ZONE FACTOR "Z"

Zone -->	1	2A	28	3	4
Zone Factor -->	0.075	0.15	0.20	0.30	0.40

Refer to zone map on the following page for general information purposes, or visit "<http://eqhazmaps.usgs.gov>" for current seismic zone information.



The maps shown above are for general information purposes, please visit "<http://eqhazmaps.usgs.gov>" for current seismic zone information.

1994 Uniform Building Code zone map. Zones are identified by the numbers from 0 to 4.

Seismic zone factors are assigned to each zone; Zone 0 = 0, Zone 1 = 0.075, Zone 2A = 0.15, Zone 2B = 0.20, Zone 3 = 0.3, and Zone 4 = 0.4.

Each zone also has specific structural detailing requirements.

PIPE SUPPORTS — GROOVED PIPING

When designing the hangers, supports and anchors for a grooved end pipe system, the piping designer must consider certain unique characteristics of the grooved type coupling in addition to many universal pipe hanger and support design factors. As with any pipe system, the hanger or support system must provide for

- 1) the weight of the pipe, couplings, fluid and pipe system components;
- 2) reduce stresses at pipe joints; and
- 3) permit required pipe system movement to relieve stress.

The following special factors should be considered when designing hangers and supports for a grooved end pipe system.

PIPE HANGER SPACING:

The following charts show the maximum span between pipe hangers for straight runs of standard weight steel pipe filled with water or other similar fluids.

Do not use these values where critical span calculations are made or where there are concentrated loads between supports.

PIPE HANGER SPACING	
FOR STRAIGHT RUNS WITHOUT CONCENTRATED LOADS AND WHERE FULL LINEAR MOVEMENT IS NOT REQUIRED.	
Nominal Pipe Size Range	Max.Span Between Hangers
¾" — 1"	7'
1¼" — 2"	10'
2½" — 4"	12'
5" — 8"	14'
10" — 12"	16'
14" — 16"	18'
18" — 24"	20'

PIPE HANGER SPACING											
FOR STRAIGHT RUNS WITHOUT CONCENTRATED LOADS AND WHERE FULL LINEAR MOVEMENT IS REQUIRED											
Nominal Pipe Size Range	Pipe Length in Feet										
	*Average Hangers per Pipe Length (Evenly Spaced)										
	7'	10'	12'	15'	20'	22'	25'	30'	35'	40'	
¾" — 1"	1	2	2	2	3	3	4	4	5	6	
1¼" — 2"	1	2	2	2	3	3	4	4	5	6	
2½" — 4"	1	1	2	2	2	2	2	3	4	4	
5" — 8"	1	1	1	2	2	2	2	3	3	3	
10" — 12"	1	1	1	2	2	2	2	3	3	3	
14" — 16"	1	1	1	2	2	2	2	3	3	3	
18" — 24"	1	1	1	2	2	2	2	3	3	3	

*No pipe length should be left unsupported between any two couplings.

COUPLING FLEXIBILITY:

The grooved coupling's capability to allow angular and rotational movement within the coupling joint must be considered when deciding hanger and support locations. Spring hangers and supports providing for movement in more than one plane are often used to allow the pipe system to move without introducing additional stress into the pipe system.

Figure 38 demonstrates the need for each pipe length in a grooved system to be supported. The sag due to the flexibility of the Gruvlok joint could be eliminated with the proper positioning of hangers on both "L1" and "L2".





Figure 39 illustrates the effect of pump oscillation on a piping system. A spring hanger should be used to support the pipe section and also respond to the induced vibrations. The couplings in the horizontal run above the riser, should accommodate the deflection without transmitting bending stresses through the pipe system.



PRESSURE THRUSTS

Gruvlok couplings react to the application of system pressure and restrain the pipe ends from separation due to the pressure force. However, the coupling joint may not be in the self-restraining configuration prior to the application of system pressure. The Gruvlok coupling does not restrain adjacent pipe sections from separation due to pressure forces until the coupling key sections engage the groove walls.

Random coupling joint installation will produce installed coupling conditions ranging from pipe ends fully butted to fully separated to the maximum available gap. Thus, only after system pressurization will the self-restraining function of the coupling be in effect.

The designer must account for the movement to be encountered when the system is pressurized and the joints are fully separated. Anchor and guide positions must be defined to direct the pipe joint movement such that it is not detrimental to the pipe system.

The effect of pressure thrust are shown in the following examples.




FIGURE 40 - PRESSURE THRUST




Figure 40 - The coupling joints have been installed butted or partially open. When pressurized the pipe ends in the coupling joints will separate to the maximum amount permitted by the coupling design.

The coupling key sections will make contact with the groove walls and restrain the pipe from further separation.

The movement at each coupling joint will add with all other joints and produce ΔL .

FIGURE 41 - PRESSURE THRUST




Figure 41 - In the system shown here, the pipe will move and deflect at the elbow joint due to pressure thrust.

The pipe designer must assure himself that the system has the capability of deflecting sufficiently to absorb this movement without introducing additional stresses into the pipe system.

In the deflected condition shown, temperature increases would produce further expansion of the pipe system thus increasing the deflection.

FIGURE 42 - PRESSURE THRUST




Figure 42 - To restrain this system provide a pressure thrust anchor at "R1" to resist the pressure thrust acting through the tee "D1" at the cap "C". Provide a hanger at Point "R2", or a base support at Point "D2" to support the vertical column. If the offsets L_1 , L_2 , and L_3 are of adequate length to handle expected pipe movements, no additional anchoring is required. Thermal movement of the pipe system should also be considered, and intermediate anchors located as required, to direct the pipe movement so as to prevent introducing bending stresses into the system.

FIGURE 43 - PRESSURE THRUST




Figure 43 - Anchor at "A" to support weight of vertical water column. Use spring hanger at "D" and "E" to allow movement of vertical piping.

Anchors at "B" and "C" if offsets at L_1 and L_2 are insufficiently long to handle expected pipe movements.

FIGURE 44 - LATERAL RESTRAINT




Figure 44 [Lateral Restraint] - A grooved coupling joint installed in a partially deflected condition between anchor locations will deflect to its fully deflected condition when pressurized. Hangers and supports must be selected with consideration of the hanger's capability to provide lateral restraint.

Light duty hangers, while acceptable in many installations, may deflect against the application of lateral forces and result in "snaking" conditions of the pipe system.



RISER DESIGN:

Risers assembled with Gruvlok couplings are generally installed in either of two ways. In the most common method, the pipe ends are butted together within the coupling joint. Note that when installing risers, the gasket is first placed onto the lower pipe and rolled back away from the pipe end prior to positioning the upper pipe. Anchoring of the riser may be done prior to pressurization with the pipe ends butted or while pressurized, when, due to pressure thrust, the pipe ends will be fully separated.

An alternative method of riser installation is to place a metal spacer of a predetermined thickness, between the pipe ends when an additional length of pipe is added to the riser stack. The upper pipe length is anchored, the spacer removed and the coupling is then installed. This method creates a predetermined gap at each pipe joint which can be utilized in pipe systems where thermal movement is anticipated and in systems with rigid (threaded, welded, flanged) branch connections where shear forces due to pressure thrust could damage the rigid connections.


The following examples illustrate methods of installing commonly encountered riser designs.

RISERS *Without* Branch Connections

Install the riser with the pipe ends butted.

Locate an anchor at the base of the riser (A) to support the total weight of the pipe, couplings and fluid. Provide pipe guides on every other pipe length, as a minimum, to prevent possible deflection of the pipe line at the coupling joints as the riser expands due to pressure thrust or thermal growth. Note that no intermediate anchors are required.

When the system is pressurized the pipe stack will "grow" due to pressure thrust which causes maximum separation of pipe ends within the couplings. The maximum amount of stack growth can be predetermined (see Linear Movement). In this example the pipe length "L" at the top of the riser must be long enough to permit sufficient deflection (see Angular Movement) to accommodate the total movement "M" from both pressure thrust and thermal gradients.




RISERS *With* Branch Connections


Install the riser with the predetermined gap method. Anchor the pipe at or near the base with a pressure thrust anchor "A" capable of supporting the full pressure thrust, weight of pipe and the fluid column. Anchor at "B" with an anchor capable of withstanding full pressure thrust at the top of the riser plus weight of pipe column.

Place intermediate anchors "C" as shown, between anchors "A" and "B". Also place intermediate clamps at every other pipe length as a minimum.


When this system is pressurized, the pipe movement due to pressure thrust will be restrained and there will be no shear forces acting at the branch connections.




Constant Hanger Assemblies




Fig_80V_Type_A .DWG, .DXF, or .EPS




Fig_80V_Type_B .DWG, .DXF, or .EPS




Fig_80V_Type_C .DWG, .DXF, or .EPS




Fig_80V_Type_D .DWG, .DXF, or .EPS




Fig_80V_Type_E .DWG, .DXF, or .EPS



Fig_80V_Type_G .DWG, .DXF, or .EPS



Fig_81H_Type_A_224 .DWG, .DXF, or .EPS




Fig_81H_Type_A_295 .DWG, .DXF, or .EPS


Each of these drawings are available on the Anvil web site in CAD format. The file name at the bottom of each box refers to that CAD file.




Constant Hanger Assemblies (continued)




Fig_81H_Type_B_295 .DWG, .DXF, or .EPS




Fig_81H_Type_B_53_SD .DWG, .DXF, or .EPS



Fig_81H_Type_C .DWG, .DXF, or .EPS




Fig_81H_Type_D .DWG, .DXF, or .EPS




Fig_81H_Type_F .DWG, .DXF, or .EPS

Each of these drawings are available on the Anvil web site in CAD format. The file name at the bottom of each box refers to that CAD file.


Spring Hanger Assemblies




SH_Type_A_212 .DWG, .DXF, or .EPS




SH_Type_A_295 .DWG, .DXF, or .EPS




SH_Type_A_60 .DWG, .DXF, or .EPS




SH_Type_A_53SD .DWG, .DXF, or .EPS




SH_Type_A_53SD_60 .DWG, .DXF, or .EPS




SH_Type_A_Riser.DWG, .DXF, or .EPS



SH_Type_B_295 .DWG, .DXF, or .EPS



SH_Type_B_53SD .DWG, .DXF, or .EPS




SH_Type_C_212 .DWG, .DXF, or .EPS


Each of these drawings are available on the Anvil web site in CAD format. The file name at the bottom of each box refers to that CAD file.




Spring Hanger Assemblies (continued)




SH_Type_C_295 .DWG, .DXF, or .EPS




SH_Type_C_53SD .DWG, .DXF, or .EPS




SH_Type_D_295 .DWG, .DXF, or .EPS




SH_Type_D_53SD .DWG, .DXF, or .EPS




SH_Type_E .DWG, .DXF, or .EPS




SH_Type_F_PipeSlide .DWG, .DXF, or .EPS




SH_Type_F_PipeRoller .DWG, .DXF, or .EPS




SH_Type_F_63 .DWG, .DXF, or .EPS



SH_Type_F_62 .DWG, .DXF, or .EPS




SH_Type_G .DWG, .DXF, or .EPS



SH_Type_G_160-137S.DWG, .DXF, or .EPS

Each of these drawings are available on the Anvil web site in CAD format. The file name at the bottom of each box refers to that CAD file.


Rigid Hanger Assemblies




Each of these drawings are available on the Anvil web site in CAD format. The file name at the bottom of each box refers to that CAD file.




Rigid Hanger Assemblies (continued)




RH_181_157_218.DWG, .DXF, or .EPS




RH_167_65_157_218.DWG, .DXF, or .EPS




RH_65_157_218.DWG, .DXF, or .EPS




RH_167_65_92.DWG, .DXF, or .EPS




RH_295_290_228.DWG, .DXF, or .EPS




RH_260_228.DWG, .DXF, or .EPS




RH_212_290_228.DWG, .DXF, or .EPS




RH_69_157_218.DWG, .DXF, or .EPS




RH_65_86.DWG, .DXF, or .EPS



RH_69_92.DWG, .DXF, or .EPS




RH_295_290_60.DWG, .DXF, or .EPS




RH_295_290_66.DWG, .DXF, or .EPS


Each of these drawings are available on the Anvil web site in CAD format. The file name at the bottom of each box refers to that CAD file.

Rigid Hanger Assemblies (continued)



RH_260_290_66.DWG, .DXF, or .EPS




RH_167_65_60.DWG, .DXF, or .EPS




RH_212_290_60.DWG, .DXF, or .EPS




RH_69_281_CI .DWG, .DXF, or .EPS




RH_65_281_CI .DWG, .DXF, or .EPS




RH_167_65_281_CI .DWG, .DXF, or .EPS



RH_69_60.DWG, .DXF, or .EPS



RH_160_181_60.DWG, .DXF, or .EPS



RH_167_260_60.DWG, .DXF, or .EPS

Each of these drawings are available on the Anvil web site in CAD format. The file name at the bottom of each box refers to that CAD file.

WEIGHTS OF PIPING MATERIALS – INTRODUCTION

The tabulation of weights of standard piping materials presented on the following pages has been arranged for convenience of selection of data that formerly consumed considerable time to develop. For special materials, the three formulae listed below for weights of tubes, weights of contents of tubes, and weights of piping insulation will be helpful.

$$\text{Weight of tube} = F \times 10.68 \times T \times (D - T) \text{ lb/ft}$$

T = wall thickness in inches

D = outside diameter in inches

F = relative weight factor

The weight of tube furnished in this piping data is based on low carbon steel weighing 0.2833 lb/in³.

RELATIVE WEIGHT FACTOR F

Aluminum	0.34
Brass	1.09
Cast Iron	0.92
Copper	1.14
Ferritic stainless steel	0.95
Austenitic stainless steel	1.02
Steel	1.00
Wrought iron	0.99

WEIGHT OF CONTENTS OF A TUBE

$$\text{Weight of Tube Contents} = G \times .3405 \times (D - 2T)^2 \text{ lb/ft}$$

G = specific gravity of contents

T = tube wall thickness in inches

D = tube outside diameter in inches

WEIGHT TOLERANCES

The weight per foot of steel pipe is subject to the following tolerances:

SPECIFICATION	TOLERANCE	
ASTM A-120 & ASTM A-53		
STD WT	+5%	-5%
XS WT	+5%	5%
XXS WT	+10%	-10%
ASTM A-106		
SCH 10-120	+6.5%	-3.5%
SCH 140-160	+10%	-3.5%
ASTM A-335		
12" and under	+6.5%	-3.5%
over 12"	+10%	-5%
ASTM A-312 & ASTM A-376		
12"and under	+6.5%	-3.5%
API 5L All sizes	+6.5%	-3.5%

The weight of welding tees and laterals are for full size fittings. The weights of reducing fittings are approximately the same as for full size fittings.

The weights of welding reducers are for one size reduction, and are approximately correct for other reductions.

Weights of valves of the same type may vary because of individual manufacturer's designs. Listed valve weights are approximate only. Specific valve weights should be used when available.

Where specific insulation thicknesses and densities differ from those shown, refer to "Weight of Piping Insulation" formula below.

WEIGHT OF PIPING INSULATION

$$\text{Pipe Insulation Weight} = I \times .0218 \times T \times (D + T) \text{ lb/ft}$$

I = insulation density in pounds per cubic foot

T = insulation thickness in inches

D = outside diameter of pipe in inches

TABLE III - LOAD CAPACITY OF THREADED HANGER RODS
ASTM A36, A575 GR 1020 OR A576 GR 1020

Nominal Rod Diam. Inch	Root Area of Coarse Thread Sq. In.	Max Recommended Load at Rod Temp 650° Lbs
3/8	0.068	730
1/2	0.126	1,350
5/8	0.202	2,160
3/4	0.302	3,230
7/8	0.419	4,480
1	0.552	5,900
1 1/4	0.889	9,500
1 1/2	1.293	13,800
1 3/4	1.744	18,600
2	2.292	24,600
2 1/4	3.021	32,300
2 1/2	3.716	39,800
2 3/4	4.619	49,400
3	5.621	60,100
3 1/4	6.720	71,900
3 1/2	7.918	84,700
3 3/4	9.214	98,500
4	10.608	114,000
4 1/4	12.100	129,000
4 1/2	13.690	146,000
4 3/4	15.379	165,000
5	17.165	184,000

PIPE						
Sch./Wall Designation -->	5S	10S	40/Std.	80/XS	160	XXS
Thickness -- In.	0.065	0.109	0.133	0.179	0.25	0.358
Pipe -- Lbs/Ft	0.868	1.404	1.68	2.17	2.84	3.66
Water -- Lbs/Ft	0.478	0.409	0.37	0.31	0.23	0.12
WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR						
 L.R. 90° Elbow	0.2 0.3	0.4 0.3	0.4 0.3	0.4 0.3	0.6 0.3	1 0.3
 S.R. 90° Elbow			0.3 0.2			
 L.R. 45° Elbow	0.1 0.2	0.3 0.2	0.3 0.2	0.3 0.2	0.4 0.2	0.5 0.2
 Tee	0.4 0.4	0.6 0.4	0.8 0.4	0.9 0.4	1.1 0.4	1.3 0.4
 Lateral	0.7 1.1	1.2 1.1	1.7 1.1	2.5 1.1		
 Reducer	0.2 0.2	0.4 0.2	0.3 0.2	0.4 0.2	0.5 0.2	0.5 0.2
 Cap	0.1 0.3	0.1 0.3	0.3 0.3	0.3 0.3	0.4 0.3	0.5 0.3

PIPE INSULATION												
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite Calcium Silicate	Nom. Thick., In.	1	1	1½	2	2						
	Lbs./Ft	0.57	0.57	0.97	1.54	1.54						
Combination	Nom. Thick., In.						2½	2½	2½	3	3	3
	Lbs/Ft						3.3	3.3	3.3	4.7	4.7	4.7

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
	Screwed or Slip-On	2.3 1.5	4 1.5	2.5 1.5	4 1.5	5 1.5	5 1.5	12 1.5	12 1.5	15 1.5
	Welding Neck			3 1.5	5 1.5	7 1.5	7 1.5	12 1.5	12 1.5	16 1.5
	Lap Joint			2.5 1.5	4 1.5	5 1.5	5 1.5	12 1.5	12 1.5	15 1.5
	Blind	2.5 1.5	5 1.5	2.5 1.5	5 1.5	5 1.5	5 1.5	12 1.5	12 1.5	15 1.5
	S.R. 90° Elbow						15 3.7		28 3.8	
	L.R. 90° Elbow									
	45° Elbow						14 3.4		26 3.6	
	Tee						20 5.6		39 5.7	
	Flanged Bonnet Gate				20 1.2		25 1.5		80 4.3	
	Flanged Bonnet – Globe or Angle								84 3.5	
	Flanged Bonnet – Check									
	Pressure Seal – Bonnet, Gate						31 1.7	31 1.7		
	Pressure Seal – Bonnet, Globe									

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.

PIPE						
Sch./Wall Designation -->	5S	10S	40/Std.	80/XS	160	XXS
Thickness -- In.	0.065	0.109	0.14	0.191	0.25	0.382
Pipe -- Lbs/Ft	1.11	1.81	2.27	3.00	3.77	5.22
Water -- Lbs/Ft	0.8	0.71	0.65	0.56	0.46	0.27
WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR						
 L.R. 90° Elbow	0.3 0.3	0.5 0.3	0.6 0.3	0.8 0.3	1 0.3	1.3 0.3
 S.R. 90° Elbow			0.4 0.2			
 L.R. 45° Elbow	0.2 0.2	0.3 0.2	0.3 0.2	0.5 0.2	0.6 0.2	0.7 0.2
 Tee	0.7 0.5	1.1 0.5	1.6 0.5	1.6 0.5	1.9 0.5	2.4 0.5
 Lateral	1.1 1.2	1.9 1.2	2.4 1.2	3.8 1.2		
 Reducer	0.3 0.2	0.4 0.2	0.5 0.2	0.6 0.2	0.7 0.2	0.8 0.2
 Cap	0.1 0.3	0.1 0.3	0.4 0.3	0.4 0.3	0.6 0.3	0.6 0.3

PIPE INSULATION												
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesia	Nom. Thick., In.	1	1	1½	2	2	2½	2½	2½	3	3	3
Calcium Silicate	Lbs./Ft	0.65	0.65	1.47	1.83	1.83	2.65	2.65	2.65	3.58	3.58	3.58
Combination	Nom. Thick., In.						2½	2½	2½	3	3	3
	Lbs/Ft						3.17	3.17	3.17	5.76	5.76	5.76

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron			Steel					
		125	250	150	300	400	600	900	1500	2500
 Screwed or Slip-On		2.5 1.5	4.8 1.5	3.5 1.5	5 1.5	7 1.5	7 1.5	13 1.5	13 1.5	23 1.5
 Welding Neck				3 1.5	7 1.5	8 1.5	8 1.5	13 1.5	13 1.5	25 1.5
 Lap Joint				3.5 1.5	5 1.5	7 1.5	7 1.5	13 1.5	13 1.5	22 1.5
 Blind		2.8 1.5	5.5 1.5	3.5 1.5	4 1.5	7 1.5	7 1.5	13 1.5	13 1.5	23 1.5
 S.R. 90° Elbow					17 3.7		18 3.8		33 3.9	
 L.R. 90° Elbow					18 3.9					
 45° Elbow					15 3.4		16 3.5		31 3.7	
 Tee					23 5.6		28 5.6		49 5.9	
 Flanged Bonnet Gate					40 4		60 4.2		97 4.6	
 Flanged Bonnet - Globe or Angle										
 Flanged Bonnet - Check					21 4					
 Pressure Seal - Bonnet, Gate								38 1.1	38 1.1	
 Pressure Seal - Bonnet, Globe										

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesia and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.

Sch./Wall Designation -->	PIPE							
	5S	10S	40/Std.	80/XS	160	XXS		
Thickness -- In.	0.065	0.109	0.145	0.2	0.281	0.4	0.525	0.65
Pipe -- Lbs/Ft	1.27	2.09	2.72	3.63	4.86	6.41	7.71	8.68
Water -- Lbs/Ft	1.07	0.96	0.88	0.77	0.61	0.41	0.25	0.12

WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR							
 L.R. 90° Elbow	0.4 0.4	0.8 0.4	0.9 0.4	1.2 0.4	1.5 0.4	2 0.4	
 S.R. 90° Elbow			0.6 0.3	0.8 0.3			
 L.R. 45° Elbow	0.3 0.2	0.5 0.2	0.5 0.2	0.7 0.2	0.8 0.2	0.1 0.2	
 Tee	0.9 0.6	1.5 0.6	2 0.6	2.4 0.6	3 0.6	3.7 0.6	
 Lateral	1.3 1.3	2.1 1.3	3.3 1.3	5.5 1.3			
 Reducer	0.3 0.2	0.6 0.2	0.6 0.2	0.8 0.2	1 0.2	1.2 0.2	
 Cap	0.1 0.3	0.2 0.3	0.4 0.3	0.5 0.3	0.7 0.3	0.8 0.3	

		PIPE INSULATION										
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1	1	1½	2	2	2½	2½	2½	3	3	3
Calcium Silicate	Lbs./Ft	0.84	0.84	1.35	2.52	2.52	3.47	3.47	3.47	4.52	4.52	4.52
Combination	Nom. Thick., In.						2½	2½	2½	3	3	3
	Lbs./Ft						4.2	4.2	4.2	5.62	5.62	5.62

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
 Screwed or Slip-On		3 1.5	6 1.5	3.5 1.5	6 1.5	9 1.5	9 1.5	19 1.5	19 1.5	30 1.5
 Welding Neck				4.5 1.5	8 1.5	12 1.5	12 1.5	19 1.5	19 1.5	34 1.5
 Lap Joint				3.5 1.5	6 1.5	9 1.5	9 1.5	19 1.5	19 1.5	30 1.5
 Blind		4 1.5	6 1.5	3.5 1.5	8 1.5	10 1.5	10 1.5	19 1.5	19 1.5	31 1.5
 S.R. 90° Elbow		9 3.7		12 3.7	23 3.8		26 3.9		46 4	
 L.R. 90° Elbow		12 4		13 4	24 4					
 45° Elbow		8 3.4		11 3.4	21 3.5		23 3.5		39 3.7	
 Tee		15 5.6		20 5.6	30 5.7		37 5.8		70 6	
 Flanged Bonnet Gate		27 6.8			55 4.2		70 4.5		125 5	
 Flanged Bonnet - Globe or Angle					40 4.2		45 4.2		170 5	
 Flanged Bonnet - Check				30 4.1	35 4.1		40 4.2		110 4.5	
 Pressure Seal - Bonnet, Gate								42 1.9	42 1.2	
 Pressure Seal - Bonnet, Globe										

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.



PIPE								
Sch./Wall Designation -->	5S	10S	40/Std.	80/XS	160	XXS		
Thickness -- In.	0.065	0.109	0.154	0.218	0.343	0.436	0.562	0.687
Pipe -- Lbs/Ft	1.60	2.64	3.65	5.02	7.44	9.03	10.88	12.39
Water -- Lbs/Ft	1.72	1.58	1.46	1.28	0.97	0.77	0.53	0.34

WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR						
L.R. 90° Elbow	0.6 0.5	1.1 0.5	1.5 0.5	2.1 0.5	3 0.5	4 0.5
S.R. 90° Elbow			1 0.3	1.4 0.3		
L.R. 45° Elbow	0.4 0.2	0.6 0.2	0.9 0.2	1.1 0.2	1.6 0.2	2 0.2
Tee	1.1 0.6	1.8 0.6	2.9 0.6	3.7 0.6	4.9 0.6	5.7 0.6
Lateral	1.9 1.4	3.2 1.4	5 1.4	7.7 1.4		
Reducer	0.4 0.3	0.9 0.3	0.9 0.3	1.2 0.3	1.6 0.3	1.9 0.3
Cap	0.2 0.4	0.3 0.4	0.6 0.4	0.7 0.4	1.1 0.4	1.2 0.4

PIPE INSULATION												
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1	1	1½	2	2	2½	2½	2½	3	3	3
Calcium Silicate	Lbs./Ft	1.01	1.01	1.71	2.53	2.53	3.48	3.48	4.42	4.42	4.42	5.59
Combination	Nom. Thick., In.						2½	2½	2½	3	3	3
	Lbs./Ft						4.28	4.28	5.93	5.93	5.93	7.8

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron			Steel					
		125	250	150	300	400	600	900	1500	2500
Screwed or Slip-On		5 1.5	7 1.5	6 1.5	9 1.5	11 1.5	11 1.5	32 1.5	32 1.5	49 1.5
Welding Neck				7 1.5	11 1.5	14 1.5	14 1.5	32 1.5	32 1.5	53 1.5
Lap Joint				6 1.5	9 1.5	11 1.5	11 1.5	32 1.5	32 1.5	48 1.5
Blind		5 1.5	8 1.5	5 1.5	10 1.5	12 1.5	12 1.5	32 1.5	32 1.5	50 1.5
S.R. 90° Elbow		14 3.8	20 3.8	19 3.8	29 3.8		35 4		83 4.2	
L.R. 90° Elbow		16 4.1	27 4.1	22 4.1	31 4.1					
45° Elbow		12 3.4	18 3.5	16 3.4	24 3.5		33 3.7		73 3.9	
Tee		21 5.7	32 5.7	27 5.7	41 5.7		52 6		129 6.3	
Flanged Bonnet Gate		37 6.9	52 7.1	40 4	65 4.2		80 4.5		190 5	
Flanged Bonnet - Globe or Angle		30 7	64 7.3	30 3.8	45 4		85 4.5		235 5.5	
Flanged Bonnet - Check		26 7	51 7.3	35 3.8	40 4		60 4.2		300 5.8	
Pressure Seal - Bonnet, Gate									150 2.5	
Pressure Seal - Bonnet, Globe									165 3	

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.

PIPE								
Sch./Wall Designation -->	5S	10S	40/Std.	80/XS	160	XXS		
Thickness -- In.	0.083	0.12	0.203	0.276	0.375	0.553	0.675	0.8
Pipe -- Lbs/Ft	2.48	3.53	5.79	7.66	10.01	13.70	15.86	17.73
Water -- Lbs/Ft	2.5	2.36	2.08	1.84	1.54	1.07	0.79	0.55

WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR						
 L.R. 90° Elbow	1.2 0.6	1.8 0.6	3 0.6	3.8 0.6	5 0.6	7 0.6
 S.R. 90° Elbow			2.2 0.4	2.5 0.4		
 L.R. 45° Elbow	0.7 0.3	1 0.3	1.6 0.3	2.1 0.3	3 0.3	3.5 0.3
 Tee	2.1 0.8	3 0.8	5.2 0.8	6.4 0.8	7.8 0.8	9.8 8
 Lateral	3.5 1.5	4.9 1.5	9 1.5	13 1.5		
 Reducer	0.6 0.3	1.2 0.3	1.6 0.3	2 0.3	2.7 0.3	3.3 0.3
 Cap	0.3 0.4	0.4 0.4	0.9 4	0.1 0.4	1.9 0.4	2.0 0.4

PIPE INSULATION												
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1	1	1½	2	2	2½	2½	3	3	3½	3½
Calcium Silicate	Lbs./Ft	1.14	1.14	2.29	3.23	3.23	4.28	4.28	5.46	5.46	6.86	6.86
Combination	Nom. Thick., In.						2½	2½	3	3	3½	3½
	Lbs./Ft						5.2	5.2	7.36	7.36	9.58	9.58

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
	Screwed or Slip-On	7 1.5	12.5 1.5	8 1.5	14 1.5	17 1.5	17 1.5	46 1.5	46 1.5	69 1.5
	Welding Neck			11 1.5	16 1.5	22 1.5	22 1.5	46 1.5	46 1.5	66 1.5
	Lap Joint			8 1.5	14 1.5	16 1.5	16 1.5	45 1.5	45 1.5	67 1.5
	Blind	7.8 1.5	10 1.5	8 1.5	16 1.5	19 1.5	19 1.5	45 1.5	45 1.5	70 1.5
	S.R. 90° Elbow	20 3.8	33 3.9	27 3.8	42 3.9		50 4.1		114 4.4	
	L.R. 90° Elbow	24 4.2		30 4.2	47 4.2					
	45° Elbow	18 3.5	31 3.6	22 3.5	35 3.6		46 3.8		99 3.9	
	Tee	31 5.7	49 5.8	42 5.7	61 5.9		77 6.2		169 6.6	
	Flanged Bonnet Gate	50 7	82 7.1	60 4	100 4.2		105 4.6		275 5.2	
	Flanged Bonnet - Globe or Angle	43 7.1	87 7.4	50 4	70 4.1		120 4.6		325 5.5	
	Flanged Bonnet - Check	36 7.1	71 7.4	40 4	50 4		105 4.6		320 5.5	
	Pressure Seal - Bonnet, Gate								215 2.5	
	Pressure Seal - Bonnet, Globe								230 2.8	

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.



Sch./Wall Designation -->	PIPE							
	5S	10S	40/Std.	80/XS	160	XXS		
Thickness -- In.	0.083	0.12	0.216	0.3	0.438	0.6	725	0.85
Pipe -- Lbs/Ft	3.03	4.33	7.58	10.25	14.32	18.58	21.49	24.06
Water -- Lbs/Ft	3.78	3.61	3.2	2.86	2.35	1.8	1.43	1.1

WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR							
L.R. 90° Elbow	1.7 0.8	2.5 0.8	4.7 0.8	6 0.8	8.5 0.8	11 0.8	
S.R. 90° Elbow			3.3 0.5	4.1 0.5			
L.R. 45° Elbow	0.9 0.3	1.3 0.3	2.5 0.3	3.3 0.3	4.5 0.3	5.5 0.3	
Tee	2.7 0.8	3.9 0.8	7 0.8	10 0.8	12.2 0.8	14.8 0.8	
Lateral	4.5 1.8	6.4 1.8	12.5 1.8	18 1.8			
Reducer	0.8 0.3	1.5 0.3	2.1 0.3	2.8 0.3	3.7 0.3	4.6 0.3	
Cap	0.5 0.5	0.7 0.5	1.4 0.5	1.8 0.5	3.5 0.5	3.6 0.5	

		PIPE INSULATION										
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1	1	1½	2	2	2½	3	3	3	3½	3½
Calcium Silicate	Lbs./Ft	1.25	1.25	2.08	3.01	3.01	4.07	5.24	5.24	5.24	6.65	6.65
Combination	Nom. Thick., In.						2½	3	3	3	3½	3½
	Lbs./Ft						5.07	6.94	6.94	6.94	9.17	9.17

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR									
		Pressure Rating (PSI)							
		Cast Iron		Steel					
		125	250	150	300	400	600	900	1500
		2500							
Screwed or Slip-On		8.6 1.5	15.8 1.5	9 1.5	17 1.5	20 1.5	20 1.5	37 1.5	61 1.5
Welding Neck				12 1.5	19 1.5	27 1.5	27 1.5	38 1.5	61 1.5
Lap Joint				9 1.5	17 1.5	19 1.5	19 1.5	36 1.5	60 1.5
Blind		9 1.5	17.5 1.5	10 1.5	20 1.5	24 1.5	24 1.5	38 1.5	61 1.5
S.R. 90° Elbow		25 3.9	44 4	32 3.9	53 4		67 4.1	98 4.3	150 4.6
L.R. 90° Elbow		29 4.3		40 4.3	63 4.3				
45° Elbow		21 3.5	39 3.6	28 3.5	46 3.6		60 3.8	93 3.9	135 4
Tee		38 5.9	62 6	52 5.9	81 6		102 6.2	151 6.5	238 6.9
Flanged Bonnet Gate		66 7	112 7.4	70 4	125 4.4		155 4.8	260 5	410 5.5
Flanged Bonnet - Globe or Angle		56 7.2	87 7.6	60 4.3	95 4.5		155 4.8	225 5	495 5.5
Flanged Bonnet - Check		46 7.2	100 7.6	60 4.3	70 4.4		120 4.8	150 4.9	440 5.8
Pressure Seal - Bonnet, Gate								208 3	235 3.2
Pressure Seal - Bonnet, Globe								135 2.5	180 3

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.

PIPE					
Sch./Wall Designation -->	5S	10S	40/Std.	80/XS	160
Thickness -- In.	0.083	0.12	0.226	0.318	0.636
Pipe -- Lbs/Ft	3.47	4.97	9.11	12.51	22.85
Water -- Lbs/Ft	5.01	4.81	4.28	3.85	2.53
WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR					
 L.R. 90° Elbow	2.4 0.9	3.4 0.9	6.7 0.9	8.7 0.9	15.0 0.9
 S.R. 90° Elbow			4.2 0.6	5.75 0.6	
 L.R. 45° Elbow	1.2 4	1.7 0.4	3.3 0.4	4.4 0.4	8.0 0.4
 Tee	3.4 0.9	4.9 0.9	10.3 0.9	13.8 0.9	20.2 0.9
 Lateral	6.2 1.8	8.9 1.8	17.2 1.8	25 1.8	
 Reducer	1.2 0.3	2.1 0.3	3.0 0.3	4.0 0.3	6.8 0.3
 Cap	0.6 0.6	0.8 0.6	2.1 0.6	2.8 0.6	5.5 0.6

		PIPE INSULATION										
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1	1	1½	2	2½	2½	3	3	3½	3½	3½
Calcium Silicate	Lbs./Ft	1.83	1.83	2.77	3.71	4.88	4.88	6.39	6.39	7.8	7.8	7.8
Combination	Nom. Thick., In.						2½	3	3	3½	3½	3½
	Lbs./Ft						6.49	8.71	8.71	10.8	10.8	10.8

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
	Screwed or Slip-On	11 1.5	20 1.5	13 1.5	21 1.5	27 1.5	27 1.5			
	Welding Neck			14 1.5	22 1.5	32 1.5	32 1.5			
	Lap Joint			13 1.5	21 1.5	26 1.5	26 1.5			
	Blind	13 1.5	23 1.5	15 1.5	25 1.5	35 1.5	35 1.5			
	S.R. 90° Elbow	33 4		49 4			82 4.3			
	L.R. 90° Elbow			54 4.4						
	45° Elbow	29 3.6		39 3.6			75 3.6			
	Tee	51 6	103 6.2	70 6			133 6.4			
	Flanged Bonnet Gate	82 7.1	143 7.5	155 4.5			180 4.8	360 5	510 5.5	
	Flanged Bonnet - Globe or Angle	74 7.3	137 7.7				160 4.7			
	Flanged Bonnet - Check	71 7.3	125 7.7				125 4.7			
	Pressure Seal - Bonnet, Gate						140 2.5	295 2.8	380 3	
	Pressure Seal - Bonnet, Globe									

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.



PIPE											
Sch./Wall Designation -->	5S	10S	10		40/Std.	80/XS	120		160	XXS	
Thickness -- In.	0.083	0.12	0.188	0.237	0.337	0.438	0.5	0.531	0.674	0.8	0.925
Pipe -- Lbs/Ft	3.92	5.61	8.56	10.79	14.98	18.96	21.36	22.51	27.54	31.61	35.32
Water -- Lbs/Ft	6.4	6.17	5.8	5.51	4.98	4.48	4.16	4.02	3.38	2.86	2.39

WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR											
L.R. 90° Elbow	3 1	4.3 1		8.7 1	12 1			18 1	20.5 1		
S.R. 90° Elbow				6.7 0.7	8.3 0.7						
L.R. 45° Elbow	1.5 0.4	2.2 0.4		4.3 0.4	5.9 0.4			8.5 0.4	10 4		
Tee	3.9 1	5.7 1		13.5 1	16.4 1			22.8 1	26.6 1		
Lateral	6.6 2.1	10 2.1		20.5 2.1	32 2.1						
Reducer	1.2 0.3	2.4 0.3		3.6 0.3	4.8 0.3			6.6 0.3	8.2 0.3		
Cap	0.8 0.3	1.2 0.3		2.5 0.5	3.4 0.5			6.5 6.5	6.6 6.6		

PIPE INSULATION												
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1	1	1½	2	2½	2½	3	3	3½	3½	4
Calcium Silicate	Lbs./Ft	1.62	1.62	2.55	3.61	4.66	4.66	6.07	6.07	7.48	7.48	9.1
Combination	Nom. Thick., In.						2½	3	3	3½	3½	3½
	Lbs/Ft						6.07	8.3	8.3	10.6	10.6	10.6

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron			Steel					
		125	250	150	300	400	600	900	1500	2500
Screwed or Slip-On		14 1.5	24 1.5	15 1.5	26 1.5	32 1.5	43 1.5	66 1.5	90 1.5	158 1.5
Welding Neck				17 1.5	29 1.5	41 1.5	48 1.5	648 1.5	90 1.5	177 1.5
Lap Joint				15 1.5	26 1.5	31 1.5	42 1.5	64 1.5	92 1.5	153 1.5
Blind		16 1.5	27 1.5	19 1.5	31 1.5	39 1.5	47 1.5	67 1.5	90 1.5	164 1.5
S.R. 90° Elbow		43 4.1	69 4.2	59 4.1	85 4.2	99 4.3	128 4.4	185 4.5	254 4.8	
L.R. 90° Elbow		50 4.5		72 4.5	98 4.5					
45° Elbow		38 3.7	62 3.8	51 3.7	78 3.8	82 3.9	119 4	170 4.1	214 4.2	
Tee		66 6.1	103 6.3	86 6.1	121 6.3	153 6.4	187 6.6	262 6.8	386 7.2	
Flanged Bonnet Gate		109 7.2	188 7.5	100 4.2	175 4.5	195 5	255 5.1	455 5.4	735 6	
Flanged Bonnet - Globe or Angle		97 7.4	177 7.8	95 4.3	145 4.8	215 5	230 5.1	415 5.5	800 6	
Flanged Bonnet - Check		80 7.4	146 7.8	80 4.3	105 4.5	160 4.8	195 5	320 5.6	780 6	
Pressure Seal - Bonnet, Gate							215 2.8	380 3	520 4	
Pressure Seal - Bonnet, Globe								240 2.7	290 3	

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.

PIPE									
Sch./Wall Designation -->	5S	10S	40/Std	80/XS	120	160	XXS		
Thickness -- In.	0.109	0.134	0.258	0.375	0.5	0.625	0.75	0.875	1
Pipe -- Lbs/Ft	6.35	7.77	14.62	20.78	27.04	32.96	38.55	43.81	47.73
Water -- Lbs/Ft	9.73	9.53	8.66	7.89	7.09	6.33	5.62	4.95	4.23
WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR									
 L.R. 90° Elbow	6 1.3	7.4 1.3	16 1.3	21.4 1.3		33 1.3	34 1.3		
 S.R. 90° Elbow	4.2 0.8	5.2 0.8	10.4 0.8	14.5 0.8					
 L.R. 45° Elbow	3.1 0.5	3.8 0.5	8.3 0.5	10.5 0.5		14 0.5	18 0.5		
 Tee	9.8 1.2	12 1.2	19.8 1.2	26.9 1.2		38.5 1.2	43.4 1.2		
 Lateral	15.3 2.5	18.4 2.5	31 2.5	49 2.5					
 Reducer	2.5 0.4	4.3 0.4	5.9 0.4	8.3 0.4		12.4 0.4	14.2 0.4		
 Cap	1.3 0.7	1.6 0.7	4.2 0.7	5.7 0.7		11 0.7	11 0.7		

PIPE INSULATION												
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1	1½	1½		2½	2½	3	3½	3½	4	4
Calcium Silicate	Lbs./Ft	1.86	2.92	2.92	4.08	5.38	5.38	6.9	8.41	8.41	10.4	10.4
Combination	Nom. Thick., In.						2½	3	3½	3½	4	4
	Lbs./Ft						7.01	9.3	11.8	11.8	14.9	14.9

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
	Screwed or Slip-On	17 1.5	28 1.5	18 1.5	32 1.5	37 1.5	73 1.5	100 1.5	162 1.5	259 1.5
	Welding Neck			22 1.5	36 1.5	49 1.5	78 1.5	103 1.5	162 1.5	293 1.5
	Lap Joint			18 1.5	32 1.5	35 1.5	71 1.5	98 1.5	179 1.5	253 1.5
	Blind	21 1.5	35 1.5	23 1.5	39 1.5	50 1.5	78 1.5	104 1.5	172 1.5	272 1.5
	S.R. 90° Elbow	55 4.3	91 4.3	80 4.3	113 4.3	123 4.5	205 4.7	268 4.8	435 5.2	
	L.R. 90° Elbow	65 4.7		91 4.7	128 4.7					
	45° Elbow	48 3.8	80 3.8	66 3.8	98 3.8	123 4	180 4.2	239 4.3	350 4.5	
	Tee	84 6.4	139 6.5	119 6.4	172 6.4	179 6.8	304 7	415 7.2	665 7.8	
	Flanged Bonnet Gate	138 7.3	264 7.9	150 4.3	265 4.9	310 5.3	455 5.5	615 6	1340 7	
	Flanged Bonnet - Globe or Angle	138 7.6	247 8	155 4.3	215 5	355 5.2	515 5.8	555 5.8	950 6	
	Flanged Bonnet - Check	118 7.6	210 8	110 4.3	165 5	185 5	350 5.8	570 6	1150 7	
	Pressure Seal - Bonnet, Gate						350 3.1	520 3.8	865 4.5	
	Pressure Seal - Bonnet, Globe							280 4	450 4.5	

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.



Sch./Wall Designation -->	PIPE									
	5S	10	40/Std.	80/XS	120	160	XXS			
Thickness -- In.	0.109	0.134	0.219	0.28	0.432	0.562	0.718	0.864	1	1.125
Pipe -- Lbs/Ft	5.37	9.29	15.02	18.97	28.57	36.39	45.30	53.20	60.01	66.08
Water -- Lbs/Ft	13.98	13.74	13.1	12.51	11.29	10.3	9.2	8.2	7.28	6.52

WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR									
L.R. 90° Elbow	8.9 1.5	11 1.5		22.8 1.5	32.2 1.5	43 1.5	55 1.6	62 1.5	
S.R. 90° Elbow	6.1 1	7.5 1		16.6 1	22.9 1	30 1			
L.R. 45° Elbow	4.5 0.6	5.5 0.6		11.3 0.6	16.4 0.6	21 0.6	26 0.6	30 0.6	
Tee	13.8 1.4	17 1.4		31.3 1.4	39.5 1.4		59 1.4	68 1.4	
Lateral	16.7 2.9	20.5 2.9		42 2.9	78 2.9				
Reducer	3.3 0.5	5.8 0.5		8.6 0.6	12.6 0.5		18.8 0.5	21.4 0.5	
Cap	1.6 0.9	1.9 0.9		6.4 0.9	9.2 0.9	13.3 0.9	17.5 0.9	17.5 0.9	

		PIPE INSULATION										
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1	1½	2	2	2½	3	3	3½	3½	4	4
Calcium Silicate	Lbs./Ft	2.11	3.28	4.57	4.57	6.09	7.6	7.6	9.82	9.82	11.5	11.4
Combination	Nom. Thick., In.						3	3	3½	3½	4	4
	Lbs./Ft						10.3	10.3	13.4	13.4	16.6	16.6

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron			Steel					
		125	250	150	300	400	600	900	1500	2500
Screwed or Slip-On		20 1.5	38 1.5	22 1.5	45 1.5	54 1.5	95 1.5	128 1.5	202 1.5	396 1.5
Welding Neck				27 1.5	48 1.5	67 1.5	96 1.5	130 1.5	202 1.5	451 1.5
Lap Joint				22 1.5	45 1.5	52 1.5	93 1.5	125 1.5	208 1.5	387 1.5
Blind		26 1.5	48 1.5	29 1.5	56 1.5	71 1.5	101 1.5	133 1.5	197 1.5	418 1.5
S.R. 90° Elbow		71 4.3	121 4.4	90 4.3	147 4.4	184 4.6	275 4.8	375 5	566 5.3	
L.R. 90° Elbow		88 4.9		126 4.9	182 4.9					
45° Elbow		63 3.8	111 3.9	82 3.8	132 3.9	149 4.1	240 4.3	320 4.3	487 4.6	
Tee		108 6.5	186 6.6	149 6.5	218 6.6	280 6.9	400 7.2	565 7.5	839 8	
Flanged Bonnet Gate		172 7.3	359 8	190 4.3	360 5	435 5.5	620 5.8	835 6	1595 7	
Flanged Bonnet - Globe or Angle		184 7.8	345 8.2	185 4.4	275 5	415 5.3	645 5.8	765 6	1800 7	
Flanged Bonnet - Check		154 7.8	286 8.2	150 4.8	200 5	360 5.4	445 6	800 6.4	1730 7	
Pressure Seal - Bonnet, Gate							580 3.5	750 4	1215 5	
Pressure Seal - Bonnet, Globe								730 4	780 5	

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.

Sch./Wall Designation -->	PIPE											
	5S	10S		20	30	40/STD	60	80/XS	100	120	140	160
Thickness -- In.	0.109	0.148	0.219	0.25	0.277	0.322	0.406	0.5	0.593	0.718	0.812	0.906
Pipe -- Lbs/Ft	9.91	13.40	19.64	22.36	24.70	28.55	35.64	43.4	50.9	60.6	67.8	74.7
Water -- Lbs/Ft	24.07	23.59	22.9	22.48	22.18	21.69	20.79	19.8	18.8	17.6	16.7	15.8
WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR												
 L.R. 90° Elbow	15.4 2	21 2				44.9 2		70.3 2				120 2
 S.R. 90° Elbow	6.6 1.3	14.3 1.3				34.5 1.3		50.2 1.3				
 L.R. 45° Elbow	8.1 0.8	11 0.8				22.8 0.8		32.8 0.8				56 0.8
 Tee	18.4 1.8	25 1.8				60.2 1.8		78 1.8				120 1.8
 Lateral	25.3 3.8	41.1 3.8				76 3.8		140 3.8				
 Reducer	4.5 0.5	7.8 0.5				13.9 0.5		20.4 0.5				32.1 0.5
 Cap	2.1 1	2.8 1				11.3 1		16.3 1				32 1

		PIPE INSULATION										
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1½	1½	2	2	2½	3	3½	3½	4	4	4½
Calcium Silicate	Lbs./Ft	4.13	4.13	5.64	5.64	7.85	9.48	11.5	11.5	13.8	13.8	16
Combination	Nom. Thick., In.						3	3½	3½	4	4	4½
	Lbs./Ft						12.9	16.2	16.2	20.4	20.4	23.8

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
 Screwed or Slip-On		29 1.5	60 1.5	33 1.5	67 1.5	82 1.5	135 1.5	207 1.5	319 1.5	601 1.5
 Welding Neck				42 1.5	76 1.5	104 1.5	137 1.5	222 1.5	334 1.5	692 1.5
 Lap Joint				33 1.5	77 1.5	79 1.5	132 1.5	223 1.5	347 1.5	587 1.5
 Blind		43 1.5	79 1.5	48 1.5	90 1.5	115 1.5	159 1.5	232 1.5	363 1.5	649 1.5
 S.R. 90° Elbow		113 4.5	194 4.7	157 4.5	238 4.7	310 5	435 5.2	639 5.4	995 5.7	
 L.R. 90° Elbow		148 5.3		202 5.3	283 5.3					
 45° Elbow		97 3.9	164 4	127 3.9	203 4	215 4.1	360 4.4	507 4.5	870 4.8	
 Tee		168 6.8	289 7.1	230 6.8	337 7.1	445 7.5	610 7.8	978 8.1	1465 8.6	
 Flanged Bonnet Gate		251 7.5	583 8.1	305 4.5	505 5.1	703 6	960 6.3	1180 6.6	2740 7	
 Flanged Bonnet - Globe or Angle		317 8.4	554 8.6	475 5.4	505 5.5	610 5.9	1130 6.3	1160 6.3	2865 7	
 Flanged Bonnet - Check		302 8.4	454 8.6	235 5.2	310 5.3	475 5.6	725 6	1140 6.4	2075 7	
 Pressure Seal - Bonnet, Gate							925 4.5	1185 4.7	2345 5.5	
 Pressure Seal - Bonnet, Globe								1550 4	1680 5	

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.



PIPE												
Sch./Wall Designation -->	5S	10S		20	30	40/STD	60	80/XS	100	120	140	160
Thickness -- In.	0.134	0.165	0.219	0.25	0.307	0.365	0.5	0.593	0.718	0.843	1	1.125
Pipe -- Lbs/Ft	15.15	18.70	24.63	28.04	34.24	40.5	54.7	64.3	76.9	89.2	104.1	115.7
Water -- Lbs/Ft	37.4	36.9	36.2	35.77	34.98	34.1	32.3	31.1	29.5	28	26.1	24.6
WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR												
L.R. 90° Elbow	29.2 2.5	36 2.5				84 2.5	112 2.5					230 2.5
S.R. 90° Elbow	20.3 1.7	24.9 1.7				62.2 1.7	74 1.7					
L.R. 45° Elbow	14.6 1	18 1				42.4 1	53.8 1					109 1
Tee	30 2.1	37 2.1				104 2.1	132 2.1					222 2.1
Lateral	47.5 4.4	70 4.4				124 4.4	200 4.4					
Reducer	8.1 0.6	14 0.6				23.2 0.6	31.4 0.6					58 0.6
Cap	3.8 1.3	4.7 1.3				20 1.3	26.3 1.3					59 1.3

PIPE INSULATION												
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1½	1½	2	2½	2½	3	3½	3½	4	4	4½
Calcium Silicate	Lbs./Ft	5.2	5.2	7.07	8.93	8.93	11	13.2	13.2	15.5	15.5	18.1
Combination	Nom. Thick., In.						3	3½	3½	4	4	4½
	Lbs./Ft						15.4	19.3	19.3	23	23	27.2

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron			Steel					
		125	250	150	300	400	600	900	1500	2500
Screwed or Slip-On		45 1.5	93 1.5	50 1.5	100 1.5	117 1.5	213 1.5	293 1.5	528 1.5	1148 1.5
Welding Neck				59 1.5	110 1.5	152 1.5	225 1.5	316 1.5	546 1.5	1291 1.5
Lap Joint				50 1.5	110 1.5	138 1.5	231 1.5	325 1.5	577 1.5	1120 1.5
Blind		66 1.5	120 1.5	77 1.5	146 1.5	181 1.5	267 1.5	338 1.5	599 1.5	1248 1.5
S.R. 90° Elbow		182 4.8	306 4.9	240 4.8	343 4.9	462 5.2	747 5.6	995 5.8		
L.R. 90° Elbow		237 5.8		290 5.8	438 5.8					
45° Elbow		152 4.1	256 4.2	185 4.1	288 4.2	332 4.3	572 4.6	732 4.7		
Tee		277 7.2	446 7.4	353 7.2	527 7.4	578 7.8	1007 8.4	1417 8.7		
Flanged Bonnet Gate		471 7.7	899 8.3	455 4.5	750 5	1035 6	1575 6.9	2140 7.1	3690 8	
Flanged Bonnet - Globe or Angle		541 9.1	943 9.1	485 4.5	855 5.5	1070 6	1500 6.3	2500 6.8	4160 8	
Flanged Bonnet - Check		453 9.1	751 9.1	370 6	485 6.1	605 6.3	1030 6.8	1350 7	2280 7.5	
Pressure Seal - Bonnet, Gate							1450 4.9	1860 5.5	3150 6	
Pressure Seal - Bonnet, Globe								1800 5	1910 6	

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesia and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.

Sch./Wall Designation -->	PIPE											
	5S	10S	20	30	Std.	40	XS	60	80	120	140	160
Thickness -- In.	0.156	180	0.25	0.33	0.375	0.406	0.5	0.562	0.687	1	1.125	1.312
Pipe -- Lbs/Ft	20.99	24.20	33.38	43.8	49.6	53.5	65.4	73.2	88.5	125.5	139.7	160.3
Water -- Lbs/Ft	52.7	52.2	51.1	49.7	49	48.5	47	46	44	39.3	37.5	34.9
WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR												
 L.R. 90° Elbow	51.2 3	57 3			122 3		156 3					375 3
 S.R. 90° Elbow	33.6 2	38.1 2			82 2		104 2					
 L.R. 45° Elbow	25.5 1.3	29 1.3			60.3 1.3		78 1.3					182 1.3
 Tee	46.7 2.5	54 2.5			162 2.5		180 2.5					360 2.5
 Lateral	74.7 5.4	86.2 5.4			180 5.4		273 5.4					
 Reducer	14.1 0.7	20.9 0.7			33.4 0.7		43.6 0.7					94 0.7
 Cap	6.2 1.5	7.1 1.5			29.5 1.5		38.1 1.5					95 1.5

		PIPE INSULATION										
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1½	1½	2	2½	3	3	3½	4	4	4½	4½
Calcium Silicate	Lbs./Ft	6.04	6.04	8.13	10.5	12.7	12.7	15.1	17.9	17.9	20.4	20.4
Combination	Nom. Thick., In.						3	3½	4	4	4½	4½
	Lbs./Ft						17.7	21.9	26.7	26.7	31.1	31.1

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
 Screwed or Slip-On		58 1.5	123 1.5	71 1.5	140 1.5	164 1.5	261 1.5	388 1.5	820 1.5	1611 1.5
 Welding Neck				87 1.5	163 1.5	212 1.5	272 1.5	434 1.5	843 1.5	1919 1.5
 Lap Joint				71 1.5	164 1.5	187 1.5	286 1.5	433 1.5	902 1.5	1583 1.5
 Blind		95 1.5	165 1.5	117 1.5	209 1.5	261 1.5	341 1.5	475 1.5	928 1.5	1775 1.5
 S.R. 90° Elbow		257 5	430 5.2	345 5	509 5.2	669 5.5	815 5.8	1474 6.2		
 L.R. 90° Elbow		357 6.2		485 6.2	624 6.2			1598 6.2		
 45° Elbow		227 4.3	360 4.3	282 4.3	414 4.3	469 4.5	705 4.7	1124 4.8		
 Tee		387 7.5	640 7.8	513 7.5	754 7.8	943 8.3	1361 8.7	1928 9.3		
 Flanged Bonnet Gate		687 7.8	1298 8.5	635 4	1015 5	1420 5.5	2155 7	2770 7.2	4650 8	
 Flanged Bonnet - Globe or Angle		808 9.4	1200 9.5	710 5	1410 5.5					
 Flanged Bonnet - Check		674 9.4	1160 9.5	560 6	720 6.5		1410 7.2	2600 8	3370 8	
 Pressure Seal - Bonnet, Gate							1975 5.5	2560 6	4515 7	
 Pressure Seal - Bonnet, Globe										

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.



PIPE												
Sch./Wall Designation -->	5S	10S	10	20	30/Std.	40	XS	60	80	120	140	160
Thickness -- In.	0.156	188	0.25	0.312	0.375	438	0.5	0.593	0.75	1.093	1.25	1.406
Pipe -- Lbs/Ft	23.0	27.7	36.71	45.7	54.6	63.4	72.1	84.9	106.1	150.7	170.2	189.1
Water -- Lbs/Ft	63.7	63.1	62.06	60.92	59.7	58.7	57.5	55.9	53.2	47.5	45	42.6

WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR												
L.R. 90° Elbow	65.6 3.5	78 3.5			157 3.5		200 3.5					
S.R. 90° Elbow	43.1 2.3	51.7 2.3			108 2.3		135 2.3					
L.R. 45° Elbow	32.5 1.5	39.4 1.5			80 1.5		98 1.5					
Tee	49.4 2.8	59.6 2.8			196 2.8		220 2.8					
Lateral	94.4 5.8	113 5.8			218 5.8		340 5.8					
Reducer	25 1.1	31.2 1.1			63 1.1		83 1.1					
Cap	7.6 1.7	9.2 1.7			35.3 1.7		45.9 1.7					

PIPE INSULATION												
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1½	1½	2	2½	3	3	3½	4	4	4½	4½
Calcium Silicate	Lbs./Ft	6.16	6.16	8.38	10.7	13.1	13.1	15.8	18.5	18.5	21.3	21.3
Combination	Nom. Thick., In.						3	3½	4	4	4½	4½
	Lbs./Ft						18.2	22.8	27.5	27.5	32.4	32.4

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR												
		Pressure Rating (PSI)										
		Cast Iron		Steel								
		125	250	150	300	400	600	900	1500	2500		
Screwed or Slip-On		90 1.5	184 1.5	95 1.5	195 1.5	235 1.5	318 1.5	460 1.5	1016 1.5			
Welding Neck				130 1.5	217 1.5	277 1.5	406 1.5	642 1.5	1241 1.5			
Lap Joint				119 1.5	220 1.5	254 1.5	349 1.5	477 1.5	1076 1.5			
Blind		125 1.5	239 1.5	141 1.5	267 1.5	354 1.5	437 1.5	574 1.5				
S.R. 90° Elbow		360 5.3	617 5.5	497 5.3	632 5.5	664 5.7	918 5.9	1549 6.4				
L.R. 90° Elbow		480 6.6	767 6.6	622 6.6	772 6.6							
45° Elbow		280 4.3	497 4.4	377 4.3	587 4.4	638 4.6	883 4.8	1246 4.9				
Tee		540 8	956 8.4	683 8	968 8.3	1131 8.6	1652 8.9	2318 9.6				
Flanged Bonnet Gate		921 7.9	1762 8.8	905 4.9	1525 6	1920 6.3	2960 7	4170 8	6425 8.8			
Flanged Bonnet - Globe or Angle		1171 9.9										
Flanged Bonnet - Check		885 9.9		1010 5	1155 5.2							
Pressure Seal - Bonnet, Gate							2620 6	3475 6.5	6380 7.5			
Pressure Seal - Bonnet, Globe												

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.

Sch./Wall Designation -->	PIPE											
	5S	10S	10	20	30/Std	40	60/XS	80	100	120	140	160
Thickness -- In.	0.165	0.188	0.25	0.312	0.375	0.5	0.656	0.843	1.031	1.218	1.438	1.593
Pipe -- Lbs/Ft	28.0	32.0	42.1	52.4	62.6	82.8	107.5	136.5	164.8	192.3	223.6	245.1
Water -- Lbs/Ft	83.5	83	81.8	80.5	79.1	76.5	73.4	69.7	66.1	62.6	58.6	55.9

WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR						
 L.R. 90° Elbow	89.8 4	102 4			208 4	270 4
 S.R. 90° Elbow	59.7 2.5	67.7 2.5			135 2.5	177 2.5
 L.R. 45° Elbow	44.9 1.7	51 1.7			104 1.7	136 1.7
 Tee	66.8 3.2	75.9 3.2			250 3.2	278 3.2
 Lateral	127 6.7	144 6.7			275 6.7	431 6.7
 Reducer	31.3 1.2	35.7 1.2			77 1.2	102 1.2
 Cap	10.1 1.8	11.5 1.8			44.3 1.8	57 1.8

PIPE INSULATION												
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1½	1½	2	2½	3	3	3½	4	4	4½	4½
Calcium Silicate	Lbs./Ft	6.9	6.9	9.33	12	14.6	14.6	17.5	20.5	20.5	23.6	23.6
Combination	Nom. Thick., In.						3	3½	4	4	4½	4½
	Lbs./Ft						20.3	25.2	30.7	30.7	36	36

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
	Screwed or Slip-On	114 1.5	233 1.5	107 1.5	262 1.5	310 1.5	442 1.5	559 1.5	1297 1.5	
	Welding Neck			141 1.5	288 1.5	351 1.5	577 1.5	785 1.5	1597 1.5	
	Lap Joint			142 1.5	282 1.5	337 1.5	476 1.5	588 1.5	1372 1.5	
	Blind	174 1.5	308 1.5	184 1.5	349 1.5	455 1.5	603 1.5	719 1.5		
	S.R. 90° Elbow	484 5.5	826 5.8	656 5.5	958 5.8	1014 6	1402 6.3	1886 6.7		
	L.R. 90° Elbow	684 7	1036 7	781 7	1058 7					
	45° Elbow	374 4.3	696 4.6	481 4.3	708 4.6	839 4.7	1212 5	1586 5		
	Tee	714 8.3	1263 8.7	961 8.3	1404 8.6	1671 9	2128 9.4	3054 10		
	Flanged Bonnet Gate	1254 8	2321 9	1190 5	2015 7	2300 7.2	3675 7.9	4950 8.2	7875 9	
	Flanged Bonnet – Globe or Angle									
	Flanged Bonnet – Check	1166 10.5			1225 6					
	Pressure Seal – Bonnet, Gate						3230 7		8130 8	
	Pressure Seal – Bonnet, Globe									

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesia and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.



PIPE												
Sch./Wall Designation -->	5S	10S	10	20	Std.	30	XS	40	60	80	120	160
Thickness -- In.	0.165	0.188	0.25	0.312	0.375	0.438	0.5	0.562	750	937	1.375	1.781
Pipe -- Lbs/Ft	31.0	36.0	47.4	59.0	70.6	82.1	93.5	104.8	138.2	170.8	244.1	308.5
Water -- Lbs/Ft	106.2	105.7	104.3	102.8	101.2	99.9	98.4	97	92.7	88.5	79.2	71
WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR												
L.R. 90° Elbow	114 4.5	129 4.5			256 4.5		332 4.5					
S.R. 90° Elbow	75.7 2.8	85.7 2.8			176 2.8		225 2.8					
L.R. 45° Elbow	57.2 1.9	64.5 1.9			132 1.9		168 1.9					
Tee	83.2 3.6	94.7 3.6			282 3.6		351 3.6					
Lateral	157 7.5	179 7.5			326 7.5		525 7.5					
Reducer	42.6 1.3	48.5 1.3			94 1.3		123 1.3					
Cap	12.7 2.1	14.5 2.1			57 2.1		75 2.1					

PIPE INSULATION												
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1½	1½	2	2½	3	3	3½	4	4	4½	4½
Calcium Silicate	Lbs./Ft	7.73	7.73	10.4	13.3	16.3	16.3	19.3	22.6	22.6	25.9	25.9
Combination	Nom. Thick., In.						3	3½	4	4	4½	4½
	Lbs/Ft						22.7	28	33.8	33.8	39.5	39.5

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
Screwed or Slip-On		125 1.5		139 1.5	331 1.5	380 1.5	573 1.5	797 1.5	1694 1.5	
Welding Neck				159 1.5	355 1.5	430 1.5	652 1.5	1074 1.5	2069 1.5	
Lap Joint				165 1.5	355 1.5	415 1.5	566 1.5	820 1.5	1769 1.5	
Blind		209 1.5	396 1.5	228 1.5	440 1.5	572 1.5	762 1.5	1030 1.5		
S.R. 90° Elbow		599 5.8	1060 6	711 5.8	1126 6	1340 6.2	1793 6.6	2817 7		
L.R. 90° Elbow			1350 7.4	941 7.4	1426 7.4					
45° Elbow		439 4.4	870 4.7	521 4.4	901 4.7	1040 4.8	1543 5	2252 5.2		
Tee		879 8.6	1625 9	1010 8.6	1602 9	1909 9.3	2690 9.9	4327 10.5		
Flanged Bonnet Gate		1629 8.2	2578 9.3	1510 6	2505 6.5	3765 7	4460 7.8	6675 8.5		
Flanged Bonnet - Globe or Angle										
Flanged Bonnet - Check		1371 10.5								
Pressure Seal - Bonnet, Gate							3100 5.5	3400 5.6	4200 6	
Pressure Seal - Bonnet, Globe										

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.

Sch./Wall Designation -->	PIPE											
	5S	10S	10	20/Std.	30/XS	40	60	80	100	120	140	160
Thickness -- In.	0.188	0.218	0.25	0.375	0.5	0.593	0.812	1.031	1.281	1.5	1.75	1.968
Pipe -- Lbs/Ft	40.0	46.0	52.7	78.6	104.1	122.9	166.4	208.9	256.1	296.4	341.1	379.0
Water -- Lbs/Ft	131	130.2	129.5	126	122.8	120.4	115	109.4	103.4	98.3	92.6	87.9

WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR					
 L.R. 90° Elbow	160 5	185 5		322 5	438 5
 S.R. 90° Elbow	106 3.4	122 3.4		238 3.4	278 3.4
 L.R. 45° Elbow	80.3 2.1	92.5 2.1		160 2.1	228 2.1
 Tee	112 4	130 4		378 4	490 4
 Lateral	228 8.3	265 8.3		396 8.3	625 8.3
 Reducer	71.6 1.7	87.6 1.7		142 1.7	186 1.7
 Cap	17.7 2.3	20.5 2.3		71 2.3	93 2.3

PIPE INSULATION												
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1½	1½	2	2½	3	3	3½	4	4	4½	4½
Calcium Silicate	Lbs./Ft	8.45	8.45	11.6	14.6	17.7	17.7	21.1	24.6	24.6	28.1	28.1
Combination	Nom. Thick., In.						3	3½	4	4	4½	4½
	Lbs/Ft						24.7	30.7	37	37	43.1	43.1

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
	Screwed or Slip-On	153 1.5		180 1.5	378 1.5	468 1.5	733 1.5	972 1.5	2114 1.5	
	Welding Neck			195 1.5	431 1.5	535 1.5	811 1.5	1344 1.5	2614 1.5	
	Lap Joint			210 1.5	428 1.5	510 1.5	725 1.5	1048 1.5	2189 1.5	
	Blind	275 1.5	487 1.5	297 1.5	545 1.5	711 1.5	976 1.5	1287 1.5		
	S.R. 90° Elbow	792 6	1315 6.3	922 6	1375 6.3	1680 6.5	2314 6.9	3610 7.3		
	L.R. 90° Elbow	1132 7.8	1725 7.8	1352 7.8	1705 7.8					
	45° Elbow	592 4.6	1055 4.8	652 4.6	1105 4.8	1330 4.9	1917 5.2	2848 5.4		
	Tee	1178 9	2022 9.5	1378 9	1908 9.5	2370 9.7	3463 10.1	5520 11		
	Flanged Bonnet Gate	1934 8.3	3823 9.5	1855 6	3370 7	5700 8	5755 8			
	Flanged Bonnet - Globe or Angle									
	Flanged Bonnet - Check	1772 11								
	Pressure Seal - Bonnet, Gate									
	Pressure Seal - Bonnet, Globe									

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.



PIPE											
Sch./Wall Designation -->	5S	10	20/Std.	XS	30	40	60	80	120	140	160
Thickness -- In.	0.218	0.25	0.375	0.5	0.562	0.687	0.968	1.218	1.812	2.062	2.343
Pipe -- Lbs/Ft	55.0	63.4	94.6	125.5	140.8	171.2	238.1	296.4	429.4	483.1	541.9
Water -- Lbs/Ft	188.9	188	183.8	180.1	178.1	174.3	165.8	158.3	141.4	134.5	127

WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR				
L.R. 90° Elbow	260 6		500 6	578 6
S.R. 90° Elbow	178 3.7		305 3.7	404 3.7
L.R. 45° Elbow	130 2.5		252 2.5	292 2.5
Tee	174 4.9		544 4.9	607 4.9
Lateral	361 10		544 10	875 10
Reducer	107 1.7		167 1.7	220 1.7
Cap	28.6 2.8		102 2.8	134 2.8

PIPE INSULATION												
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1½	1½	2	2½	3	3	3½	4	4	4½	4½
Calcium Silicate	Lbs./Ft	10	10	13.4	17	21	21	24.8	28.7	28.7	32.9	32.9
Combination	Nom. Thick., In.						3	3½	4	4	4½	4½
	Lbs/Ft						29.2	36	43.1	43.1	50.6	50.6

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
Screwed or Slip-On		236 1.5		245 1.5	577 1.5	676 1.5	1056 1.5	1823 1.5	3378 1.5	
Welding Neck				295 1.5	632 1.5	777 1.5	1157 1.5	2450 1.5	4153 1.5	
Lap Joint				295 1.5	617 1.5	752 1.5	1046 1.5	2002 1.5	3478 1.5	
Blind		404 1.5	757 1.5	446 1.5	841 1.5	1073 1.5	1355 1.5	2442 1.5		
S.R. 90° Elbow		1231 6.7	2014 6.8	1671 6.7	2174 6.8	2474 7.1	3506 7.6	6155 8.1		
L.R. 90° Elbow		1711 8.7	2644 8.7	1821 8.7	2874 8.7					
45° Elbow		871 4.8	1604 5	1121 4.8	1634 5	1974 5.1	2831 5.5	5124 6		
Tee		1836 10	3061 10.2	2276 10	3161 10.2	3811 10.6	5184 11.4	9387 12.1		
Flanged Bonnet Gate		3062 8.5	6484 9.8	2500 5	4675 7	6995 8.7	8020 9.5			
Flanged Bonnet - Globe or Angle										
Flanged Bonnet - Check		2956 12								
Pressure Seal - Bonnet, Gate										
Pressure Seal - Bonnet, Globe										

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.

Sch./Wall Designation -->	PIPE								
		10	Std.	20/XS					
Thickness -- In.	0.25	0.312	0.375	0.5	0.625	0.75	0.875	1	1.125
Pipe -- Lbs/Ft	67.0	85.7	102.6	136.2	169.0	202.0	235.0	267.0	299.0
Water -- Lbs/Ft	221.4	219.2	216.8	212.5	208.6	204.4	200.2	196.1	192.1

WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR				
 L.R. 90° Elbow			502 8.5	713 8.5
 S.R. 90° Elbow			359 5	474 5
 L.R. 45° Elbow			269 3.5	355 3.5
 Tee			634 6.8	794 6.8
 Lateral				
 Reducer			200 4.3	272 4.3
 Cap			110 4.3	145 4.3

		PIPE INSULATION										
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1½	1½	2	2½	3	3½	4	4½	5	5	6
Calcium Silicate	Lbs./Ft	10.4	10.4	14.1	18	21.9	26	30.2	34.6	39.1	39.1	48.4
Combination	Nom. Thick., In.						3½	4½	5½	6	6½	7
	Lbs/Ft						37	51.9	67.8	76	84.5	93.2

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
 Screwed or Slip-On				292 1.5	699 1.5	650 1.5	950 1.5	1525 1.5		
 Welding Neck				342 1.5	799 1.5	750 1.5	1025 1.5	1575 1.5		
 Lap Joint										
 Blind				567 1.5	1179 1.5	1125 1.5	1525 1.5	2200 1.5		
 S.R. 90° Elbow										
 L.R. 90° Elbow										
 45° Elbow										
 Tee										
 Flanged Bonnet Gate										
 Flanged Bonnet - Globe or Angle										
 Flanged Bonnet - Check										
 Pressure Seal - Bonnet, Gate										
 Pressure Seal - Bonnet, Globe										

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.



PIPE									
Sch./Wall Designation -->		10	Std.	20/XS	30				
Thickness -- In.	0.25	0.312	0.375	0.5	0.625	0.75	0.875	1	1.125
Pipe -- Lbs/Ft	74.0	92.4	110.6	146.9	182.7	218.0	253.0	288.0	323.0
Water -- Lbs/Ft	257.3	255	252.7	248.1	243.6	238.9	234.4	230	225.6

WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR				
L.R. 90° Elbow			626 9	829 9
S.R. 90° Elbow			415 5.4	551 5.4
L.R. 45° Elbow			312 3.6	413 3.6
Tee			729 7	910 7
Lateral				
Reducer			210 2.7	290 2.7
Cap			120 4.5	160 4.5

PIPE INSULATION												
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1½	1½	2	2½	3	3½	4	4½	5	5	6
Calcium Silicate	Lbs./Ft	11.2	11.2	15.1	19.2	23.4	27.8	32.3	36.9	41.6	41.6	51.4
Combination	Nom. Thick., In.						3½	4½	5½	6	6½	7
	Lbs/Ft						39.5	55.4	72.2	80.9	89.8	99

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
	Screwed or Slip-On			334 1.5	853 1.5	780 1.5	1075 1.5	1800 1.5		
	Welding Neck			364 1.5	943 1.5	880 1.5	1175 1.5	1850 1.5		
	Lap Joint									
	Blind			669 1.5	1408 1.5	1425 1.5	1750 1.5	2575 1.5		
	S.R. 90° Elbow									
	L.R. 90° Elbow									
	45° Elbow									
	Tee									
	Flanged Bonnet Gate									
	Flanged Bonnet – Globe or Angle									
	Flanged Bonnet – Check									
	Pressure Seal – Bonnet, Gate									
	Pressure Seal – Bonnet, Globe									

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.

Sch./Wall Designation -->	PIPE								
	5S	10 & 10S	Std.	20/XS	30				
Thickness -- In.	0.25	0.312	0.375	.500	0.625	0.75	0.875	1	1.125
Pipe -- Lbs/Ft	.79	98.9	118.7	157.6	196.1	234.0	272.0	310.0	347.0
Water -- Lbs/Ft	296.3	293.5	291	286	281.1	276.6	271.8	267	262.2

WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR						
 L.R. 90° Elbow	478.0 10		775 10	953 10		596 10
 S.R. 90° Elbow	319 5.9		470 5.9	644 5.9		388 5.9
 L.R. 45° Elbow	239 3.9		358 3.9	475 3.9		298 3.9
 Tee			855 7.8	1065 7.8		
 Lateral						
 Reducer			220 3.9	315 3.9		
 Cap			125 4.8	175 4.8		

		PIPE INSULATION										
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1½	1½	2	2½	3	3½	4	4½	5	5	6
Calcium Silicate	Lbs./Ft	11.9	11.9	16.1	20.5	25	29.5	34.3	39.1	44.1	44.1	54.4
Combination	Nom. Thick., In.						3½	4½	5½	6	6½	7
	Lbs/Ft						42.1	58.9	76.5	85.7	95.1	104.7

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
 Screwed or Slip-On				365 1.5	975 1.5	900 1.5	1175 1.5	2075 1.5		
 Welding Neck				410 1.5	1095 1.5	1000 1.5	1300 1.5	2150 1.5		
 Lap Joint										
 Blind				770 1.5	1665 1.5	1675 1.5	2000 1.5	3025 1.5		
 S.R. 90° Elbow										
 L.R. 90° Elbow										
 45° Elbow										
 Tee										
 Flanged Bonnet Gate										
 Flanged Bonnet - Globe or Angle										
 Flanged Bonnet - Check										
 Pressure Seal - Bonnet, Gate										
 Pressure Seal - Bonnet, Globe										

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/ cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.



PIPE										
Sch./Wall Designation -->		10	Std.	20/XS	30	40				
Thickness -- In.	0.25	0.312	0.375	0.5	0.625	688	0.75	0.875	1	1.125
Pipe -- Lbs/Ft	85.0	105.8	126.7	168.2	209.4	229.9	250.0	291.0	331.0	371.0
Water -- Lbs/Ft	337.8	335	323.3	327	321.8	319.2	316.7	311.6	306.4	301.3

WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR				
L.R. 90° Elbow			818 10.5	1090 10.5
S.R. 90° Elbow			546 6.3	722 6.3
L.R. 45° Elbow			408 4.2	541 4.2
Tee			991 8.4	1230 8.4
Lateral				
Reducer			255 3.1	335 3.1
Cap			145 5.2	190 5.2

PIPE INSULATION												
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1½	1½	2	2½	3	3½	4	4½	5	5	6
Calcium Silicate	Lbs./Ft	12.7	12.7	17.1	21.7	26.5	31.3	36.3	41.4	46.6	46.6	57.5
Combination	Nom. Thick., In.						3½	4½	5½	6	6½	7
	Lbs/Ft						44.7	62.3	80.9	90.5	100.4	110.5

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
	Screwed or Slip-On			476 1.5	1093 1.5	1025 1.5	1375 1.5	2500 1.5		
	Welding Neck			516 1.5	1228 1.5	1150 1.5	1500 1.5	2575 1.5		
	Lap Joint									
	Blind			951 1.5	1978 1.5	1975 1.5	2300 1.5	3650 1.5		
	S.R. 90° Elbow									
	L.R. 90° Elbow									
	45° Elbow									
	Tee									
	Flanged Bonnet Gate									
	Flanged Bonnet – Globe or Angle									
	Flanged Bonnet – Check									
	Pressure Seal – Bonnet, Gate									
	Pressure Seal – Bonnet, Globe									

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.

Sch./Wall Designation -->	PIPE									
		10	Std.	20/XS	30	40				
Thickness -- In.	0.25	0.312	0.375	0.5	625	688	0.75	0.875	1	1.125
Pipe -- Lbs/Ft	90.0	112.4	134.7	178.9	222.8	244.6	266.0	310.0	353.0	395.0
Water -- Lbs/Ft	382	379.1	376	370.3	365	362.2	359.5	354.1	348.6	343.2

WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR				
 L.R. 90° Elbow			926 11	1230 11
 S.R. 90° Elbow			617 5.5	817 5.5
 L.R. 45° Elbow			463 4.4	615 4.4
 Tee			1136 8.9	1420 8.9
 Lateral				
 Reducer			270 3.3	355 3.3
 Cap			160 5.6	210 5.6

		PIPE INSULATION										
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1½	1½	2	2½	3	3½	4	4½	5	5	6
Calcium Silicate	Lbs./Ft	13.4	13.4	18.2	23	28	33.1	38.3	43.7	49.1	49.1	60.5
Combination	Nom. Thick., In.						3½	4½	5½	6	6½	7
	Lbs/Ft						47.2	65.8	85.3	95.4	105.7	116.3

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
 Screwed or Slip-On				515 1.5	1281 1.5	1150 1.5	1500 1.5	2950 1.5		
 Welding Neck				560 1.5	1406 1.5	1300 1.5	1650 1.5	3025 1.5		
 Lap Joint										
 Blind				1085 1.5	2231 1.5	2250 1.5	2575 1.5	4275 1.5		
 S.R. 90° Elbow										
 L.R. 90° Elbow										
 45° Elbow										
 Tee										
 Flanged Bonnet Gate										
 Flanged Bonnet - Globe or Angle										
 Flanged Bonnet - Check										
 Pressure Seal - Bonnet, Gate										
 Pressure Seal - Bonnet, Globe										

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.



PIPE									
Sch./Wall Designation -->		10	Std.	20/XS	30	40			
Thickness -- In.	0.25	0.312	0.375	0.5	0.625	0.75	0.875	1	1.125
Pipe -- Lbs/Ft	96.0	119.1	142.7	189.6	236.1	282.4	328.0	374.0	419.0
Water -- Lbs/Ft	429.1	425.9	422.6	416.6	411	405.1	399.4	393.6	387.9

WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR				
L.R. 90° Elbow			1040 12	1380 12
S.R. 90° Elbow			692 5	913 5
L.R. 45° Elbow			518 4.8	686 4.8
Tee			1294 9.5	1610 9.5
Lateral				
Reducer			340 3.6	360 3.6
Cap			175 6	235 6

PIPE INSULATION												
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1½	1½	2	2½	3	3½	4	4½	5	5	6
Calcium Silicate	Lbs./Ft	14.2	14.2	19.2	24.2	29.5	34.8	40.3	45.9	51.7	51.7	63.5
Combination	Nom. Thick., In.						3½	4½	5½	6	6½	7
	Lbs/Ft						49.8	69.3	89.7	100.2	111	122

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
	Screwed or Slip-On			588 1.5	1485 1.5	1325 1.5	1600 1.5	3350 1.5		
	Welding Neck			628 1.5	1585 1.5	1475 1.5	1750 1.5	3450 1.5		
	Lap Joint									
	Blind			1233 1.5	2560 1.5	2525 1.5	2950 1.5	4900 1.5		
	S.R. 90° Elbow									
	L.R. 90° Elbow									
	45° Elbow									
	Tee									
	Flanged Bonnet Gate									
	Flanged Bonnet - Globe or Angle									
	Flanged Bonnet - Check									
	Pressure Seal - Bonnet, Gate									
	Pressure Seal - Bonnet, Globe									

- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.

PIPE								
Sch./Wall Designation -->		Std.	20/XS	30	40			
Thickness -- In.	0.25	0.375	0.5	0.625	0.75	1	1.25	1.5
Pipe -- Lbs/Ft	112.0	166.7	221.6	276.0	330.0	438.0	544.0	649.0
Water -- Lbs/Ft	586.4	578.7	571.7	565.4	558.4	544.8	531.2	517.9

WELDED FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR				
 L.R. 90° Elbow		1420 15	1880 15	
 S.R. 90° Elbow		1079 9	1430 9	
 L.R. 45° Elbow		707 6	937 6	
 Tee		1870	2415	
 Lateral				
 Reducer		310 4.5	410 4.5	
 Cap		230 7.5	300 7.5	

PIPE INSULATION												
Temp. Range -->		100-199	200-299	300-399	400-499	500-599	600-699	700-799	800-899	900-999	1,000-1,099	1,100-1,200
85% Magnesite	Nom. Thick., In.	1½	1½	2	2½	3	3½	4	4½	5	5	6
Calcium Silicate	Lbs./Ft	16.5	16.5	22.2	28	34	40.1	46.4	52.7	59.2	59.2	72.6
Combination	Nom. Thick., In.						3½	4½	5½	6	6½	7
	Lbs/Ft						57.4	79.7	102.8	114.8	126.9	139.3

CAST IRON & STEEL FITTINGS - LINE 1: WEIGHT IN POUNDS, LINE 2: INSULATION FACTOR										
		Pressure Rating (PSI)								
		Cast Iron		Steel						
		125	250	150	300	400	600	900	1500	2500
	Screwed or Slip-On			792 1.5	1895 1.5	1759 1.5	2320 1.5			
	Welding Neck			862 1.5	2024 1.5	1879 1.5	2414 1.5			
	Lap Joint									
	Blind			1733 1.5	3449 1.5	3576 1.5	4419 1.5			
	S.R. 90° Elbow									
	L.R. 90° Elbow									
	45° Elbow									
	Tee									
	Flanged Bonnet Gate									
	Flanged Bonnet - Globe or Angle									
	Flanged Bonnet - Check									
	Pressure Seal - Bonnet, Gate									
	Pressure Seal - Bonnet, Globe									


- Insulation thicknesses and weights are based on average conditions and do not constitute a recommendation for specific thicknesses of materials.
- Insulation weights are based on 85% magnesite and hydrous calcium silicate at 11 lbs/cu. foot. The listed thicknesses and weights of combination covering are the sums of the inner layer of diatomaceous earth at 21 lbs/cu. foot and the outer layer at 11 lbs/cubic foot.
- Insulation weights include allowances for wire, cement, canvas, bands and paint but not special surface finishes.
- To find the weight of covering on flanges, valves or fittings, multiply the weight factor by the weight per foot of covering used on straight pipe.
- Valve weights are approximate. Whenever possible, obtain weights from the manufacturer.
- Cast iron valve weights are for flanged end valves; steel weights for welding end valves.
- All flanged fitting, flanged valve and flange weights include the proportional weight of bolts or studs to make up all joints.

Note: **Boldface type** is weight in pounds and light type underneath is weight factor for insulation.




THERMAL EXPANSION OF PIPE MATERIALS — INCHES PER FOOT										
	Carbon Steel • Carbon Moly Steel • Low-Chrome Steel (Thru 3% Cr) — Temperature									
Temp °F	0	10	20	30	40	50	60	70	80	90
-200	-0.0180	-0.0187	-0.0192	-0.0198	-0.0203	-0.0209	-0.0215	-0.0220	-0.0225	-0.0230
-100	-0.0121	-0.0127	-0.0133	-0.0140	-0.0146	-0.0152	-0.0158	-0.0163	-0.0169	-0.0171
0	-0.0051	-0.0058	-0.0065	-0.0073	-0.0080	-0.0087	-0.0096	-0.0103	-0.0109	-0.0116
0	-0.0051	-0.0044	-0.0037	-0.0029	-0.0022	-0.0015	-0.0007	0.0000	0.0008	0.0015
100	0.0023	0.0030	0.0038	0.0046	0.0053	0.0061	0.0068	0.0076	0.0084	0.0091
200	0.0099	0.0107	0.0116	0.0124	0.0132	0.0141	0.0149	0.0157	0.0165	0.0174
300	0.0182	0.0191	0.0200	0.0208	0.0217	0.0226	0.0235	0.0244	0.0252	0.0261
400	0.0270	0.0279	0.0288	0.0298	0.0307	0.0316	0.0325	0.0344	0.0344	0.0353
500	0.0362	0.0372	0.0382	0.0391	0.0401	0.0411	0.0421	0.0431	0.0440	0.0450
600	0.0460	0.0470	0.0481	0.0491	0.0501	0.0512	0.0522	0.0532	0.0542	0.0553
700	0.0563	0.0574	0.0584	0.0595	0.0606	0.0617	0.0627	0.0638	0.0649	0.0659
800	0.0670	0.0681	0.0692	0.0703	0.0714	0.0726	0.0737	0.0748	0.0759	0.0770
900	0.0781	0.0792	0.0803	0.0813	0.0824	0.0835	0.0846	0.0857	0.0867	0.0878
1,000	0.0889	0.0901	0.0912	0.0924	0.9350	0.0946	0.0958	0.0970	0.0981	0.3993
1,100	0.1004	0.1015	0.1025	0.1036	0.1046	0.1057	0.1068	0.1078	0.1089	0.1099
1,200	0.1110	0.1121	0.1132	0.1144	0.1155	0.1166	0.1177	0.1188	0.1200	0.1211
1,300	0.1222	0.1233	0.1244	0.1256	0.1267	0.1278	0.1299	0.1320	0.1342	0.1363
1,400	0.1334	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000


THERMAL EXPANSION OF PIPE MATERIALS — INCHES PER FOOT										
	Carbon Steel • Carbon Moly Steel • Low-Chrome Steel (Thru 3% Cr) — Temperature									
Temp °F	0	10	20	30	40	50	60	70	80	90
-200	-0.0180	-0.0187	-0.0192	-0.0198	-0.0203	-0.0209	-0.0215	-0.0220	-0.0225	-0.0230
-100	-0.0121	-0.0127	-0.0133	-0.0140	-0.0146	-0.0152	-0.0158	-0.0163	-0.0169	-0.0171
0	-0.0051	-0.0058	-0.0065	-0.0073	-0.0080	-0.0087	-0.0096	-0.0103	-0.0109	-0.0116
0	-0.0051	-0.0044	-0.0037	-0.0029	-0.0022	-0.0015	-0.0007	0.0000	0.0008	0.0015
100	0.0023	0.0030	0.0038	0.0046	0.0053	0.0061	0.0068	0.0076	0.0084	0.0091
200	0.0099	0.0107	0.0116	0.0124	0.0132	0.0141	0.0149	0.0157	0.0165	0.0174
300	0.0182	0.0191	0.0200	0.0208	0.0217	0.0226	0.0235	0.0244	0.0252	0.0261
400	0.0270	0.0279	0.0288	0.0298	0.0307	0.0316	0.0325	0.0344	0.0344	0.0353
500	0.0362	0.0372	0.0382	0.0391	0.0401	0.0411	0.0421	0.0431	0.0440	0.0450
600	0.0460	0.0470	0.0481	0.0491	0.0501	0.0512	0.0522	0.0532	0.0542	0.0553
700	0.0563	0.0574	0.0584	0.0595	0.0606	0.0617	0.0627	0.0638	0.0649	0.0659
800	0.0670	0.0681	0.0692	0.0703	0.0714	0.0726	0.0737	0.0748	0.0759	0.0770
900	0.0781	0.0792	0.0803	0.0813	0.0824	0.0835	0.0846	0.0857	0.0867	0.0878
1,000	0.0889	0.0901	0.0912	0.0924	0.9350	0.0946	0.0958	0.0970	0.0981	0.3993
1,100	0.1004	0.1015	0.1025	0.1036	0.1046	0.1057	0.1068	0.1078	0.1089	0.1099
1,200	0.1110	0.1121	0.1132	0.1144	0.1155	0.1166	0.1177	0.1188	0.1200	0.1211
1,300	0.1222	0.1233	0.1244	0.1256	0.1267	0.1278	0.1299	0.1320	0.1342	0.1363
1,400	0.1334	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000



Values are plotted for the pipes empty since this more nearly approaches the condition that exists for pocketing of condensation. Although the weight of fluid carried by the pipe will cause an increase in the deflection of the pipe between supports, this increased sag disappears during drainage. Therefore, the deflection produced by the weight of empty pipe should be considered in determining slope for drainage.

This chart is based on $E = 29,000,000$ P.S.I.








MINIMUM DISTANCE TO FIRST RIGID HANGER


$$L = \sqrt{\frac{\Delta \times (\text{O.D. of Pipe}) \times 10^6}{1.6 \times S}}$$

S = 10,000 p.s.i


		Pipe Size, Pipe O.D.																
		1 1.315	1¼ 1.660	1½ 1.900	2 2.375	2½ 2.875	3 3.5	3½ 4	4 4.5	5 5.563	6 6.625	8 8.625	10 10.75	12 12.75	14 14	16 16	18 18	20 20
Deflection	¼	4½	5	5½	6	6½	7½	8	8½	9½	10	11½	13	14	15	16	17	17½
	½	6½	7	7½	8½	9½	10½	11	12	13	14½	16½	18½	20	21	22½	23½	25
	¾	8	9	9½	10½	11½	13	13½	14½	16	17½	20	22½	24½	25½	27½	29	30½
	1	9	10	11	12	13½	15	16	17	18½	20½	23	26	28	29½	31½	33½	35½
	1¼	10	11½	12	13½	15	16½	17½	19	21	23	26	29	31½	33	35½	37½	39½
	1½	11	12½	13½	15	16½	18	19½	20½	23	25	28½	31½	34½	36	38½	41	43½
	1¾	12	13½	14½	16	17½	19½	21	22	24½	27	30½	34½	37½	39	42	44½	47
	2	13	14½	15½	17	19	21	22½	23½	26½	29	33	36½	40	42	44½	47½	50
	2¼	13½	15½	16½	18½	20	22	23½	25	28	30½	35	39	42½	44½	47½	50½	53
	2½	14½	16	17	19½	21	23½	25	26½	29½	32	36½	41	44½	47	50	53	56
	2¾	15	17	18	20	22	24½	26	28	31	33½	38½	43	47	49	52½	55½	58½
	3	15½	17½	19	21	23	25½	27½	29	32½	35	40	45	49	51	55	58	61
	3½	17	19	20½	23	25	27½	29½	31½	35	38	43½	48½	53	55½	59	62½	66
	4	18	20½	22	24½	27	29½	31½	33½	37½	40½	46½	52	56½	59	63	67	70½
	4½	19	21½	23	26	28½	31½	33½	35½	39½	43	49½	55	60	62½	67	71	75
	5	20½	23	24½	27	30	33	35½	37½	41½	45½	52	58	63	66	70½	75	79
	5½	21½	24	25½	28½	31½	34½	37	39½	43½	47½	54½	61	66	69½	74	78½	83
	6	22	25	26½	30	33	36	38½	41	45½	50	57	63½	69	72½	77½	82	86½

AMERICAN STANDARD CHANNELS



Y in	Wt./Ft. lb	Width in	Z in
3	4.1	1 $\frac{3}{8}$	0.250
	5.0	1 $\frac{1}{2}$	
	6.0	1 $\frac{5}{8}$	
4	5.4	1 $\frac{5}{8}$	0.313
	7.25	1 $\frac{3}{4}$	
5	6.7	1 $\frac{3}{4}$	0.313
	9.0	1 $\frac{7}{8}$	
6	8.2	1 $\frac{7}{8}$	0.375
	10.5	2	
	13.0	2 $\frac{1}{8}$	
7	9.8	2 $\frac{1}{8}$	0.375
	12.15	2 $\frac{1}{4}$	
	14.75	2 $\frac{3}{8}$	
8	11.5	2 $\frac{1}{4}$	0.375
	13.75	2 $\frac{1}{4}$	
	18.75	2 $\frac{1}{2}$	
9	13.4	2 $\frac{3}{8}$	0.438
	15.0	2 $\frac{1}{2}$	
10	20.0	2 $\frac{5}{8}$	0.438
	25.0	3	
12	20.7	3	0.500
	25.0	3	
	30.0	3 $\frac{1}{8}$	
15	33.9	3 $\frac{3}{8}$	0.625
	40.0	3 $\frac{1}{2}$	
	50.0	3 $\frac{3}{4}$	
18	42.7	4	0.625
	45.8	4	
	51.9	4 $\frac{1}{8}$	
	58.0	4 $\frac{1}{4}$	

S SHAPES


Y in	Wt./Ft. lb	Width in	Z in
3	5.7	2 $\frac{3}{8}$	0.250
	7.5	2 $\frac{1}{2}$	
4	7.7	2 $\frac{5}{8}$	0.313
	9.5	2 $\frac{3}{4}$	
5	10.0	3	0.313
	14.75	3 $\frac{1}{4}$	
6	12.5	3 $\frac{3}{8}$	0.375
	12.25	3 $\frac{5}{8}$	
7	15.3	3 $\frac{3}{8}$	0.375
	20.0	3 $\frac{3}{8}$	
8	18.4	4	0.438
	23.0	4 $\frac{1}{8}$	
10	25.4	4 $\frac{5}{8}$	0.500
	35.0	5	
12	31.8	5	0.563
	35.0	5 $\frac{1}{8}$	
	40.8	5 $\frac{1}{4}$	
15	50.0	5 $\frac{1}{2}$	0.625
	54.7	6	
18	70.0	6 $\frac{1}{4}$	0.688
	75.5	6 $\frac{3}{8}$	
20	86.0	7	0.938
	96.0	7 $\frac{1}{4}$	
24	80.0	7	0.875
	90.0	7 $\frac{1}{8}$	
	100.0	7 $\frac{1}{4}$	

W SHAPES


Y in	Wt./Ft. lb	Width in	Z in
5	19.0	5	0.430
6	25.0	6 $\frac{1}{8}$	0.455
8	18.0	5 $\frac{1}{4}$	0.330
	21.0	5 $\frac{1}{4}$	0.400
	24.0	6 $\frac{1}{2}$	0.400
	28.0	6 $\frac{1}{2}$	0.465
	31.0	8	0.435
	35.0	8	0.495
	40.0	8 $\frac{1}{8}$	0.560
	48.0	8 $\frac{1}{8}$	0.685
	58.0	8 $\frac{1}{4}$	0.810
	67.0	8 $\frac{1}{4}$	0.935
10	22.0	5 $\frac{3}{4}$	0.360
	26.0	5 $\frac{3}{4}$	0.440
	30.0	5 $\frac{3}{4}$	0.510
	33.0	8	0.435
	39.0	8	0.530
	45.0	8	0.620
	49.0	10	0.560
	54.0	10	0.615
	60.0	10 $\frac{1}{8}$	0.680
	68.0	10 $\frac{1}{8}$	0.770
12	77.0	10 $\frac{1}{4}$	0.870
	88.0	10 $\frac{1}{4}$	0.990
	26.0	6 $\frac{1}{2}$	0.380
	30.0	6 $\frac{1}{2}$	0.440
	35.0	6 $\frac{1}{2}$	0.520
	40.0	8	0.515
	45.0	8	0.575
	50.0	8 $\frac{1}{8}$	0.640
	53.0	10	0.575
	58.0	10	0.640
14	65.0	12	0.605
	72.0	12	0.670
	79.0	12 $\frac{1}{8}$	0.735
	87.0	12 $\frac{1}{8}$	0.810
	96.0	12 $\frac{1}{8}$	0.900
	106.0	12 $\frac{1}{4}$	0.990
	30.0	6 $\frac{3}{4}$	0.385
	34.0	6 $\frac{3}{4}$	0.455
	38.0	6 $\frac{3}{4}$	0.515
	43.0	8	0.530
16	48.0	8	0.595
	53.0	8	0.660
	61.0	10	0.645
	68.0	10	0.720
	74.0	10 $\frac{1}{8}$	0.785
	82.0	10 $\frac{1}{8}$	0.855
	90.0	14 $\frac{1}{2}$	0.710
	99.0	14 $\frac{5}{8}$	0.780
	109.0	14 $\frac{5}{8}$	0.860
	120.0	14 $\frac{5}{8}$	0.940
18	132.0	14 $\frac{3}{4}$	1.030
	36.0	7	0.430
	40.0	7	0.505
	45.0	7	0.565
	50.0	7 $\frac{1}{8}$	0.630
	57.0	7 $\frac{1}{8}$	0.715
	67.0	10 $\frac{1}{4}$	0.665
	77.0	10 $\frac{1}{4}$	0.760
	89.0	10 $\frac{3}{8}$	0.875
	100.0	10 $\frac{3}{8}$	0.985
21	50.0	7 $\frac{1}{2}$	0.570
	55.0	7 $\frac{1}{2}$	0.630
	60.0	7 $\frac{1}{2}$	0.695
	65.0	7 $\frac{5}{8}$	0.750
	71.0	7 $\frac{5}{8}$	0.810
	76.0	11	0.680
	86.0	11 $\frac{1}{8}$	0.770
	97.0	11 $\frac{1}{8}$	0.870
	106.0	11 $\frac{1}{4}$	0.940
	62.0	8 $\frac{1}{4}$	0.615
24	68.0	8 $\frac{1}{4}$	0.685
	73.0	8 $\frac{1}{4}$	0.740
	83.0	8 $\frac{3}{8}$	0.835
	93.0	8 $\frac{3}{8}$	0.930
	101.0	12 $\frac{1}{4}$	0.800
	111.0	12 $\frac{3}{8}$	0.875
	122.0	12 $\frac{3}{8}$	0.960
	76.0	9	0.680
	84.0	9	0.770
	94.0	9 $\frac{1}{8}$	0.875
27	104.0	12 $\frac{3}{4}$	0.750
	117.0	12 $\frac{3}{4}$	0.850
	131.0	12 $\frac{7}{8}$	0.960
	94.0	10	0.745
	102.0	10	0.830
	114.0	10 $\frac{1}{8}$	0.930
	146.0	14	0.975
	108.0	10 $\frac{1}{2}$	0.760
	116.0	10 $\frac{1}{2}$	0.850
	124.0	10 $\frac{1}{2}$	0.930
30	132.0	10 $\frac{1}{2}$	1.000
	118.0	11 $\frac{1}{2}$	0.740
	130.0	11 $\frac{1}{2}$	0.855
	141.0	11 $\frac{1}{2}$	0.960
	135.0	12	0.790
	150.0	12	0.940
	160.0	12	1.020
	118.0	11 $\frac{1}{2}$	0.855
	130.0	11 $\frac{1}{2}$	0.960
	141.0	11 $\frac{1}{2}$	0.960



PRESSURE CONVERSIONS

To convert PSI to Feet of Water, find PSI value in the middle column and read Feet of Water in right hand column.
To convert Feet of Water to PSI, find Feet of Water value in the middle column and read PSI in left hand column.

Feet of Water			Feet of Water			Feet of Water			Feet of Water			Feet of Water		
PSI			PSI			PSI			PSI			PSI		
0.43	1	2.31	28.14	65	150.15	55.84	129	297.99	83.55	193	445.83	111.26	257	593.67
0.87	2	4.62	28.57	66	152.46	56.28	130	300.30	83.98	194	448.14	111.69	258	595.98
1.30	3	6.93	29.00	67	154.77	56.71	131	302.61	84.42	195	450.45	112.12	259	598.29
1.73	4	9.24	29.44	68	157.08	57.14	132	304.92	84.85	196	452.76	112.55	260	600.60
2.16	5	11.55	29.87	69	159.39	57.58	133	307.23	85.28	197	455.07	112.99	261	602.91
2.60	6	13.86	30.30	70	161.70	58.01	134	309.54	85.71	198	457.38	113.42	262	605.22
3.03	7	16.17	30.74	71	164.01	58.44	135	311.85	86.15	199	459.69	113.85	263	607.53
3.46	8	18.48	31.17	72	166.32	58.87	136	314.16	86.58	200	462.00	114.29	264	609.84
3.90	9	20.79	31.60	73	168.63	59.31	137	316.47	87.01	201	464.31	114.72	265	612.15
4.33	10	23.10	32.03	74	170.94	59.74	138	318.78	87.45	202	466.62	116.88	270	623.70
4.76	11	25.41	32.47	75	173.25	60.17	139	321.09	87.88	203	468.93	119.05	275	635.25
5.19	12	27.72	32.90	76	175.56	60.61	140	323.40	88.31	204	471.24	121.21	280	646.80
5.63	13	30.03	33.33	77	177.87	61.04	141	325.71	88.74	205	473.55	123.38	285	658.35
6.06	14	32.34	33.77	78	180.18	61.47	142	328.02	89.18	206	475.86	125.54	290	669.90
6.49	15	34.65	34.20	79	182.49	61.90	143	330.33	89.61	207	478.17	127.71	295	681.45
6.93	16	36.96	34.63	80	184.80	62.34	144	332.64	90.04	208	480.48	129.87	300	693.00
7.36	17	39.27	35.06	81	187.11	62.77	145	334.95	90.48	209	482.79	132.03	305	704.55
7.79	18	41.58	35.50	82	189.42	63.20	146	337.26	90.91	210	485.10	134.20	310	716.10
8.23	19	43.89	35.93	83	191.73	63.64	147	339.57	91.34	211	487.41	136.36	315	727.65
8.66	20	46.20	36.36	84	194.04	64.07	148	341.88	91.77	212	489.72	138.53	320	739.20
9.09	21	48.51	36.80	85	196.35	64.50	149	344.19	92.21	213	492.03	140.69	325	750.75
9.52	22	50.82	37.23	86	198.66	64.94	150	346.50	92.64	214	494.34	142.86	330	762.30
9.96	23	53.13	37.66	87	200.97	65.37	151	348.81	93.07	215	496.65	145.02	335	773.85
10.39	24	55.44	38.10	88	203.28	65.80	152	351.12	93.51	216	498.96	147.19	340	785.40
10.82	25	57.75	38.53	89	205.59	66.23	153	353.43	93.94	217	501.27	149.35	345	796.95
11.26	26	60.06	38.96	90	207.90	66.67	154	355.74	94.37	218	503.58	151.52	350	808.50
11.69	27	62.37	39.39	91	210.21	67.10	155	358.05	94.81	219	505.89	153.68	355	820.05
12.12	28	64.68	39.83	92	212.52	67.53	156	360.36	95.24	220	508.20	155.84	360	831.60
12.55	29	66.99	40.26	93	214.83	67.97	157	362.67	95.67	221	510.51	158.01	365	843.15
12.99	30	69.30	40.69	94	217.14	68.40	158	364.98	96.10	222	512.82	160.17	370	854.70
13.42	31	71.61	41.13	95	219.45	68.83	159	367.29	96.54	223	515.13	162.34	375	866.25
13.85	32	73.92	41.56	96	221.76	69.26	160	369.60	96.97	224	517.44	164.50	380	877.80
14.29	33	76.23	41.99	97	224.07	69.70	161	371.91	97.40	225	519.75	166.67	385	889.35
14.72	34	78.54	42.42	98	226.38	70.13	162	374.22	97.84	226	522.06	168.83	390	900.90
15.15	35	80.85	42.86	99	228.69	70.56	163	376.53	98.27	227	524.37	171.00	395	912.45
15.58	36	83.16	43.29	100	231.00	71.00	164	378.84	98.70	228	526.68	173.16	400	924.00
16.02	37	85.47	43.72	101	233.31	71.43	165	381.15	99.13	229	528.99	183.98	425	981.75
16.45	38	87.78	44.16	102	235.62	71.86	166	383.46	99.57	230	531.30	194.81	450	1,040
16.88	39	90.09	44.59	103	237.93	72.29	167	385.77	100.00	231	533.61	205.63	475	1,097
17.32	40	92.40	45.02	104	240.24	72.73	168	388.08	100.43	232	535.92	216.45	500	1,155
17.75	41	94.71	45.45	105	242.55	73.16	169	390.39	100.87	233	538.23	227.27	525	1,213
18.18	42	97.02	45.89	106	244.86	73.59	170	392.70	101.30	234	540.54	238.10	550	1,271
18.61	43	99.33	46.32	107	247.17	74.03	171	395.01	101.73	235	542.85	248.92	575	1,328
19.05	44	101.64	46.75	108	249.48	74.46	172	397.32	102.16	236	545.16	259.74	600	1,386
19.48	45	103.95	47.19	109	251.79	74.89	173	399.63	102.60	237	547.47	270.56	625	1,444
19.91	46	106.26	47.62	110	254.10	75.32	174	401.94	103.03	238	549.78	281.39	650	1,502
20.35	47	108.57	48.05	111	256.41	75.76	175	404.25	103.46	239	552.09	292.21	675	1,559
20.78	48	110.88	48.48	112	258.72	76.19	176	406.56	103.90	240	554.40	303.03	700	1,617
21.21	49	113.19	48.92	113	261.03	76.62	177	408.87	104.33	241	556.71	313.85	725	1,675
21.65	50	115.50	49.35	114	263.34	77.06	178	411.18	104.76	242	559.02	324.68	750	1,733
22.08	51	117.81	49.78	115	265.65	77.49	179	413.49	105.19	243	561.33	335.50	775	1,790
22.51	52	120.12	50.22	116	267.96	77.92	180	415.80	105.63	244	563.64	346.32	800	1,848
22.94	53	122.43	50.65	117	270.27	78.35	181	418.11	106.06	245	565.95	357.14	825	1,906
23.38	54	124.74	51.08	118	272.58	78.79	182	420.42	106.49	246	568.26	367.97	850	1,964
23.81	55	127.05	51.52	119	274.89	79.22	183	422.73	106.93	247	570.57	378.79	875	2,021
24.24	56	129.36	51.95	120	277.20	79.65	184	425.04	107.36	248	572.88	389.61	900	2,079
24.68	57	131.67	52.38	121	279.51	80.09	185	427.35	107.79	249	575.19	400.43	925	2,137
25.11	58	133.98	52.81	122	281.82	80.52	186	429.66	108.23	250	577.50	411.26	950	2,195
25.54	59	136.29	53.25	123	284.13	80.95	187	431.97	108.66	251	579.81	422.08	975	2,252
25.97	60	138.60	53.68	124	286.44	81.39	188	434.28	109.09	252	582.12	432.90	1000	2,310
26.41	61	140.91	54.11	125	288.75	81.82	189	436.59	109.52	253	584.43	649.4	1500	3,465
26.84	62	143.22	54.55	126	291.06	82.25	190	438.90	109.96	254	586.74	865.8	2000	4,620
27.27	63	145.53	54.98	127	293.37	82.68	191	441.21	110.39	255	589.05	1,082	2500	5,780
27.71	64	147.84	55.41	128	295.68	83.12	192	443.52	110.82	256	591.36	1,300	3000	6,930

PROPERTIES OF WATER AT SATURATION PRESSURE					
Temp °F	Saturation Pressure PSI (abs)	Density lb/ft ³	Density lb/gal	Convert Factor ft. of water to PSI	Absolute Viscosity lb./sec. ft.
32	0.0885	62.42	8.346	2.307	0.001203
40	0.1217	62.43	8.347	2.307	0.001042
50	0.1781	62.41	8.344	2.307	0.000880
60	0.2563	62.37	8.339	2.309	0.000753
70	0.3631	62.30	8.330	2.311	0.000657
80	0.5069	62.22	8.319	2.315	0.000579
90	0.6982	62.12	8.305	2.318	0.000513
100	0.9492	62.00	8.289	2.323	0.000460
110	1.275	61.84	8.268	2.328	0.000415
120	1.692	61.73	8.253	2.333	0.000376
130	2.222	61.54	8.228	2.340	0.000343
140	2.889	61.39	8.208	2.346	0.000316
150	3.718	61.20	8.182	2.353	0.000290
160	4.741	61.01	8.157	2.360	0.000269
170	5.992	60.79	8.128	2.369	0.000250
180	7.510	60.57	8.098	2.377	0.000233
190	9.339	60.35	8.069	2.386	0.000218
200	11.53	60.13	8.039	2.395	0.000205
210	14.12	59.88	8.006	2.405	0.000193
212	14.696	59.81	7.997	2.408	0.000191
220	17.19	59.63	7.973	2.415	0.000181
230	20.78	59.38	7.939	2.425	0.000171
240	24.97	59.10	7.902	2.436	0.000163
250	29.82	58.82	7.864	2.448	0.000154
275	45.42	58.09	7.767	2.479	0.000136
300	67.01	57.31	7.662	2.513	0.000124
350	134.6	55.59	7.432	2.591	0.000108
400	247.3	53.65	7.173	2.684	0.0000874
450	422.6	51.55	6.892	2.793	0.0000806
500	680.8	49.02	6.554	2.938	0.0000672
550	1045	45.87	6.133	3.139	0.0000605
600	1543	42.37	5.665	3.399	0.0000538
650	2208	37.31	4.988	3.860	0.0000470
700	3094	27.10	3.623	5.314	0.0000269

Decimal Foot — Inch Measurement
0.001302 — 1/64"
0.002604 — 1/32"
0.003906 — 3/64"
0.005208 — 1/16"
0.006510 — 5/64"
0.007813 — 3/32"
0.009115 — 7/64"
0.010417 — 1/8"
0.011719 — 9/64"
0.013021 — 5/32"
0.014323 — 11/64"
0.015625 — 3/16"
0.016927 — 13/64"
0.018229 — 7/32"
0.019531 — 15/64"
0.020833 — 1/4"
0.022135 — 17/64"
0.023438 — 9/32"
0.024740 — 19/64"
0.026042 — 5/16"
0.027344 — 21/64"
0.028646 — 11/32"
0.029948 — 23/64"
0.031250 — 3/8"
0.032552 — 25/64"
0.033854 — 13/32"
0.035156 — 27/64"
0.036458 — 7/16"
0.037760 — 29/64"
0.039063 — 15/32"
0.040365 — 31/64"
0.041667 — 1/2"

Decimal Foot — Inch Measurement
0.042969 — 33/64"
0.044271 — 17/32"
0.045573 — 35/64"
0.046875 — 9/16"
0.048177 — 37/64"
0.049479 — 19/32"
0.050781 — 39/64"
0.052083 — 5/8"
0.053385 — 41/64"
0.054688 — 21/32"
0.055990 — 43/64"
0.057292 — 11/16"
0.058594 — 45/64"
0.059896 — 23/32"
0.061198 — 47/64"
0.062500 — 3/4"
0.063802 — 49/64"
0.065104 — 25/32"
0.066406 — 51/64"
0.067708 — 13/16"
0.069010 — 53/64"
0.070313 — 27/32"
0.071615 — 55/64"
0.072917 — 7/8"
0.074219 — 57/64"
0.075521 — 29/32"
0.076823 — 59/64"
0.078125 — 15/16"
0.079427 — 61/64"
0.080729 — 31/32"
0.082031 — 63/64"
0.083333 — 1"

Decimal — Inch Foot — Measurement
0.166667 — 2"
0.250000 — 3"
0.333333 — 4"
0.416667 — 5"
0.500000 — 6"
0.583333 — 7"
0.666667 — 8"
0.750000 — 9"
0.833333 — 10"
0.916667 — 11"
1.000000 — 12"

Decimal Equiv. — Fraction
0.015625 — 1/64
0.031250 — 1/32
0.046875 — 3/64
0.062500 — 1/16
0.078125 — 5/64
0.093750 — 3/32
0.109375 — 7/64
0.125000 — 1/8
0.140625 — 9/64
0.156250 — 5/32
0.171875 — 11/64
0.187500 — 3/16
0.203125 — 13/64
0.218750 — 7/32
0.234375 — 15/64
0.250000 — 1/4

Decimal Equiv. — Fraction
0.265625 — 17/64
0.281250 — 9/32
0.296875 — 19/64
0.312500 — 5/16
0.328125 — 21/64
0.343750 — 11/32
0.359375 — 23/64
0.375000 — 3/8
0.390625 — 25/64
0.406250 — 13/32
0.421875 — 27/64
0.437500 — 7/16
0.453125 — 29/64
0.468750 — 15/32
0.484375 — 31/64
0.500000 — 1/2

Decimal Equiv. — Fraction
0.515625 — 33/64
0.531250 — 17/32
0.546875 — 35/64
0.562500 — 9/16
0.578125 — 37/64
0.593750 — 19/32
0.609375 — 39/64
0.625000 — 5/8
0.640625 — 41/64
0.656250 — 21/32
0.671875 — 43/64
0.687500 — 11/16
0.703125 — 45/64
0.718750 — 23/32
0.734375 — 47/64
0.750000 — 3/4

Decimal Equiv. — Fraction
0.765625 — 49/64
0.781250 — 25/32
0.796875 — 51/64
0.812500 — 13/16
0.828125 — 53/64
0.843750 — 27/32
0.859375 — 55/64
0.875000 — 7/8
0.890625 — 57/64
0.906250 — 29/32
0.921875 — 59/64
0.937500 — 15/16
0.953125 — 61/64
0.968750 — 31/32
0.984375 — 63/64
1.000000 — 1

Inch	Millimeters
0	0
$\frac{1}{128}$	0.1984375
$\frac{1}{64}$	0.396875
$\frac{3}{128}$	0.5953125
$\frac{1}{32}$	0.79375
$\frac{5}{128}$	0.9921875
$\frac{3}{64}$	1.190625
$\frac{7}{128}$	1.3890625
$\frac{1}{16}$	1.5875

$\frac{1}{16}$	1.5875
$\frac{1}{8}$	3.175
$\frac{3}{16}$	4.7625
$\frac{1}{4}$	6.35
$\frac{5}{16}$	7.9375
$\frac{3}{8}$	9.525
$\frac{7}{16}$	11.1125
$\frac{1}{2}$	12.7
$\frac{9}{16}$	14.2875
$\frac{5}{8}$	15.875
$\frac{11}{16}$	17.4625
$\frac{3}{4}$	19.05
$\frac{13}{16}$	20.6375
$\frac{7}{8}$	22.225
$\frac{15}{16}$	23.8125
1	25.4
$\frac{1}{16}$	26.9875
$\frac{1}{8}$	28.575
$\frac{1}{4}$	30.1625
$\frac{1}{2}$	31.75
$\frac{5}{8}$	33.3375
$\frac{3}{4}$	34.925
$\frac{7}{8}$	36.5125
$\frac{1}{2}$	38.1
$\frac{1}{4}$	39.6875
$\frac{1}{8}$	41.275
$\frac{1}{16}$	42.8625
$\frac{1}{32}$	44.45
$\frac{1}{64}$	46.0375
$\frac{1}{128}$	47.625
$\frac{1}{256}$	49.2125
2	50.8

METRIC CONVERSION TABLE	
Example: Convert 3.7664 meters to feet, inches and fractions Using the feet to meter table, 12 ft. = 3.6576 So now convert 3.7664m - 3.6576m = 108.8mm Using the inch to millimeter table, $\frac{1}{4}$ in. = 107.95mm So now convert 108.8mm - 107.95mm = 0.85mm Using the inch to millimeter table, $\frac{1}{32}$ = 0.79375	Example: Convert 15 ft. $\frac{6}{16}$ in. to meters Using the feet to meter table, 15 ft. = 4.572 meters Using the inch to millimeter table, $\frac{6}{16}$ in. = .1635125 meters Thus, 15 ft. $\frac{6}{16}$ in. = 4.7355125 meters

Inch	Millimeters
$\frac{2}{16}$	52.3875
$\frac{2}{8}$	53.975
$\frac{2}{16}$	55.5625
$\frac{2}{4}$	57.15
$\frac{2}{16}$	58.7375
$\frac{2}{8}$	60.325
$\frac{2}{16}$	61.9125
$\frac{2}{2}$	63.5
$\frac{2}{16}$	65.0875
$\frac{2}{8}$	66.675
$\frac{2}{16}$	68.2625
$\frac{2}{4}$	69.85
$\frac{2}{16}$	71.4375
$\frac{2}{8}$	73.025
$\frac{2}{16}$	74.6125
3	76.2

Inch	Millimeters
$\frac{4}{16}$	103.1875
$\frac{4}{8}$	104.775
$\frac{4}{16}$	106.3625
$\frac{4}{4}$	107.95
$\frac{4}{16}$	109.5375
$\frac{4}{8}$	111.125
$\frac{4}{16}$	112.7125
$\frac{4}{2}$	114.3
$\frac{4}{16}$	115.8875
$\frac{4}{8}$	117.475
$\frac{4}{16}$	119.0625
$\frac{4}{4}$	120.65
$\frac{4}{16}$	122.2375
$\frac{4}{8}$	123.825
$\frac{4}{16}$	125.4125
5	127

Inch	Millimeters
$\frac{6}{16}$	153.9875
$\frac{6}{8}$	155.575
$\frac{6}{16}$	157.1625
$\frac{6}{4}$	158.75
$\frac{6}{16}$	160.3375
$\frac{6}{8}$	161.925
$\frac{6}{16}$	163.5125
$\frac{6}{2}$	165.1
$\frac{6}{16}$	166.6875
$\frac{6}{8}$	168.275
$\frac{6}{16}$	169.8625
$\frac{6}{4}$	171.45
$\frac{6}{16}$	173.0375
$\frac{6}{8}$	174.625
$\frac{6}{16}$	176.2125
7	177.8

Inch	Millimeters
$\frac{8}{16}$	204.7875
$\frac{8}{8}$	206.375
$\frac{8}{16}$	207.9625
$\frac{8}{4}$	209.55
$\frac{8}{16}$	211.1375
$\frac{8}{8}$	212.725
$\frac{8}{16}$	214.3125
$\frac{8}{2}$	215.9
$\frac{8}{16}$	217.4875
$\frac{8}{8}$	219.075
$\frac{8}{16}$	220.6625
$\frac{8}{4}$	222.25
$\frac{8}{16}$	223.8375
$\frac{8}{8}$	225.425
$\frac{8}{16}$	227.0125
9	228.6

Inch	Millimeters
$\frac{10}{16}$	255.5875
$\frac{10}{8}$	257.175
$\frac{10}{16}$	258.7625
$\frac{10}{4}$	260.35
$\frac{10}{16}$	261.9375
$\frac{10}{8}$	263.525
$\frac{10}{16}$	265.1125
$\frac{10}{2}$	266.7
$\frac{10}{16}$	268.2875
$\frac{10}{8}$	269.875
$\frac{10}{16}$	271.4625
$\frac{10}{4}$	273.05
$\frac{10}{16}$	274.6375
$\frac{10}{8}$	276.225
$\frac{10}{16}$	277.8125
11	279.4

$\frac{3}{16}$	77.7875
$\frac{3}{8}$	79.375
$\frac{3}{16}$	80.9625
$\frac{3}{4}$	82.55
$\frac{3}{16}$	84.1375
$\frac{3}{8}$	85.725
$\frac{3}{16}$	87.3125
$\frac{3}{2}$	88.9
$\frac{3}{16}$	90.4875
$\frac{3}{8}$	92.075
$\frac{3}{16}$	93.6625
$\frac{3}{4}$	95.25
$\frac{3}{16}$	96.8375
$\frac{3}{8}$	98.425
$\frac{3}{16}$	100.0125
4	101.6

$\frac{5}{16}$	128.5875
$\frac{5}{8}$	130.175
$\frac{5}{16}$	131.7625
$\frac{5}{4}$	133.35
$\frac{5}{16}$	134.9375
$\frac{5}{8}$	136.525
$\frac{5}{16}$	138.1125
$\frac{5}{2}$	139.7
$\frac{5}{16}$	141.2875
$\frac{5}{8}$	142.875
$\frac{5}{16}$	144.4625
$\frac{5}{4}$	146.05
$\frac{5}{16}$	147.6375
$\frac{5}{8}$	149.225
$\frac{5}{16}$	150.8125
6	152.4

$\frac{7}{16}$	179.3875
$\frac{7}{8}$	180.975
$\frac{7}{16}$	182.5625
$\frac{7}{4}$	184.15
$\frac{7}{16}$	185.7375
$\frac{7}{8}$	187.325
$\frac{7}{16}$	188.9125
$\frac{7}{2}$	190.5
$\frac{7}{16}$	192.0875
$\frac{7}{8}$	193.675
$\frac{7}{16}$	195.2625
$\frac{7}{4}$	196.85
$\frac{7}{16}$	198.4375
$\frac{7}{8}$	200.025
$\frac{7}{16}$	201.6125
8	203.2

$\frac{9}{16}$	230.1875
$\frac{9}{8}$	231.775
$\frac{9}{16}$	233.3625
$\frac{9}{4}$	234.95
$\frac{9}{16}$	236.5375
$\frac{9}{8}$	238.125
$\frac{9}{16}$	239.7125
$\frac{9}{2}$	241.3
$\frac{9}{16}$	242.8875
$\frac{9}{8}$	244.475
$\frac{9}{16}$	246.0625
$\frac{9}{4}$	247.65
$\frac{9}{16}$	249.2375
$\frac{9}{8}$	250.825
$\frac{9}{16}$	252.4125
10	254

$\frac{11}{16}$	280.9875
$\frac{11}{8}$	282.575
$\frac{11}{16}$	284.1625
$\frac{11}{4}$	285.75
$\frac{11}{16}$	287.3375
$\frac{11}{8}$	288.925
$\frac{11}{16}$	290.5125
$\frac{11}{2}$	292.1
$\frac{11}{16}$	293.6875
$\frac{11}{8}$	295.275
$\frac{11}{16}$	296.8625
$\frac{11}{4}$	298.45
$\frac{11}{16}$	300.0375
$\frac{11}{8}$	301.625
$\frac{11}{16}$	303.2125
12	304.8

Feet	Meters
1	0.3048
2	0.6096
3	0.9144
4	1.2192
5	1.524
6	1.8288
7	2.1336
8	2.4384
9	2.7432
10	3.048
11	3.3528
12	3.6576
13	3.9624
14	4.2672
15	4.572
16	4.8768
17	5.1816
18	5.4864
19	5.7912
20	6.096

Feet	Meters
21	6.4008
22	6.7056
23	7.0104
24	7.3152
25	7.62
26	7.9248
27	8.2296
28	8.5344
29	8.8392
30	9.144
31	9.4488
32	9.7536
33	10.0584
34	10.3632
35	10.668
36	10.9728
37	11.2776
38	11.5824
39	11.8872
40	12.192

Feet	Meters
41	12.4968
42	12.8016
43	13.1064
44	13.4112
45	13.716
46	14.0208
47	14.3256
48	14.6304
49	14.9352
50	15.24
51	15.5448
52	15.8496
53	16.1544
54	16.4592
55	16.764
56	17.0688
57	17.3736
58	17.6784
59	17.9832
60	18.288

Feet	Meters
61	18.5928
62	18.8976
63	19.2024
64	19.5072
65	19.812
66	20.1168
67	20.4216
68	20.7264
69	21.0312
70	21.336
71	21.6408
72	21.9456
73	22.2504
74	22.5552
75	22.86
76	23.1648
77	23.4696
78	23.7744
79	24.0792
80	24.384

Feet	Meters
81	24.6888
82	24.9936
83	25.2984
84	25.6032
85	25.908
86	26.2128
87	26.5176
88	26.8224
89	27.1272
90	27.432
91	27.7368
92	28.0416
93	28.3464
94	28.6512
95	28.956
96	29.2608
97	29.5656
98	29.8704
99	30.1752
100	30.48

The following formulas are used in the computation of the values shown in the table:

$$\begin{aligned} \uparrow \text{weight of pipe per foot (pounds)} &= 10.6802t (D - t) \\ \text{weight of water per foot (pounds)} &= 0.3405 \times d^2 \\ \text{square feet outside surface per foot} &= \pi/12 \times D \\ \text{squarefeet inside surface perfoot} &= \pi/12 \times d \\ \text{inside area (square inches)} &= \pi/4 \times d^2 \\ \text{area of metal (square inches)} &= \pi/4 \times (D^2 - d^2) \\ \text{moment of inertia (inches}^4\text{)} &= \pi/64 \times (D^2 - d^2) = A_m R_g^2 \\ \text{section modulus (inches}^3\text{)} &= \pi/32 \times (D^4 - d^4)/D \\ \text{radius of gyration (inches)} &= \sqrt{(D^2 - d^2)/4} \end{aligned}$$

Where:

A_m = area of metal (square inches)
 d = inside diameter (inches)
 D = outside diameter (inches)
 R_g = radius of gyration (inches)

t = pipewall thickness(inches)

Note:

† The ferritic steels may be about 5% less, and the austenitic stainless steels about 2% greater than the values shown in this table which are based on weights for carbon steel.

* Schedule Numbers

Standard weight pipe and schedule 40 are the same in all sizes through 10-inch from 12-inch through 24-inch, standard weight pipe has a wall thickness of 3/8-inch.

Extra strong weight pipe and schedule 80 are the same in all sizes through 8-inch; from 8-inch through 24-inch, extra strong weight pipe has a wall thickness of 1/2.

Double extra strong weight pipe has no corresponding schedule number.

a: ANSI B36.10 steel pipe schedule numbers

b: ANSI B36.10 steel pipe nominal wall thickness designation

c: ANSI B36.19 stainless steel pipe schedule numbers

Nom. Pipe Size, O.D. Inches	Schedule Number*			Wall Thickness Inch	Inside Diameter Inch	Inside Area Sq. In.	Metal Area Sq. In.	Outside Surface Sq. Ft./Ft.	Inside Surface Sq. Ft./Ft.	Weight per Foot Lbs.†	Weight of Water per Foot Lbs.	Moment of Inertia In. ⁴	Section Modulus In. ³	Radius Gyration In.
	a	b	c											
1/8 0.4050	—	—	10S	0.049	0.307	0.0740	0.0548	0.106	0.0804	0.186	0.0321	0.00088	0.00437	0.1271
	40	Std	40S	0.068	0.269	0.0568	0.0720	0.106	0.0704	0.245	0.0246	0.00106	0.00525	0.1215
	80	XS	80S	0.095	0.215	0.0363	0.0925	0.106	0.0563	0.315	0.0157	0.00122	0.00600	0.1146
1/4 0.5400	—	—	10S	0.065	0.410	0.132	0.0970	0.141	0.1073	0.330	0.0572	0.00279	0.0103	0.1695
	40	Std	40S	0.088	0.364	0.104	0.125	0.141	0.0953	0.425	0.0451	0.00331	0.0123	0.1628
	80	XS	80S	0.119	0.302	0.072	0.157	0.141	0.0791	0.535	0.0311	0.00377	0.0139	0.1547
3/8 0.6750	—	—	10S	0.065	0.545	0.233	0.125	0.177	0.1427	0.423	0.1011	0.00586	0.0174	0.2169
	40	Std	40S	0.091	0.493	0.191	0.167	0.177	0.1291	0.568	0.0828	0.00729	0.0216	0.2090
	80	XS	80S	0.126	0.423	0.141	0.217	0.177	0.1107	0.739	0.0609	0.00862	0.0255	0.1991
1/2 0.8400	—	—	5S	0.065	0.710	0.396	0.158	0.220	0.1859	0.538	0.172	0.01197	0.0285	0.2750
	—	—	10S	0.083	0.674	0.357	0.197	0.220	0.1765	0.671	0.155	0.01431	0.0341	0.2692
	40	Std	40S	0.109	0.622	0.304	0.250	0.220	0.1628	0.851	0.132	0.01709	0.0407	0.2613
	80	XS	80S	0.147	0.546	0.234	0.320	0.220	0.1429	1.09	0.102	0.02008	0.0478	0.2505
	160	—	—	0.187	0.466	0.171	0.384	0.220	0.1220	1.30	0.074	0.02212	0.0527	0.2402
	—	XXS	—	0.294	0.252	0.050	0.504	0.220	0.0660	1.71	0.022	0.02424	0.0577	0.2192
3/4 1.0500	—	—	5S	0.065	0.920	0.665	0.201	0.275	0.2409	0.684	0.288	0.02450	0.0467	0.349
	—	—	10S	0.083	0.884	0.614	0.252	0.275	0.2314	0.857	0.266	0.02969	0.0566	0.343
	40	Std	40S	0.113	0.824	0.533	0.333	0.275	0.2157	1.13	0.231	0.03704	0.0705	0.334
	80	XS	80S	0.154	0.742	0.432	0.433	0.275	0.1943	1.47	0.187	0.04479	0.0853	0.321
	160	—	—	0.218	0.614	0.296	0.570	0.275	0.1607	1.94	0.128	0.05269	0.1004	0.304
	—	XXS	—	0.308	0.434	0.148	0.718	0.275	0.1136	2.44	0.064	0.05792	0.1103	0.284
1 1.3150	—	—	5S	0.065	1.185	1.103	0.255	0.344	0.3102	0.868	0.478	0.04999	0.0760	0.443
	—	—	10S	0.109	1.097	0.945	0.413	0.344	0.2872	1.40	0.410	0.07569	0.1151	0.428
	40	Std	40S	0.133	1.049	0.864	0.494	0.344	0.2746	1.68	0.375	0.08734	0.1328	0.421
	80	XS	80S	0.179	0.957	0.719	0.639	0.344	0.2505	2.17	0.312	0.10561	0.1606	0.407
	160	—	—	0.250	0.815	0.522	0.836	0.344	0.2134	2.84	0.226	0.12512	0.1903	0.387
	—	XXS	—	0.358	0.599	0.282	1.076	0.344	0.1568	3.66	0.122	0.14046	0.2136	0.361
1 1/4 1.6600	—	—	5S	0.065	1.530	1.839	0.326	0.435	0.4006	1.11	0.797	0.10375	0.1250	0.564
	—	—	10S	0.109	1.442	1.633	0.531	0.435	0.3775	1.81	0.708	0.16049	0.1934	0.550
	40	Std	40S	0.140	1.380	1.496	0.669	0.435	0.3613	2.27	0.648	0.19471	0.2346	0.540
	80	XS	80S	0.191	1.278	1.283	0.881	0.435	0.3346	3.00	0.556	0.24179	0.2913	0.524
	160	—	—	0.250	1.160	1.057	1.107	0.435	0.3037	3.76	0.458	0.28386	0.3420	0.506
	—	XXS	—	0.382	0.896	0.631	1.534	0.435	0.2346	5.21	0.273	0.34110	0.4110	0.472

Nom. Pipe Size, O.D. Inches	Schedule Number*			Wall Thickness Inch	Inside Diameter Inch	Inside Area Sq. In.	Metal Area Sq. In.	Outside Surface Sq. Ft./Ft.	Inside Surface Sq. Ft./Ft.	Weight per Foot Lbs.†	Weight of Water per Foot Lbs.	Moment of Inertia In. ⁴	Section Modulus In. ³	Radius Gyration In.
	a	b	c											
1 1/2 1.9000	–	–	5S	0.065	1.770	2.461	0.375	0.497	0.4634	1.27	1.067	0.15792	0.1662	0.649
	–	–	10S	0.109	1.682	2.222	0.613	0.497	0.4403	2.08	0.963	0.24682	0.2598	0.634
	40	Std	40S	0.145	1.610	2.036	0.799	0.497	0.4215	2.72	0.883	0.30989	0.3262	0.623
	80	XS	80S	0.200	1.500	1.767	1.068	0.497	0.3927	3.63	0.766	0.39121	0.4118	0.605
	160	–	–	0.281	1.338	1.406	1.429	0.497	0.3503	4.86	0.610	0.48239	0.5078	0.581
	–	XXS	–	0.400	1.100	0.950	1.885	0.497	0.2880	6.41	0.412	0.56784	0.5977	0.549
	–	–	–	0.525	0.850	0.567	2.268	0.497	0.2225	7.71	0.246	0.61409	0.6464	0.520
	–	–	–	0.650	0.600	0.283	2.553	0.497	0.1571	8.68	0.123	0.63335	0.6667	0.498
2 2.3750	–	–	5S	0.065	2.245	3.958	0.472	0.622	0.5877	1.60	1.716	0.31489	0.2652	0.817
	–	–	10S	0.109	2.157	3.654	0.776	0.622	0.5647	2.64	1.584	0.49919	0.4204	0.802
	40	Std	40S	0.154	2.067	3.356	1.075	0.622	0.5411	3.65	1.455	0.66575	0.5606	0.787
	80	XS	80S	0.218	1.939	2.953	1.477	0.622	0.5076	5.02	1.280	0.86792	0.7309	0.766
	160	–	–	0.343	1.689	2.241	2.190	0.622	0.4422	7.44	0.971	1.16232	0.9788	0.729
	–	XXS	–	0.436	1.503	1.774	2.656	0.622	0.3935	9.03	0.769	1.31130	1.104	0.703
	–	–	–	0.562	1.251	1.229	3.201	0.622	0.3275	10.9	0.533	1.44157	1.214	0.671
	–	–	–	0.687	1.001	0.787	3.643	0.622	0.2621	12.4	0.341	1.51251	1.274	0.644
2 1/2 2.8750	–	–	5S	0.083	2.709	5.764	0.728	0.753	0.7092	2.47	2.499	0.71002	0.4939	0.988
	–	–	10S	0.120	2.635	5.453	1.039	0.753	0.6898	3.53	2.364	0.98725	0.6868	0.975
	40	Std	40S	0.203	2.469	4.788	1.704	0.753	0.6464	5.79	2.076	1.52955	1.064	0.947
	80	XS	80S	0.276	2.323	4.238	2.254	0.753	0.6082	7.66	1.837	1.92423	1.339	0.924
	160	–	–	0.375	2.125	3.547	2.945	0.753	0.5563	10.0	1.538	2.35274	1.637	0.894
	–	XXS	–	0.552	1.771	2.463	4.028	0.753	0.4636	13.7	1.068	2.87079	1.997	0.844
	–	–	–	0.675	1.525	1.827	4.665	0.753	0.3992	15.9	0.792	3.08819	2.148	0.814
	–	–	–	0.800	1.275	1.277	5.215	0.753	0.3338	17.7	0.554	3.22396	2.243	0.786
3 3.5000	–	–	5S	0.083	3.334	8.730	0.891	0.916	0.8728	3.03	3.785	1.30116	0.7435	1.208
	–	–	10S	0.120	3.260	8.347	1.274	0.916	0.8535	4.33	3.619	1.82196	1.041	1.196
	40	Std	40S	0.216	3.068	7.393	2.228	0.916	0.8032	7.58	3.205	3.01716	1.724	1.164
	80	XS	80S	0.300	2.900	6.605	3.016	0.916	0.7592	10.3	2.864	3.89432	2.225	1.136
	160	–	–	0.437	2.626	5.416	4.205	0.916	0.6875	14.3	2.348	5.03192	2.875	1.094
	–	XXS	–	0.600	2.300	4.155	5.466	0.916	0.6021	18.6	1.801	5.99251	3.424	1.047
	–	–	–	0.725	2.050	3.301	6.320	0.916	0.5367	21.5	1.431	6.49924	3.714	1.014
	–	–	–	0.850	1.800	2.545	7.076	0.916	0.4712	24.1	1.103	6.85088	3.915	0.984
3 1/2 4.0000	–	–	5S	0.083	3.834	11.545	1.021	1.05	1.004	3.47	5.005	1.95972	0.9799	1.385
	–	–	10S	0.120	3.760	11.104	1.463	1.05	0.9844	4.97	4.814	2.75519	1.378	1.372
	40	Std	40S	0.226	3.548	9.887	2.680	1.05	0.9289	9.11	4.286	4.78772	2.394	1.337
	80	XS	80S	0.318	3.364	8.888	3.678	1.05	0.8807	12.5	3.853	6.28009	3.140	1.307
	–	XXS	–	0.636	2.728	5.845	6.721	1.05	0.7142	22.9	2.534	9.84776	4.924	1.210
4 4.5000	–	–	5S	0.083	4.334	14.753	1.152	1.18	1.135	3.92	6.396	2.80979	1.249	1.562
	–	–	10S	0.120	4.260	14.253	1.651	1.18	1.115	5.61	6.179	3.96268	1.761	1.549
	–	–	–	0.188	4.124	13.358	2.547	1.18	1.080	8.66	5.791	5.93033	2.636	1.526
	40	Std	40S	0.237	4.026	12.730	3.174	1.18	1.054	10.8	5.519	7.23260	3.214	1.510
	80	XS	80S	0.337	3.826	11.497	4.407	1.18	1.002	15.0	4.984	9.61049	4.271	1.477
	120	–	–	0.437	3.626	10.326	5.578	1.18	0.9493	19.0	4.477	11.6433	5.175	1.445
	–	–	–	0.500	3.500	9.621	6.283	1.18	0.9163	21.4	4.171	12.7627	5.672	1.425
	160	–	–	0.531	3.438	9.283	6.621	1.18	0.9001	22.5	4.025	13.2710	5.898	1.416
	–	XXS	–	0.674	3.152	7.803	8.101	1.18	0.8252	27.5	3.383	15.2837	6.793	1.374
	–	–	–	0.800	2.900	6.605	9.299	1.18	0.7592	31.6	2.864	16.6570	7.403	1.338
	–	–	–	0.925	2.650	5.515	10.389	1.18	0.6938	35.3	2.391	17.7081	7.870	1.306

Nom. Pipe Size, O.D. Inches	Schedule Number*			Wall Thickness Inch	Inside Diameter Inch	Inside Area Sq. In.	Metal Area Sq. In.	Outside Surface Sq. Ft./Ft.	Inside Surface Sq. Ft./Ft.	Weight per Foot Lbs.†	Weight of Water per Foot Lbs.	Moment of Inertia In. ⁴	Section Modulus In. ³	Radius Gyration In.
	a	b	c											
5 5.5630	—	—	5S	0.109	5.345	22.438	1.868	1.46	1.399	6.35	9.728	6.94713	2.498	1.929
	—	—	10S	0.134	5.295	22.020	2.285	1.46	1.386	7.77	9.547	8.42536	3.029	1.920
	40	Std	40S	0.258	5.047	20.006	4.300	1.46	1.321	14.6	8.673	15.1622	5.451	1.878
	80	XS	80S	0.375	4.813	18.194	6.112	1.46	1.260	20.8	7.888	20.6707	7.431	1.839
	120	—	—	0.500	4.563	16.353	7.953	1.46	1.195	27.0	7.090	25.7317	9.251	1.799
	160	—	—	0.625	4.313	14.610	9.696	1.46	1.129	33.0	6.334	30.0259	10.79	1.760
	—	XXS	—	0.750	4.063	12.965	11.340	1.46	1.064	38.6	5.621	33.6348	12.09	1.722
	—	—	—	0.875	3.813	11.419	12.887	1.46	0.9982	43.8	4.951	36.6355	13.17	1.686
	—	—	—	1.000	3.563	9.971	14.335	1.46	0.9328	48.7	4.323	39.1007	14.06	1.652
6 6.6250	—	—	5S	0.109	6.407	32.240	2.231	1.73	1.677	7.59	13.98	11.8454	3.576	2.304
	—	—	10S	0.134	6.357	31.739	2.733	1.73	1.664	9.29	13.76	14.3974	4.346	2.295
	—	—	—	0.129	6.367	31.839	2.633	1.73	1.667	8.95	13.80	13.8918	4.194	2.297
	40	Std	40S	0.280	6.065	28.890	5.581	1.73	1.588	19.0	12.53	28.1422	8.496	2.245
	80	XS	80S	0.432	5.761	26.067	8.405	1.73	1.508	28.6	11.30	40.4907	12.22	2.195
	120	—	—	0.562	5.501	23.767	10.705	1.73	1.440	36.4	10.30	49.6106	14.98	2.153
	160	—	—	0.718	5.189	21.147	13.324	1.73	1.358	45.3	9.168	58.9732	17.80	2.104
	—	XXS	—	0.864	4.897	18.834	15.637	1.73	1.282	53.2	8.165	66.3326	20.02	2.060
	—	—	—	1.000	4.625	16.800	17.671	1.73	1.211	60.1	7.284	72.1009	21.77	2.020
8 8.6250	—	—	—	1.125	4.375	15.033	19.439	1.73	1.145	66.1	6.517	76.5775	23.12	1.985
	—	—	5S	0.109	8.407	55.510	2.916	2.26	2.201	9.91	24.07	26.4402	6.131	3.011
	—	—	10S	0.148	8.329	54.485	3.941	2.26	2.181	13.4	23.62	35.4145	8.212	2.998
	—	—	—	0.219	8.187	52.643	5.783	2.26	2.143	19.7	22.82	51.1172	11.85	2.973
	20	—	—	0.250	8.125	51.849	6.578	2.26	2.127	22.4	22.48	57.7220	13.38	2.962
	30	—	—	0.277	8.071	51.162	7.265	2.26	2.113	24.7	22.18	63.3527	14.69	2.953
	40	Std	40S	0.322	7.981	50.027	8.399	2.26	2.089	28.6	21.69	72.4892	16.81	2.938
	60	—	—	0.406	7.813	47.943	10.483	2.26	2.045	35.6	20.79	88.7363	20.58	2.909
	80	XS	80S	0.500	7.625	45.664	12.763	2.26	1.996	43.4	19.80	105.716	24.51	2.878
	100	—	—	0.593	7.439	43.463	14.963	2.26	1.948	50.9	18.84	121.324	28.13	2.847
	120	—	—	0.718	7.189	40.591	17.836	2.26	1.882	60.6	17.60	140.535	32.59	2.807
	140	—	—	0.812	7.001	38.496	19.931	2.26	1.833	67.8	16.69	153.722	35.65	2.777
	160	—	—	0.906	6.813	36.456	21.970	2.26	1.784	74.7	15.80	165.887	38.47	2.748
	—	—	—	1.000	6.625	34.472	23.955	2.26	1.734	81.4	14.94	177.087	41.06	2.719
10 10.7500	—	—	—	1.125	6.375	31.919	26.507	2.26	1.669	90.1	13.84	190.572	44.19	2.681
	—	—	5S	0.134	10.482	86.294	4.469	2.81	2.744	15.2	37.41	62.9675	11.71	3.75
	—	—	10S	0.165	10.420	85.276	5.487	2.81	2.728	18.7	36.97	76.8638	14.30	3.74
	—	—	—	0.219	10.312	83.517	7.245	2.81	2.700	24.6	36.21	100.485	18.69	3.72
	20	—	—	0.250	10.250	82.516	8.247	2.81	2.683	28.0	35.77	113.714	21.16	3.71
	30	—	—	0.307	10.136	80.691	10.072	2.81	2.654	34.2	34.98	137.420	25.57	3.69
	40	Std	40S	0.365	10.020	78.854	11.908	2.81	2.623	40.5	34.19	160.734	29.90	3.67
	60	XS	80S	0.500	9.750	74.662	16.101	2.81	2.553	54.7	32.37	211.950	39.43	3.63
	80	—	—	0.593	9.564	71.840	18.922	2.81	2.504	64.3	31.15	244.844	45.55	3.60
	100	—	—	0.718	9.314	68.134	22.629	2.81	2.438	76.9	29.54	286.132	53.23	3.56
	120	—	—	0.843	9.064	64.525	26.237	2.81	2.373	89.2	27.97	324.225	60.32	3.52
	—	—	—	0.875	9.000	63.617	27.145	2.81	2.356	92.3	27.58	333.485	62.04	3.51
	140	—	—	1.000	8.750	60.132	30.631	2.81	2.291	104	26.07	367.806	68.43	3.47
	160	—	—	1.125	8.500	56.745	34.018	2.81	2.225	116	24.60	399.308	74.29	3.43
	—	—	—	1.250	8.250	53.456	37.306	2.81	2.160	127	23.18	428.149	79.66	3.39
	—	—	—	1.500	7.750	47.173	43.590	2.81	2.029	148	20.45	478.464	89.02	3.31



Nom. Pipe Size, O.D. Inches	Schedule Number*			Wall Thickness Inch	Inside Diameter Inch	Inside Area Sq. In.	Metal Area Sq. In.	Outside Surface Sq. Ft./Ft.	Inside Surface Sq. Ft./Ft.	Weight per Foot Lbs.†	Weight of Water per Foot Lbs.	Moment of Inertia In. ⁴	Section Modulus In. ³	Radius Gyration In.
	a	b	c											
12 12.7500	–	–	5S	0.156	12.438	121.504	6.172	3.34	3.256	21.0	52.68	122.389	19.20	4.45
	–	–	10S	0.180	12.390	120.568	7.108	3.34	3.244	24.2	52.27	140.419	22.03	4.44
	20	–	–	0.250	12.250	117.859	9.817	3.34	3.207	33.4	51.10	191.824	30.09	4.42
	30	–	–	0.330	12.090	114.800	12.876	3.34	3.165	43.8	49.77	248.453	38.97	4.39
	–	Std	40S	0.375	12.000	113.097	14.579	3.34	3.142	49.6	49.03	279.335	43.82	4.38
	40	–	–	0.406	11.938	111.932	15.745	3.34	3.125	53.5	48.53	300.209	47.09	4.37
	–	XS	80S	0.500	11.750	108.434	19.242	3.34	3.076	65.4	47.01	361.544	56.71	4.33
	60	–	–	0.562	11.626	106.157	21.519	3.34	3.044	73.2	46.02	400.420	62.81	4.31
	80	–	–	0.687	11.376	101.641	26.035	3.34	2.978	88.5	44.07	475.104	74.53	4.27
	–	–	–	0.750	11.250	99.402	28.274	3.34	2.945	96.1	43.09	510.926	80.15	4.25
	100	–	–	0.843	11.064	96.142	31.534	3.34	2.897	107	41.68	561.650	88.10	4.22
	–	–	–	0.875	11.000	95.033	32.643	3.34	2.880	111	41.20	578.523	90.75	4.21
	120	–	–	1.000	10.750	90.763	36.914	3.34	2.814	125	39.35	641.664	100.7	4.17
	140	–	–	1.125	10.500	86.590	41.086	3.34	2.749	140	37.54	700.551	109.9	4.13
	–	–	–	1.250	10.250	82.516	45.160	3.34	2.683	154	35.77	755.378	118.5	4.09
	160	–	–	1.312	10.126	80.531	47.145	3.34	2.651	160	34.91	781.126	122.5	4.07
14 14.0000	–	–	5S	0.156	13.688	147.153	6.785	3.67	3.584	23.1	63.80	162.564	23.22	4.89
	–	–	10S	0.188	13.624	145.780	8.158	3.67	3.567	27.7	63.20	194.566	27.80	4.88
	–	–	–	0.210	13.580	144.840	9.098	3.67	3.555	30.9	62.79	216.308	30.90	4.88
	–	–	–	0.219	13.562	144.457	9.481	3.67	3.551	32.2	62.63	225.142	32.16	4.87
	10	–	–	0.250	13.500	143.139	10.799	3.67	3.534	36.7	62.06	255.300	36.47	4.86
	–	–	–	0.281	13.438	141.827	12.111	3.67	3.518	41.2	61.49	285.047	40.72	4.85
	20	–	–	0.312	13.376	140.521	13.417	3.67	3.502	45.6	60.92	314.384	44.91	4.84
	–	–	–	0.344	13.312	139.180	14.758	3.67	3.485	50.2	60.34	344.242	49.18	4.83
	30	Std	–	0.375	13.250	137.886	16.052	3.67	3.469	54.6	59.78	372.760	53.25	4.82
	40	–	–	0.437	13.126	135.318	18.620	3.67	3.436	63.3	58.67	428.607	61.23	4.80
	–	–	–	0.469	13.062	134.001	19.937	3.67	3.420	67.8	58.09	456.819	65.26	4.79
	–	XS	–	0.500	13.000	132.732	21.206	3.67	3.403	72.1	57.54	483.756	69.11	4.78
	60	–	–	0.593	12.814	128.961	24.977	3.67	3.355	84.9	55.91	562.287	80.33	4.74
	–	–	–	0.625	12.750	127.676	26.262	3.67	3.338	89.3	55.35	588.530	84.08	4.73
	80	–	–	0.750	12.500	122.718	31.220	3.67	3.272	106	53.20	687.318	98.19	4.69
	100	–	–	0.937	12.126	115.485	38.453	3.67	3.175	131	50.07	824.436	117.8	4.63
	120	–	–	1.093	11.814	109.618	44.320	3.67	3.093	151	47.52	929.521	132.8	4.58
	140	–	–	1.250	11.500	103.869	50.069	3.67	3.011	170	45.03	1027.20	146.7	4.53
	160	–	–	1.406	11.188	98.309	55.629	3.67	2.929	189	42.62	1116.65	159.5	4.48
16 16.0000	–	–	5S	0.165	15.670	192.854	8.208	4.19	4.102	27.9	83.61	257.303	32.16	5.60
	–	–	10S	0.188	15.624	191.723	9.339	4.19	4.090	31.7	83.12	291.904	36.49	5.59
	10	–	–	0.250	15.500	188.692	12.370	4.19	4.058	42.1	81.81	383.664	47.96	5.57
	20	–	–	0.312	15.376	185.685	15.377	4.19	4.025	52.3	80.50	473.248	59.16	5.55
	30	Std	–	0.375	15.250	182.654	18.408	4.19	3.992	62.6	79.19	562.084	70.26	5.53
	40	–	–	0.500	15.000	176.715	24.347	4.19	3.927	82.8	76.61	731.942	91.49	5.48
	60	–	–	0.656	14.688	169.440	31.622	4.19	3.845	108	73.46	932.336	116.5	5.43
	80	–	–	0.843	14.314	160.921	40.141	4.19	3.747	136	69.77	1156.29	144.5	5.37
	100	–	–	1.031	13.938	152.578	48.484	4.19	3.649	165	66.15	1364.43	170.6	5.30
	120	–	–	1.218	13.564	144.499	56.563	4.19	3.551	192	62.65	1555.41	194.4	5.24
	140	–	–	1.437	13.126	135.318	65.744	4.19	3.436	224	58.67	1759.86	220.0	5.17
	160	–	–	1.593	12.814	128.961	72.101	4.19	3.355	245	55.91	1893.54	236.7	5.12

Nom. Pipe Size, O.D. Inches	Schedule Number*			Wall Thickness Inch	Inside Diameter Inch	Inside Area Sq. In.	Metal Area Sq. In.	Outside Surface Sq. Ft./Ft.	Inside Surface Sq. Ft./Ft.	Weight per Foot Lbs.†	Weight of Water per Foot Lbs.	Moment of Inertia In. ⁴	Section Modulus In. ³	Radius Gyration In.
	a	b	c											
18 18.0000	—	—	5S	0.165	17.670	245.224	9.245	4.71	4.626	31.4	106.3	367.621	40.85	6.31
	—	—	10S	0.188	17.624	243.949	10.520	4.71	4.614	35.8	105.8	417.258	46.36	6.30
	—	—	—	0.250	17.500	240.528	13.941	4.71	4.581	47.4	104.3	549.138	61.02	6.28
	20	—	—	0.312	17.376	237.132	17.337	4.71	4.549	58.9	102.8	678.244	75.36	6.25
	—	Std	—	0.375	17.250	233.705	20.764	4.71	4.516	70.6	101.3	806.631	89.63	6.23
	30	—	—	0.437	17.126	230.357	24.112	4.71	4.484	82.0	99.87	930.264	103.4	6.21
	—	XS	—	0.500	17.000	226.980	27.489	4.71	4.451	93.5	98.40	1053.17	117.0	6.19
	40	—	—	0.562	16.876	223.681	30.788	4.71	4.418	105	96.97	1171.49	130.2	6.17
	60	—	—	0.750	16.500	213.825	40.644	4.71	4.320	138	92.70	1514.64	168.3	6.10
	80	—	—	0.937	16.126	204.241	50.228	4.71	4.222	171	88.55	1833.47	203.7	6.04
	100	—	—	1.156	15.688	193.297	61.172	4.71	4.107	208	83.80	2179.69	242.2	5.97
	120	—	—	1.375	15.250	182.654	71.815	4.71	3.992	244	79.19	2498.09	277.6	5.90
	140	—	—	1.562	14.876	173.805	80.664	4.71	3.895	274	75.35	2749.11	305.5	5.84
	160	—	—	1.781	14.438	163.721	90.748	4.71	3.780	309	70.98	3019.96	335.6	5.77
20 20.0000	—	—	5S	0.188	19.624	302.458	11.701	5.24	5.138	39.8	131.1	574.172	57.42	7.00
	—	—	10S	0.218	19.564	300.611	13.548	5.24	5.122	46.1	130.3	662.796	66.28	6.99
	10	—	—	0.250	19.500	298.648	15.512	5.24	5.105	52.7	129.5	756.434	75.64	6.98
	20	Std	—	0.375	19.250	291.039	23.120	5.24	5.040	78.6	126.2	1113.47	111.3	6.94
	30	XS	—	0.500	19.000	283.529	30.631	5.24	4.974	104	122.9	1456.86	145.7	6.90
	40	—	—	0.593	18.814	278.005	36.155	5.24	4.925	123	120.5	1703.71	170.4	6.86
	60	—	—	0.812	18.376	265.211	48.948	5.24	4.811	166	115.0	2256.74	225.7	6.79
	—	—	—	0.875	18.250	261.587	52.573	5.24	4.778	179	113.4	2408.69	240.9	6.77
	80	—	—	1.031	17.938	252.719	61.440	5.24	4.696	209	109.6	2771.62	277.2	6.72
	100	—	—	1.281	17.438	238.827	75.332	5.24	4.565	256	103.5	3315.02	331.5	6.63
	120	—	—	1.500	17.000	226.980	87.179	5.24	4.451	296	98.40	3754.15	375.4	6.56
	140	—	—	1.750	16.500	213.825	100.335	5.24	4.320	341	92.70	4215.62	421.6	6.48
	160	—	—	1.968	16.064	202.674	111.486	5.24	4.206	379	87.87	4585.21	458.5	6.41
22 22.0000	—	—	5S	0.188	21.624	367.250	12.883	5.76	5.661	43.8	159.2	766.190	69.65	7.71
	—	—	10S	0.218	21.564	365.215	14.918	5.76	5.645	50.7	158.3	884.816	80.44	7.70
	10	—	—	0.250	21.500	363.050	17.082	5.76	5.629	58.1	157.4	1010.26	91.84	7.69
	20	Std	—	0.375	21.250	354.656	25.476	5.76	5.563	86.6	153.8	1489.67	135.4	7.65
	30	XS	—	0.500	21.000	346.361	33.772	5.76	5.498	115	150.2	1952.45	177.5	7.60
	—	—	—	0.625	20.750	338.163	41.970	5.76	5.432	143	146.6	2399.00	218.1	7.56
	—	—	—	0.750	20.500	330.064	50.069	5.76	5.367	170	143.1	2829.69	257.2	7.52
	60	—	—	0.875	20.250	322.062	58.070	5.76	5.301	197	139.6	3244.91	295.0	7.48
	80	—	—	1.125	19.750	306.354	73.778	5.76	5.171	251	132.8	4030.43	366.4	7.39
	100	—	—	1.375	19.250	291.039	89.094	5.76	5.040	303	126.2	4758.50	432.6	7.31
	120	—	—	1.625	18.750	276.117	104.016	5.76	4.909	354	119.7	5432.00	493.8	7.23
	140	—	—	1.875	18.250	261.587	118.546	5.76	4.778	403	113.4	6053.72	550.3	7.15
	160	—	—	2.125	17.750	247.450	132.683	5.76	4.647	451	107.3	6626.39	602.4	7.07



Nom. Pipe Size, O.D. Inches	Schedule Number*			Wall Thickness Inch	Inside Diameter Inch	Inside Area Sq. In.	Metal Area Sq. In.	Outside Surface Sq. Ft./Ft.	Inside Surface Sq. Ft./Ft.	Weight per Foot Lbs. †	Weight of Water per Foot Lbs.	Moment of Inertia In. ⁴	Section Modulus In. ³	Radius Gyration In.
	a	b	c											
24 24.0000	10	—	—	0.250	23.500	433.736	18.653	6.28	6.152	63.4	188.0	1315.34	109.6	8.40
	20	Std	—	0.375	23.250	424.557	27.833	6.28	6.087	94.6	184.1	1942.30	161.9	8.35
	—	XS	—	0.500	23.000	415.476	36.914	6.28	6.021	125	180.1	2549.35	212.4	8.31
	30	—	—	0.562	22.876	411.008	41.382	6.28	5.989	141	178.2	2843.20	236.9	8.29
	—	—	—	0.625	22.750	406.493	45.897	6.28	5.956	156	176.2	3136.93	261.4	8.27
	40	—	—	0.687	22.626	402.073	50.316	6.28	5.923	171	174.3	3421.28	285.1	8.25
	—	—	—	0.750	22.500	397.608	54.782	6.28	5.890	186	172.4	3705.46	308.8	8.22
	—	—	5S	0.218	23.564	436.102	16.288	6.28	6.169	55.4	189.1	1151.59	95.97	8.41
	—	—	—	0.875	22.250	388.821	63.568	6.28	5.825	216	168.6	4255.34	354.6	8.18
	60	—	—	0.968	22.064	382.348	70.042	6.28	5.776	238	165.8	4652.61	387.7	8.15
	80	—	—	1.218	21.564	365.215	87.174	6.28	5.645	296	158.3	5671.82	472.7	8.07
	100	—	—	1.531	20.938	344.318	108.071	6.28	5.482	367	149.3	6851.69	571.0	7.96
	120	—	—	1.812	20.376	326.083	126.307	6.28	5.334	429	141.4	7824.55	652.0	7.87
	140	—	—	2.062	19.876	310.276	142.114	6.28	5.204	483	134.5	8625.01	718.8	7.79
	160	—	—	2.343	19.314	292.978	159.412	6.28	5.056	542	127.0	9455.42	788.0	7.70
26 26.0000	—	—	—	0.250	25.500	510.705	20.224	6.81	6.676	68.8	221.4	1676.38	129.0	9.10
	10	—	—	0.312	25.376	505.750	25.179	6.81	6.643	85.6	219.3	2077.16	159.8	9.08
	—	Std	—	0.375	25.250	500.740	30.189	6.81	6.610	103	217.1	2478.42	190.6	9.06
	20	XS	—	0.500	25.000	490.874	40.055	6.81	6.545	136	212.8	3257.00	250.5	9.02
	—	—	—	0.625	24.750	481.105	49.824	6.81	6.480	169	208.6	4012.56	308.7	8.97
	—	—	—	0.750	24.500	471.435	59.494	6.81	6.414	202	204.4	4745.57	365.0	8.93
	—	—	—	0.875	24.250	461.863	69.066	6.81	6.349	235	200.2	5456.48	419.7	8.89
	—	—	—	1.000	24.000	452.389	78.540	6.81	6.283	267	196.1	6145.74	472.7	8.85
	—	—	—	1.125	23.750	443.014	87.916	6.81	6.218	299	192.1	6813.80	524.1	8.80
28 28.0000	—	—	—	0.250	27.500	593.957	21.795	7.33	7.199	74.1	257.5	2098.09	149.9	9.81
	10	—	—	0.312	27.376	588.613	27.139	7.33	7.167	92.3	255.2	2601.02	185.8	9.79
	—	Std	—	0.375	27.250	583.207	32.545	7.33	7.134	111	252.8	3105.12	221.8	9.77
	20	XS	—	0.500	27.000	572.555	43.197	7.33	7.069	147	248.2	4084.81	291.8	9.72
	30	—	—	0.625	26.750	562.001	53.751	7.33	7.003	183	243.6	5037.66	359.8	9.68
	—	—	—	0.750	26.500	551.546	64.206	7.33	6.938	218	239.1	5964.16	426.0	9.64
	—	—	—	0.875	26.250	541.188	74.564	7.33	6.872	253	234.6	6864.82	490.3	9.60
	—	—	—	1.000	26.000	530.929	84.823	7.33	6.807	288	230.2	7740.10	552.9	9.55
	—	—	—	1.125	25.750	520.768	94.984	7.33	6.741	323	225.8	8590.49	613.6	9.51
30 30.0000	—	—	5S	0.250	29.500	683.493	23.366	7.85	7.723	79.4	296.3	2585.18	172.3	10.52
	10	—	10S	0.312	29.376	677.759	29.099	7.85	7.691	98.9	293.8	3206.31	213.8	10.50
	—	Std	—	0.375	29.250	671.957	34.901	7.85	7.658	119	291.3	3829.44	255.3	10.47
	20	XS	—	0.500	29.000	660.520	46.338	7.85	7.592	158	286.4	5042.21	336.1	10.43
	30	—	—	0.625	28.750	649.181	57.678	7.85	7.527	196	281.4	6224.01	414.9	10.39
	40	—	—	0.750	28.500	637.940	68.919	7.85	7.461	234	276.6	7375.38	491.7	10.34
	—	—	—	0.875	28.250	626.797	80.062	7.85	7.396	272	271.7	8496.84	566.5	10.30
	—	—	—	1.000	28.000	615.752	91.106	7.85	7.330	310	267.0	9588.93	639.3	10.26
	—	—	—	1.125	27.750	604.806	102.053	7.85	7.265	347	262.2	10652.1	710.1	10.22
32 32.0000	—	—	—	0.250	29.500	683.493	23.366	7.85	7.723	79.4	296.3	2585.18	172.3	10.52
	10	—	—	0.312	31.376	773.188	31.060	8.38	8.214	106	335.2	3898.89	243.7	11.20
	—	Std	—	0.375	31.250	766.990	37.257	8.38	8.181	127	332.5	4658.48	291.2	11.18
	20	XS	—	0.500	31.000	754.768	49.480	8.38	8.116	168	327.2	6138.62	383.7	11.14
	30	—	—	0.625	30.750	742.643	61.605	8.38	8.050	209	322.0	7583.39	474.0	11.09
	40	—	—	0.688	30.624	736.569	67.678	8.38	8.017	230	319.3	8298.32	518.6	11.07
	—	—	—	0.750	30.500	730.617	73.631	8.38	7.985	250	316.8	8993.35	562.1	11.05
	—	—	—	0.875	30.250	718.688	85.559	8.38	7.919	291	311.6	10369.1	648.1	11.01
	—	—	—	1.000	30.000	706.858	97.389	8.38	7.854	331	306.5	11711.1	731.9	10.97
	—	—	—	1.125	29.750	695.126	109.121	8.38	7.789	371	301.4	13020.0	813.7	10.92

Nom. Pipe Size, O.D. Inches	Schedule Number*			Wall Thickness Inch	Inside Diameter Inch	Inside Area Sq. In.	Metal Area Sq. In.	Outside Surface Sq. Ft./Ft.	Inside Surface Sq. Ft./Ft.	Weight per Foot Lbs. †	Weight of Water per Foot Lbs.	Moment of Inertia In. ⁴	Section Modulus In. ³	Radius Gyration In.
	a	b	c											
34 34.0000	–	–	–	0.250	33.500	881.413	26.507	8.90	8.770	90.1	382.1	3774.38	222.0	11.93
	10	–	–	0.312	33.376	874.900	33.020	8.90	8.738	112	379.3	4684.65	275.6	11.91
	–	Std	–	0.375	33.250	868.307	39.614	8.90	8.705	135	376.4	5599.28	329.4	11.89
	20	XS	–	0.500	33.000	855.288	52.632	8.90	8.639	179	370.8	7384.89	434.4	11.85
	30	–	–	0.625	32.750	842.389	65.532	8.90	8.574	223	365.2	9127.59	536.9	11.80
	40	–	–	0.688	32.624	835.919	72.001	8.90	8.541	245	362.4	9991.61	587.7	11.78
	–	–	–	0.750	32.500	829.577	78.343	8.90	8.508	266	359.7	10832.2	637.2	11.76
	–	–	–	0.875	32.250	816.863	91.057	8.90	8.443	310	354.1	12497.9	735.2	11.72
	–	–	–	1.000	32.000	804.248	103.673	8.90	8.378	352	348.7	14125.4	830.9	11.67
	–	–	–	1.125	31.750	791.730	116.190	8.90	8.312	395	343.2	15715.1	924.4	11.63
36 36.0000	–	–	–	0.250	35.500	989.798	28.078	9.42	9.294	95.5	429.1	4485.90	249.2	12.64
	10	–	–	0.312	35.376	982.895	34.981	9.42	9.261	119	426.1	5569.48	309.4	12.62
	–	Std	–	0.375	35.250	975.906	41.970	9.42	9.228	143	423.1	6658.92	369.9	12.60
	20	XS	–	0.500	35.000	962.113	55.763	9.42	9.163	190	417.1	8786.20	488.1	12.55
	30	–	–	0.625	34.750	948.417	69.459	9.42	9.098	236	411.2	10868.4	603.8	12.51
	40	–	–	0.750	34.500	934.820	83.056	9.42	9.032	282	405.3	12906.1	717.0	12.47
	–	–	–	0.875	34.250	921.321	96.555	9.42	8.967	328	399.4	14900.0	827.8	12.42
	–	–	–	1.000	34.000	907.920	109.956	9.42	8.901	374	393.6	16850.7	936.2	12.38
	–	–	–	1.125	33.750	894.618	123.258	9.42	8.836	419	387.9	18758.9	1042.2	12.34
	–	–	–	1.250	33.500	881.413	136.652	9.42	8.770	464	382.1	20715.1	1157.2	12.30
42 42.0000	–	–	–	0.250	41.500	1352.652	32.790	11.00	10.86	111	586.4	7144.71	340.2	14.76
	–	Std	–	0.375	41.250	1336.404	49.038	11.00	10.80	167	579.4	10621.6	505.8	14.72
	20	XS	–	0.500	41.000	1320.254	65.188	11.00	10.73	222	572.4	14035.8	668.4	14.67
	30	–	–	0.625	40.750	1304.203	81.240	11.00	10.67	276	565.4	17388.1	828.0	14.63
	40	–	–	0.750	40.500	1288.249	97.193	11.00	10.60	330	558.5	20679.3	984.7	14.59
	–	–	–	1.000	40.000	1256.637	128.805	11.00	10.47	438	544.8	27081.3	1289.6	14.50
	–	–	–	1.250	39.500	1225.417	160.025	11.00	10.34	544	531.3	33247.7	1583.2	14.41
	–	–	–	1.500	39.000	1194.591	190.852	11.00	10.21	649	517.9	39184.3	1865.9	14.33







ANVIL MANUFACTURED PRODUCTS

Columbia, PA Foundry

1411 Lancaster Avenue
Columbia, PA 17512
Tel: 717-684-4400 • Fax: 717-684-6868
Paul Suor — Plant Manager

Henderson, TN Plant

2870 Old Jackson Road
Henderson, TN 38340
Tel: 731-989-3551 • Fax: 731-989-4144
Rich Brooks — Plant Manager

Canvil

390 Second Avenue
Simcoe, ON Canada N3Y 4K9
Tel: 519-426-4551 • Fax: 519-426-5509
Brent Widdifield — Plant Manager

Longview, TX Plant

305 Simms
Longview, TX 75604
Tel: 903-759-4417 • Fax: 903-759-1782
Van O'Keefe — Plant Manager

J.B. Smith

6618 Navigation
Houston, TX 77011
Tel: 713-928-5711 • Fax: 713-928-6733
Ray Mullenix — Plant Manager

North Kingstown, RI Plant

160 Frenchtown Road
North Kingstown, RI 02852
Tel: 401-886-3001 • Fax: 401-886-3010
Robert Taylor — General Manager

ENGINEERED PIPE SUPPORTS

- Structural Fabrication
 - Field Services
 - Non-destructive Testing
- Contact: North Kingstown, RI Plant
401-886-3001

For Sales and Service Information

Contact the Regional Service

Center Nearest You or Visit Our Website at

www.anvilintl.com

NORTH EAST REGION

Regional Service Center: Servicing Connecticut, Delaware, Maine, Maryland, Massachusetts, New Hampshire, New Jersey, New York, East Pennsylvania, Rhode Island, Vermont, Virginia

2530 Pearl Buck Road
Bristol, PA 19007
Tel: 215-788-4056 • Fax: 215-788-4475
Dean Taylor — Regional Vice President

MID WEST REGION

Regional Service Center: Servicing Illinois, Indiana, Iowa, Kansas, Kentucky, Michigan, Minnesota, Missouri, Nebraska, North and South Dakota, Ohio, West Pennsylvania, West Virginia, Wisconsin

750 Central Avenue
University Park, IL 60466
Tel: 708-534-1414 • Fax: 708-534-5441
Toll Free: 1-800-301-2701

Dean Taylor — Regional Vice President

Satellite Offices

1201 W. 96th Street
Bloomington, MN 55431
Tel: 952-884-7131 • Fax: 952-887-1501
Toll Free: 1-800-733-7131

9530 Le Saint Drive
Fairfield, OH 45014
Tel: 513-682-2330 • Fax: 513-870-0109
Toll Free: 1-800-837-2424

8615 East 33rd Street
Indianapolis, IN 46226
Tel: 317-895-2424 • Fax: 317-895-2430
Toll Free: 1-800-837-1515

1930 Warren Street
Kansas City, MO 64116
Tel: 816-474-0500 • Fax: 816-221-7150
Toll Free: 1-800-877-7007

24600 Northline Road
Taylor, MI 48180
Tel: 734-947-3083 • Fax: 734-947-4682
Toll Free: 1-800-279-1601

WESTERN REGION

Regional Service Center: Servicing Alaska, Arizona, California, Hawaii, Idaho, Montana, Nevada, Oregon, Utah, Washington

1385 Greg Street
Sparks, NV 89431
Tel: 775-331-7029 • Fax: 775-331-5075
Toll Free: 1-800-572-0051

Bob Arison — Regional Vice President

Satellite Offices

P.O. Box 10206
Portland, OR 97210
Tel: 503-223-7101 • Fax: 503-223-7130
14103 Borate St.
Sante Fe Springs, CA 90670
Tel: 562-802-7459 • Fax: 562-802-7519

Corporate Offices

110 Corporate Drive, Suite 10 • P.O. Box 3180
Portsmouth, NH 03802-3180
Tel: 603-422-8000 • Fax: 603-422-8033
E-mail address — Webmaster@anvilintl.com
www.anvilintl.com

SOUTH WEST AND SOUTH EAST REGION

Regional Service Center: Servicing Alabama, Arkansas, Colorado, Florida, Georgia, Louisiana, Mississippi, New Mexico, North and South Carolina, Oklahoma, Tennessee, Texas, Wyoming

1313 Avenue R
Grand Prairie, TX 75050
Tel: 972-343-9206 • Fax: 972-641-8946
Toll Free: 1-800-451-4414

Bob Arison — Regional Vice President

Satellite Offices

6999 Old Clinton Rd
Houston, TX 77020
Tel: 713-675-6371 • Fax: 713-678-7858

2600 W. 42nd Street
Odessa, TX 79764
Tel: 915-366-2803 • Fax: 915-366-0890

4200 Holly Street
Denver, CO 80216
Tel: 303-394-2178 • Fax: 303-321-3050

Sales Office

1202 Tech Blvd., Suite 103
Tampa, FL 33619
Tel: 800-429-0703 • Fax: 813-663-0811

CANADA — MUELLER-FLOW CONTROL

Kevin Fullan — Vice President
Tel: 905-664-1459 ext 272

Doug Crawford — National Marketing Manager
Tel: 905-664-1459 ext 248

Alberta

Calgary — Tel: 403-246-0033 • Fax: 403-246-0051
Edmonton — Tel: 780-452-9841 • Fax: 780-452-9873

British Columbia

Delta — Tel: 604-940-1449 • Fax: 604-940-9878
Nanaimo — Tel: 250-758-1551 • Fax: 250-758-1160
Prince George — Tel: 250-561-1219 • Fax: 250-561-7358
Vancouver City — Tel: 604-875-6990 • Fax: 604-875-6962

Manitoba

Winnipeg — Tel: 204-774-3461 • Fax: 204-786-5044

Ontario

Stoney Creek — Tel: 905-664-9230 • Fax: 906-664-9556
Toronto — Tel: 416-251-4171 • Fax: 416-251-7087
Sarnia — Tel: 519-336-7690 • Fax: 519-336-1621
Sudbury — Tel: 705-671-9600 • Fax: 705-671-8082

Quebec

Montreal — Tel: 514-342-2100 • Fax: 514-342-2177
Ste-Foy — Tel: 418-650-5766 • Fax: 418-266-0252

Saskatchewan

Regina — Tel: 306-543-5536 • Fax: 306-545-0390
Saskatoon — Tel: 306-242-6788 • Fax: 306-242-5089