

CHAPTER 48. HEAT EXCHANGERS

HEAT EXCHANGERS transfer heat from one fluid to another without the fluids coming in direct contact with each other. Heat transfer occurs in a heat exchanger when a fluid changes from a liquid to a vapor (evaporator), a vapor to a liquid (condenser), or when two fluids transfer heat without a phase change. The transfer of energy is caused by a temperature difference. In most HVAC&R applications, heat exchangers are selected to transfer either sensible or latent heat. Sensible heat applications involve transfer of heat from one liquid to another. Latent heat transfer results in a phase change of one of the liquids; transferring heat to a liquid by condensing steam is a common example. This chapter describes some of the fundamentals, types, components, applications, selection criteria, and installation of heat exchangers. [Chapter 4 of the 2013 ASHRAE Handbook—Fundamentals](#) covers the subject of heat transfer. Specific applications of heat exchangers are detailed in other chapters of this and other volumes of the Handbook series.

1. FUNDAMENTALS

When heat is exchanged between two fluids flowing through a heat exchanger, the rate of heat transferred may be calculated using

$$Q = UAM_m \tag{1}$$

where  
 $U$  = overall coefficient of heat transfer from fluid to fluid  
 $A$  = heat transfer area of the heat exchanger associated with  $U$   
 $\Delta t_m$  = log mean temperature difference (LMTD)  
For a heat exchanger with a constant  $U$ , the  $\Delta t_m$  is calculated as

$$\Delta t_m = C_f \frac{(T_1 - t_2) - (T_2 - t_1)}{\ln[(T_1 - t_2)/(T_2 - t_1)]} \tag{2}$$

where the temperature distribution is as shown in [Figure 1](#) and  $C_f$  is a correction factor (less than 1.0) that is applied to heat exchanger configurations that do not follow a true counterflow design. [Figure 1](#) shows a **temperature cross**, where the outlet temperature of the heating fluid is less than the outlet temperature of the fluid being heated ( $T_2 < t_2$ ). A temperature cross can only be obtained with a heat exchanger that has a 100% true counterflow arrangement. The overall coefficient  $U$  is affected by the physical arrangement of the surface area  $A$ . For a given load, not all heat exchangers with equal surface areas perform equally. For this reason, load conditions must be defined when selecting a heat exchanger for a specific application.




Figure 1. Temperature Distribution in Counterflow Heat Exchanger

The load for each fluid stream can be calculated as

$$Q = mc_p(t_{out} - t_{in}) \tag{3}$$

The value of  $\Delta t_m$  is an important factor in heat exchanger selection. If the value  $\Delta t_m$  is high, a relatively small heat exchange surface area is required for a given load. The economic effect is that the heat exchanger must be designed to accommodate the forces and movements associated with large temperature differences. When the **approach temperature** (the difference between  $T_2$  and  $t_2$ ) is small,  $\Delta t_m$  is also small and a relatively large  $A$  is required. [Chapter 4 of the 2013 ASHRAE Handbook—Fundamentals](#) describes an alternative method of evaluating heat exchanger performance that involves the exchanger heat transfer effectiveness  $\epsilon$  and number of exchanger transfer units (NTU). This method is based on the same assumptions as the logarithmic mean temperature difference method described previously.

2. TYPES OF HEAT EXCHANGERS

Most heat exchangers for HVAC&R applications are counterflow shell-and-tube or plate units. While both types physically separate the fluids transferring heat, their construction is very different, and each has unique application and performance qualities.

Shell-and-Tube Heat Exchangers

[Figure 2](#) shows the counterflow path of a shell-and-tube heat exchanger. The fluid at temperature  $T_2$  enters one end of the shell, flows outside the tubes and inside the shell, and exits at the other end at temperature  $T_1$ . The other fluid flows inside the tubes, entering one end at temperature  $t_1$  and exiting at the opposite end at temperature  $t_2$ . In a shell-and-tube heat exchanger, a tube bundle assembly is welded or bolted inside a tubular shell. The bundle is constructed of metal tubes mechanically rolled or welded at one (U-tube) or both ends (straight-tube) into tubesheet(s) that function as headers. The shell is usually a length of pipe that has inlet and outlet connections located along one or more of its longitudinal centerlines.




Figure 2. Counterflow Path in Shell-and-Tube Heat Exchanger

The shell is flanged at one or both open ends to accommodate a head assembly. The tube bundle is positioned between the shell and head assemblies so that the tube wall of the bundle mechanically separates the two flow paths. The tube bundle is assembled with tube supports, which are held together with tie rods and spacers. Units with liquid on the shell side have baffles for tube supports that direct the flow. Condensers must have baffles that have been notched on the bottom to allow the liquid condensate to flow freely to the exit nozzle. The head assembly directs the other fluid across the tubesheet(s) into and out of the tube bundle. Head assemblies are designed with pass partitions to isolate sections of the tube bundle such that the fluid must traverse the length of the unit one, two, four, or more times before exiting. One of two types of head assemblies is mechanically attached to the shell. Units with multiple tube-side pass construction have a head with both an inlet and outlet connection bolted at one end with a welded cap (U-tube) or bolted reversing head (straight-tube) at the opposite shell end. Single-pass units have an inlet head attached at one shell end and an outlet head attached at the other end.




Figure 3. U-Tube Shell-and-Tube Heat Exchanger with Removable Bundle Assembly and Cast K-Pattern Flanged Head




Figure 4. U-Tube Tank Heater with Removable Bundle Assembly and Cast Bonnet Head

Many variations of the shell-and-tube design are available, some of which are described in the following paragraphs. **U-Tube.** [Figure 3](#) shows a U-tube removable-bundle shell-and-tube heat exchanger. These units are commonly called **converters**. [Figures 4 and 5](#) depict modifications of the U-tube design. Tank heaters are U-tube heat exchangers with the shell replaced by a mounting collar, which is welded to a tank. A hot fluid or steam flows inside the tubes heating the fluid in the tank by natural convection. The tank heater manufacturer should be consulted about optimizing the bundle length. Although it is desirable for the bundle to significantly extend into the tank, the designer must consider the need for additional bundle support.




Figure 5. U-Tube Tank Suction Heater with Removable Bundle Assembly and Cast Flanged Head

Tank suction heaters differ from tank heaters because they have an additional opening that allows fluid being heated to be pumped across the outside tube wall resulting in improved thermal performance. **Straight-Tube.** [Figures 6 and 7](#) show two common designs of straight-tube, shell-and-tube exchangers, one with a fixed and the other with a removable tube bundle assembly. Some straight-tube, shell-and-tube heat exchangers have a floating head bolted with a gasket to a floating tubesheet or a shell-side expansion joint. This configuration is expensive and is rarely specified in HVAC applications.




Figure 6. Straight-Tube Fixed Tubesheet Shell-and-Tube Heat Exchanger with Fabricated Bonnet Heads and Split-Shell Flow Design




Figure 7. Straight-Tube Floating Tubesheet Shell-and-Tube Heat Exchanger with Removable Bundle Assembly and Fabricated Channel Heads

**Shell-and-Coil.** The tubes in this heat exchanger are coiled in a helical configuration around a small core. A spacer is placed between the tube layers. In some designs the tubes have an oval cross section. These heat exchangers are very compact and have a relatively large surface area for their size. [Figures 5 in Chapter 42](#) shows a shell-and-coil heat exchanger.

Plate Heat Exchangers

Plate heat exchangers consist of metal plate pairs arranged to provide separate flow paths (channels) for two fluids. Heat transfer occurs across the plate walls. The exchangers have multiple channels that are mounted on a frame and clamped together. The rectangular plates have an opening or port at each corner. When assembled, the plates are sealed so that the ports provide manifolds to distribute fluids through the separate flow paths. [Figure 8](#) shows the flow paths. The multiple plates, called a **plate pack**, are supported by a carrying bar and contained by pressure plates at each end. This design allows the units to be opened for maintenance or addition or removal of plate pairs. The adjoining plates are gasketed, welded, or brazed together. Gasketed-plate heat exchangers are typically limited to design pressures of 300 psig. The type of gasket material used limits the operating temperature. Brazed-plate units are designed for pressures up to 450 psig and temperatures up to 500°F.




Figure 8. Flow Path of Gasketed-Plate Heat Exchanger

**Gasketed.** The most common plate heat exchanger is the gasketed-plate unit. Typically, nitrile butyl rubber (NBR) gaskets are used in applications up to 230°F. Ethylene-propylene terpolymer (EPDM) gaskets are available for temperatures up to 320°F. The gaskets are glued or clipped onto the plates. The gasket pattern on each plate creates the counterflow paths illustrated in [Figure 8](#). **Semiwelded.** Two plates can be welded together at the edges into an assembly called a **cassette**. This flow channel contains fluids when appropriate gasket material is not available such as for handling corrosive fluids. The channels containing the nonaggressive fluids are sealed with standard gaskets. Semiwelded units can also be used for refrigeration applications. [Figure 9](#) shows the flow path of a welded-plate heat exchanger. **Brazed.** Brazed-plate heat exchangers have neither gaskets nor frames ([Figure 10](#)). They consist of plates brazed together with a copper or nickel flux. This design can be very cost effective in closed-system applications where lack of maintenance is not a concern.




Figure 9. Flow Path of Welded-Plate Heat Exchanger

Double-Wall Heat Exchangers

Double-wall heat exchangers have a leakage path that warns of mechanical failure before fluids can be cross contaminated. Both shell-and-tube and plate heat exchangers are available. The overall thermal performance of a double-wall unit is less than a comparable single-wall design. Double-wall units cost significantly more than single-wall units.




Figure 10. Brazed-Plate Heat Exchanger

A double-wall tube (Figure 11) consists of a tube-in-tube design fabricated into double tubesheets. The outer tube is rolled into the inner tubesheet. The inner tube is finned or has grooves cut in it. It is rolled into the outer tubesheet to provide a vented leak path between tubesheets to provide a visible indication of a failure of either tube. A double-wall plate for a gasketed plate-and-frame heat exchanger (Figure 12) is constructed by welding two standard channel plates together at the four port openings to form a leak path between the plates should a plate fail. Similarly, a double-wall plate for a brazed-plate heat exchanger (Figure 13) is constructed by brazing two special plates together while maintaining a leak path should the plate fail.

3. COMPONENTS

Heat exchangers for HVAC applications should be constructed and labeled according to the applicable ASME Boiler and Pressure Vessel Code and rated for 150 psig at 375°F. Heat exchangers operating at elevated temperatures or pressures require special construction.



Figure 11. Double-Wall Tube  
(Courtesy Bell & Gossett)

Shell-and-Tube Components

Figure 14 shows the various components of a shell-and-tube exchanger, which include the following:

- **Shells** are usually made of steel pipe; brass and stainless steel are also used. The inlet and outlet nozzles can be made with standard flange openings in various orientations to suit piping needs. The nozzles are sized to avoid excessive fluid velocity and impingement on the tubes opposite a shell inlet connection.
- **Baffles, tube supports, tie rods, and spacers** are usually made of steel; brass and stainless steel are also available. The number and spacing of baffles controls the velocity and, therefore, a significant portion of the shell-side heat transfer coefficient and pressure drop.
- **Tubes** are usually made of copper; special grades of brass and stainless steel can be specified. The tube diameter, gage, and material affect the heat transfer coefficient and performance.
- **Tubesheets** are available in the same materials as baffles, although the materials do not have to be the same in a given heat exchanger. Tubesheets are drilled for a specific tube layout called **pitch**. The holes are sometimes serrated to improve the tube-to-tubesheet joint.
- **Heads** are usually cast iron or fabricated steel. Cast brass and cast stainless steel are available in limited sizes. Heads can be custom fabricated in most metals. The inlet and outlet nozzles can be made with standard flange openings. Figures 3, 4, and 5 show three different head configurations that offer different levels of serviceability and ease of installation.




Figure 12. Double-Wall Plate Cassette for Gasketed Plate and Frame Exchanger




Figure 13. Double-Wall Plate Assembly with Brazed-Plate Exchanger  
(Courtesy Bell & Gossett)




Figure 14. Exploded View of Straight-Tube Heat Exchanger

Plate Components

Figure 15 shows the various components of a gasketed plate and frame heat exchanger. The materials of construction and purpose of the components are as follows:

- **Fixed frame plates** are usually made of carbon steel. Single-pass units have inlet and outlet connections for both fluids located on the fixed frame plate. Connections are usually NPT or stud port design to accommodate ANSI flanges. NPT connections are carbon steel or stainless steel. Stud port connections can be lined with metallic or rubber-type materials to protect against corrosion.
- **Movable pressure plates** can be moved along the length of the carrying bar to allow removal, replacement, or addition of plates. They are made of carbon steel. Multiple-pass units have some connections located on the movable pressure plate.
- **Plate packs** are made up of multiple heat transfer (channel) plates and gaskets. Plates are made of pressable metals, such as 316 or 304 stainless steel or titanium. They are formed with corrugations, typically in a herringbone or chevron pattern. The angle of these patterns affects the thermal performance and pressure drop of a given flow channel.
- **Compression bolts** compress the plate back between the moveable pressure and fixed frame plates. The dimension between the two is critical and is specified by the unit manufacturer for a given plate pack configuration.
- **Carrying and guide bars** support and align the channel plates. The upper bar is called a carrying bar, the lower a guide bar. They are made of stainless steel, aluminum, or carbon steel with zinc chromate finish.
- **Support columns** support the carrying and guide bars on larger plate heat exchangers.
- **Splashguards** are required in the United States by OSHA to enclose exterior channel plate and gasket surfaces. They are usually formed from aluminum.
- **Drip pans** made of stainless steel are often installed under plate heat exchangers to contain leakage on start-up or shut down, gasket failure, or condensation.

4. APPLICATION

Heat exchangers are used when the primary energy source is available for multiple purposes, uses a different medium, or its temperature or pressure is not in the design limits. Most of the following examples are discussed in other chapters and volumes of the *ASHRAE Handbook*. Heat exchangers are used

- To condense steam from a boiler to produce hot water for central water systems
- For service water for potable and nonpotable applications, which is often heated by a converter and hot-water or steam boilers, with or without a storage tank
- To meet special temperature requirements of parts of a system or to protect against freezing in isolated terminal units (coils) and cooling tower basins
- To isolate two systems operating at different pressures while transferring thermal energy between them
- In energy-saving applications such as condensate cooling, vent condensing, boiler blowdown, thermal storage, and chiller bypass (free cooling)
- In many refrigeration applications as evaporators, condensers, and liquid coolers




Figure 15. Components of a Gasketed Plate Heat Exchanger

5. SELECTION CRITERIA

A heat exchanger is often selected by a computer program that optimizes the selection for the given design. A manufacturer should provide detailed selection guidance for both a shell-and-tube and plate exchanger for a given set of conditions. The following list of typical information should be provided to the manufacturer:

- Type of heat exchanger
- Mass flow rates of the hot and cold media
- Inlet temperatures of the hot and cold media

- Outlet temperatures of the hot and cold media
- Steam pressure (if applicable)
- Whether potable water is used
- Any special conditions, such as length, diameter, clearances, water quality, fouling factor, etc.

Thermal/Mechanical Design

Shell-and-tube heat exchangers are designed first to be pressure vessels and second to transfer heat. Plate heat exchangers are designed to transfer heat efficiently within certain temperature and pressure limits.

**Thermal Performance.** The thermal performance of a heat exchanger is a function of the size and geometry of the heat transfer surface area. Heat transfer surface materials also affect performance; for instance, copper has a higher coefficient of heat transfer than stainless steel.

Flow rates (velocity), viscosity, and thermal conductivity of the fluids are significant factors in determining the overall heat transfer coefficient  $U$ . In addition, the fluid to be heated should be on the tube side because the overall  $U$  of a shell-and-tube unit is often reduced if the fluid to be heated is on the shell side.

Properly selected shell-and-tube heat exchangers use tube pass options and shell-side baffle spacing to maximize velocity (turbulence) without causing tube erosion. The ability to maximize velocity on each side of a heat exchanger is particularly important when the two fluids' flow rates are dissimilar. However, fluid velocity in the shell-and-tube heat exchanger is limited to avoid tube erosion. U-tube exchangers have lower tube-side velocity limits than straight-tube units due to the thinner tube wall in the U bends.

Shell-and-tube heat exchangers can be constructed for split-shell flow design (see [Figure 6](#)) to accommodate unusual conditions. These units have one shell inlet connection and two outlet connections.

Plate heat exchangers typically have U-factors three to five times higher than shell-and-tube heat exchangers. The high turbulence created by the corrugated plate design increases convection and increases the U-factor. The plate design achieves a large temperature cross at a 2°F approach because of the counterflow fluid path and high U-factor.

**Thermal Stress.** Heat exchangers must accommodate the thermal stresses associated with large temperature differences. U-tube units offer superior economic performance over straight tube units with removable tube bundles under extreme conditions. Units with fixed tubesheets do not handle large temperature differences well.

Gasketed plate units have a **differential pressure/temperature limitation (DPTL)**, which is the maximum difference in operating pressure of the two fluids at a specific temperature. A unit rated for 300 psig at 260°F might have a DPTL of 220 psig at 200°F.

**Pressure Drop.** Fluid velocity and normal limitations on tube length tend to result in relatively low pressure drops in shell-and-tube heat exchangers. Plate units tend to have larger pressure drops unless the velocity is limited. Often a pressure drop limitation rather than a thermal performance requirement determines the surface area in a plate unit.

**Fouling.** Often, excess surface area is specified to allow for scale accumulation on heat transfer surfaces without a significant reduction of performance. This fouling factor or allowance is applied when sizing the unit. Fouling allowance is better specified as a percentage of excess area rather than as a resistance to heat transfer.

Shell-and-tube exchangers with properly sized tubes can handle suspended solids better than plate units with narrow flow channels. The high fluid velocity and turbulence in plate exchangers make them less susceptible to fouling.

The addition of surface area (tube length) to a shell-and-tube exchanger does not affect fluid velocity, and, therefore, has little effect on thermal performance. This characteristic makes a fouling allowance practical. This is not the case in plate units, for which the number of parallel flow channels determines velocity. This means that as plate pairs are added to meet a load (heat transfer surface area) requirement, the number of channels increases and results in decreased fluid velocity. This lower velocity reduces performance and requires additional plate pairs, which further reduces performance.

**Cost**

On applications with temperature crosses and close approaches, plate heat exchangers usually have the lowest initial cost. Wide temperature approaches often favor shell-and-tube units. If the application requires stainless steel, the plate unit may be more economical.

Maintenance

Shell-and-tube heat exchangers have different degrees of serviceability. The type of header used facilitates access to the inside of the tubes. The heads shown in [Figures 3, 6, and 7](#) can be easily removed without special pipe arrangements. The tube bundles in all of the shell-and-tube units illustrated, except the fixed-tubesheet unit ([Figure 6](#)), can be replaced after the head is removed if they are piped with proper clearance. The diameter and configuration of the tubes are significant in determining whether the inside of tubes of straight-tube units can be mechanically cleaned. [Figure 7](#) shows a type of head that allows cleaning or inspection inside tubes after the channel cover is removed.

Plate heat exchangers can be serviced by sliding the movable pressure plate back along the carrying bars. Individual plates can be removed for cleaning, regasketing, or replacement. Plate pairs can be added for additional capacity. Complete replacement plate packs can be installed.

Space Requirements

Cost-effective and efficient shell-and-tube heat exchangers have small-diameter, long tubes. This configuration often challenges the designer when allocating space required for service and maintenance. For this reason, many shell-and-tube selections have large diameters and short lengths. Although this selection performs well, it often costs more than a smaller-diameter unit with equal surface area. Be careful to provide adequate maintenance clearance around heat exchangers. For shell-and-tube units, space should be left clear so the tube bundle can be removed.

Plate heat exchangers tend to provide the most compact design in terms of surface area for a given space.

Steam

Most HVAC applications using steam are designed with shell-and-tube units. Plate heat exchangers are used in specialized industrial and food processes with steam.

Water Quality

Ensure that the system's water quality is compatible with the materials used in the construction of the heat exchanger.

6. INSTALLATION

**Control.** Heat exchangers are usually controlled by a valve with a temperature sensor. The sensor is placed in the flow stream of the fluid to be heated or cooled. The valve regulates flow on the other side of the heat exchanger to achieve the sensor set-point temperature. [Chapter 47](#) discusses control valves.

**Piping.** Heat exchangers should be piped such that air is easily vented. Pipes must be able to be drained and accessible for service.

**Pressure Relief.** Safety pressure relief valves should be installed on both sides between the heat exchanger and shutoff valves to guard against damage from thermal expansion when the unit is not in service, as well as to protect against overpressurization.

**Flow Path.** The intended flow path of each fluid on both sides of a heat exchanger design should be followed. Failure to connect to the correct inlet and outlet connections may reduce performance.

**Condensate Removal.** Heat exchangers that condense steam require special installation. Proper removal of condensate is particularly important. Inadequate drainage of condensate can result in significant loss of capacity and even in mechanical failure. Installing a vacuum breaker aids in draining condensate, particularly when modulating steam control valves are used. Properly sized and installed steam traps are critical. [Chapter 11](#) discusses steam traps and condensate removal.

**Insulation.** Heat exchangers are often insulated. [Chapters 23, 25, 26, and 27 of the 2013 ASHRAE Handbook—Fundamentals](#) have further information on insulation.